

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Disincherla	Kalmalcheruvu	33KV	Huzurnagar	07.30	11.50	04.20	EL	Due to 33Kv insulator failure near chevarigudem village	Kalmalcheruvu	-
1	RR N	132KV Medchal	33KV Bandamadaram	33KV	Medchal	15.10	19.10	04.00	BD	33KV Cable fault at Kandlakoya Back feeding from 33KV GP Pally -I Feeder	33KV Bandamadaram	-

TSSPDCL - LMRC / Corporate office

Date: 02.07.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Badepally	Gangapur	11KV	Jadcherla	14.10	16.45	02.35		11KV Jumper Cut Near Boilakunta	-
1	NLG	Kethepally	Kasanagodu	11KV	Suryapet	05.00	08.00	03.00	E/L	Jumper cut	-
2		Karvirala	Keshavapuram	11KV	Huzurnagar	15.30	17.30	02.00	EL	Due to jumper Cutted near Keshavapuram village	-
3		Chandur	Kastala	11KV	Nalgonda	05.40	10.15	04.35	E/L	11 KV Line Melting	-
1	RR S	Puppalaguda	Narsing	11KV	RJNR	09.30	11.10	01.40	B/D	11KV insulator failed at Narsing Heights	-
1	RR N	Jeedimetla-I	Phase-V	11KV	Kukatpally	05.45	11.25	05.40	BD	11kv line AB Cable Failue at Thirumala Kantta	-
2		Mayurinagar	Gokarajurangaraju	11KV	Kukatpally	06.40	07.30	00.50	BD	A bird fallon the 11kv line at Gokarajurangaraju	-
3		Chinthal	Bhagathsingh Nagar	11KV	Medchal	06.35	07.30	00.55	BD	Bird fallen on the 11KV Line at Pochamma Temple	-
1	RR E	BANDARAVIRALA	INDUSTRIAL	11KV	SAROOR NAGAR	07.55	10.58	03.03	EL	11KV JUPER CUT AT BANDARAVIRALA	-
2		PEDDA AMBERPET	INDUSTRIAL	11KV	SAROOR NAGAR	09.25	10.30	01.05	EL	TREE BRCHANS FALLIW ON 11KV LINE AT PEDDA AMBEROPET	-
1	HYD N	Miralam	Ranjan Colony	11KV	III	17.55	19.18	01.23	W/O Indication	Breaker fault	Arranged B/F on 11KV Sattar Bagh fdr

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		1		1		1			
5	RR(N)	82	407	1	3	1	3	1	3			
6	RR(E)	38	360		2		2		2			
7	Hyd	186	1014		1		1		1			
	Total	504	2929	1	7	1	7	1	7	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969		1		1		1			
2	NLG	150	948	1	3	1	3	1	3			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	1	4	1	4	1	4	0	0	
	Grand Total	908	6149	2	11	2	11	2	11	0	0	