

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		2		2		2			
5	RR(N)	82	407		4		4		4			
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014		1		1		1			
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		3		3		3			
3	MDK	87	828	1	2	1	2	1	2			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>1</b>	<b>5</b>	<b>1</b>	<b>5</b>	<b>1</b>	<b>5</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>1</b>	<b>13</b>	<b>1</b>	<b>13</b>	<b>1</b>	<b>13</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 04.08.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Manoharabad	Donthanpally	33KV	Toopran	13.25	16.35	03.10		B/D due to after petrolling no fault at found	Donthanpally	-

## TSSPDCL - LMRC / Corporate office

Date: 04.08.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Sh.Gowraram	Kondaram	11KV	Suryapet	08.30	11.00	02.30	E/L	Jumper cut	-
2		Shivannagudem	R.R.Pally	11KV	Devarakonda	08.00	11.00	03.00	E/L	11kv jumper cut	-
3		Kopple	Bollaram	11KV	Devarakonda	14.00	16.30	02.30	E/L	insulator failure	-
1	MDK	Moosapet	Kokya thanda	11KV	Medak	05.00	09.20	04.20		B/D Due to 11KV Jumper cut	-
2		Cheryal	Dhulichand	11KV	Sangareddy	13.30	15.45	02.15		B/D due to Insulator failed at Dhulichand Company side	-
1	RR S	Kokapet	Babukhan	11KV	RJNR	04.30	05.47	01.17		Bat fallen on 11KV line at varun motor outer ring road	-
2		CBIT	Movie towers	11KV	RJNR	14.14	15.30	01.16		No visible fault (due to rain)	-
1	RR N	Gowdavelly	Ayodhya	11KV	Medchal	08.15	09.45	01.30		11KV Brass Patti Cut & Replaced at Gowdavelly Village	-
2		Athiwelly	IDA	11KV	Medchal	11.40	13.55	02.15		Tree fallen on the 11KV Line at Mahalaxmi Venture, Dabeerpur Common	-
3		Yellampet	Yellampet AGL	11KV	Medchal	12.20	13.24	01.04		LT line Touched to the 11KV Line at DRS, Dabeerpur Village(Rain fault)	-
4		Medchal	Town Medchal	11KV	Medchal	14.20	16.50	02.30		11KV Pole damaged at Check post ,Medchal	-
1	RR E	Narapally	P.singaram	11KV	Habsiguda	07.10	08.40	01.30		11kv Disk failed at venkatadri colony	-
1	HYD N	Madhapur	Vaisnavi Residency	11KV	X	15.20	17.15	01.55	EL,OL	Sparking AB Switch at Rathnadeep Super Market	-