

TSSPDCL - LMRC / Corporate office

Date: 05.08.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Manoharabad	Toopran	33KV	Toorpan	05.25	06.45	01.20		B/D due to Jumpet cut at 132/33KV SS Manoharabad		-
2		Chegunta	Yeldurthi	33KV	Toorpan	00.00	00.50	00.50		B/d due to Jumper cut near Shankarampet Village		-

TSSPDCL - LMRC / Corporate office

Date: 05.08.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	T.Giri	Thonda	11KV	Suryapet	05.00	08.00	03.00	E/L	Line melt HT/LT	-
2		Padamatpally	Turupally	11KV	Devarakonda	07.00	10.30	03.30	E/L	11 KV Jumper cut	-
3		Y.Gutta	Mallapur	11KV	Bhongir	06.00	09.00	03.00	E/L	11 KV Jumper Snapped & DTR Failure	-
4		Palakeedu	Palakeedu	11KV	Huzurnagar	10.40	13.25	02.45	OL	11 KV Line cut near palakeedu (v)	-
1	MDK	Ismailkhanpet	Erdanoor	11KV	Sangareddy	11.10	12.10	01.00		B/D Due to Bird fallen on the line at Byathole Village	-
2		Cheryal	Kalivemula	11KV	Sangareddy	10.35	13.20	02.45		B/D Due to AB switch burn at Cherlagudem Villlage	-
3		Cheryal	Indrakaran	11KV	Sangareddy	20:30 (4.07.2017 )	12:10 (5.08.2017 )	15.40		B/D Due to 132KV tower line fallen on 11KV line near Indrakaran	-
1	RR N	Nanakramguda	Church	11KV	GCB	14.55	16.34	01.39	BD	HT Service UG Cable Failure and Cable Jumper's Removed at IRD Company Sub-Station Backside.	-
2		J D M-SSI	Phase-I	11KV	KKP	08.55	10.45	01.50	BD	11kv AB Cable failure Near Sub-Station	-
3		H M T Hills	Sree Ram Nagar	11KV	KKP	19.10	19.40	00.30	BD	A Bird fallen On The 11kv line Near Pt No 102	-
1	RR E	Abdullapermet	Abdullapermet	11KV	Sarooranagar	02.30	04.15	01.45	OL	Agl. DTR AB Switch Sanap at Kawadipally	-
1	HYD N	LV Prasad Marg	Road No. 14	11KV	Banjarahills	12.50	14.22	01.32	EL,OL-Bph	Under Breakdown	Arranged B/F on 11KV Road No.10 feeder

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		3		3		3			
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014		1		1		1			
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		4		4		4			
3	MDK	87	828	2	3	2	3	2	3			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>2</b>	<b>7</b>	<b>2</b>	<b>7</b>	<b>2</b>	<b>7</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>2</b>	<b>12</b>	<b>2</b>	<b>12</b>	<b>2</b>	<b>12</b>	<b>0</b>	<b>0</b>	