

TSSPDCL - LMRC / Corporate office

Date: 07.08.17

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Nagarkurnool	Tadoor	33KV	Nagarkurnool	18.20	20.45	02.25	E/L	Due to Cable burnt near by 132KV NGKL	Tadoor	Alternate Supply Arranged Tadoor to 33KV lthole Feeder at 20:45Hrs
1	MDK	Gajwel	Jagadev pur	33KV	Toopran	16:30	17:40	1:10		BD Due to Jumper Cut	Jagadev pur	No
2		Medak	NSF	33KV	Medak	02.20	07.20	05.00		BD Due to Jumper Cut	NSF	No
1	RR E	Sainikpuri	Kalyan Garden	33KV	Sainikpuri	16:50	17:30	0:40		11Kv Pin Insuletor failure at Kalyan Garden	Kalyan Garden	No
2		Mother Dairy	Kuntloor Ganeshnagar	33KV	Saroornagar	16.05	18.10	02.05	E/L	Tree fallen on the 11KV line	Kuntloor Ganeshnagar	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Mamidala	Aregudem	11KV	Nalgonda	8:00	9:45	1:45	E/L	11 KV Jumper cut	No
2		Dirsincherla	Yellapuram	11KV	Huzurnagar	11.30	14.30	03.00	E/L	11 KV Snapped at Yellapuram village	No
3		Garidepally	L B Nagar	11KV	Huzurnagar	12.20	15.30	03.10	E/L	11KV Jumper cut near L B Nagar viilage	No
4		Siripuram	Vallapuram	11KV	Huzurnagar	14.40	16.35	01.55	E/L	11KV Jumper cut near Vallapuram viilage	No
1	MDK	Kondapur	Gangaram	11KV	Sangareddy	14:30	17:30	3:00		Conductor Snapped at Kondapur (V)	No
2		Yenigandla	Yenigandla	11KV	Medak	14.25	16.50	02.25		BD Due to Jumper Cut	No
3		Palvatla	Nirjipla	11KV	Medak	14.25	16.50	02.25		B/D Due to Insulator failed	No
4		Alladurg	Rampur	11KV	Medak	14.25	16.50	02.25		BD Due to Conductor Snapped	No
1	RR S	Shamshabad	Shamshabad	11KV	Rajendranagar	15:00	16:40	1:40		11kv Disc failed at Huda colony	No
2		Ibrahimbagh	Military-II	11KV	Rajendranagar	14.02	15.13	01.11		T/F HG Fuse insulator failed at Suncity Back side fatima masjid	No
3		Ibrahimbagh	Peddamangalram (IBGH)	11KV	Rajendranagar	14.24	15.24	01.00		T/F HG Fuse Insulator failed at Hydarshakote Laxminagar	No
4		Kattedan-II	Nethajinagar	11KV	Rajendranagar	07.40	08.40	01.00		11KV Insulator failed at Nala	No
1	RR N	HudaTruck Park	Shivalayam	11KV	Kukatpally	13:47	14:29	0:42		11kv End kit failure At Maternity Hospital Kukatpally	No
2		Nizampet	Nizampet	11KV	Kukatpally	14.15	16.42	02.27		T/F Post Off insulator failure at Sakala Basti Nizampet	No
3		G Vikas	Coco Cola	11KV	Kukatpally	17.55	19.19	01.24		11kv Disc failure At CoCo Cola	No
4		Aleap	DR Colony	11KV	Kukatpally	14.30	16.30	02.00		Tree branches fallen On The 11kv Li	No
5		JNTU	SP Nagar	11KV	Gachibowli	13.40	15.00	01.20		No visible fault	No
6		JNTU	SP Nagar	11KV	Gachibowli	18:20	19:40	1:20		T/F Lighting Arrester faied at Plot No-144, Vasanthnagar	No
1	RR E	Chengicherla	My villas	11KV	Habsiguda	14:50	16:03	1:13		Tree fallen on the11kv line	No
2		GKSR	NFC nagar	11KV	Habsiguda	14.50	17.25	02.35		11kv Disc failed	No
3		GKSR	Balaji nagar	11KV	Habsiguda	15.20	17.50	02.30		11kv Cable failed at vigyan collage kondapur village	No
4		Papet	Industrial	11KV	Saroornagar	14.00	14.40	00.40	E/L	No visible fault	No
5		Papet	Taramatipet (AGL)	11KV	Saroornagar	20:30	22:10	1:40	E/L	AGL line AB switch opened at Kalanagar	No
1	HYD N	Prashanth Nagar	Andhra Jyothi	11KV	Bowenpally	13.45	15.55	02.10	EL,OL-Rph	HT Service Pin Insulator flash over at Jaybee Company	No
2		Bowenpally	Kalinga Enclave	11KV	Bowenpally	15:00	16:55	1:55	EL	Pin Insulator flash over at HAL Colony	No
1	HYD S	Jiyaguda	Samastha Narayana	11KV	Begumbazar	14.50	18.45	03.55	EL,OL	Cable fault at Sanjay Nagar	Arranged B/F on 11KV Tappa Chabutra fdr
2		Karwan	Jiyaguda Cable	11KV	Begumbazar	15:05	16:25	1:20	EL,OL-Y&Bph	No Visible Fault	No
1	HYD C	Golconda	Golconda OH	11KV	Mehdipatnam	15.25	16.45	01.20	EL,OL-Rph	Tree branches fallen on Lines at Deccan Park	No
2		Zamisthanpur	Shastry Nagar	11KV	Azamabad	15.55	17.30	01.35	EL	Disc Insulator flash over & Jumper cut at Gemini Colony	No
3		Langer House	Netaji Nagar	11KV	Mehdipatnam	14.30	15.42	01.12	EL	Tree branches fallen on Lines at Netaji Nagar	No

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		4		4		4			
5	RR(N)	82	407		6		6		6			
6	RR(E)	38	360	2	5	2	5	2	5			
7	Hyd	186	1014		7		7		7			
	Total	504	2929	2	22	2	22	2	22	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	1		1		1				
2	NLG	150	948		4		4		4			
3	MDK	87	828	2	4	2	4	2	4			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	3	8	3	8	3	8	0	0	
	Grand Total	908	6149	5	30	5	30	5	30	0	0	