

TSSPDCL - LMRC / Corporate office

Date: 09.08.17

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Toopran	Manoharabad	33KV	Danthanpally	07.05	11:05	04.00		B/D due to Tree fallen on the 33KV Line	Manoharabad	No
2		Toopran	Chegunta	33KV	Bonala	07.55	08.50	00.55		B/D due to 33KV Jumper Cut	Chegunta	No
3		Toopran	Tukkapur	33KV	Lingapur	07.58	10.10	02.12		B/D due to tree fallen on the line	Tukkapur	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Peddarevelly	Peddarevelly	11KV	Jadcherla	11.50	12.50	01.00		11 KV Jumper cut near Bheem Reddy DTR Side.	No
2		Peddarevelly	Industrial	11KV	Jadcherla	13.00	16.00	03.00		11 KV Jumper cut Near Bodagutta tanda,	No
1	NLG	Durajpally	Kaseempeta	11KV	Suryapet	13:20	15:50	2:30	E/L	Disc failed	No
2		Anathram	Hanumapur	11KV	Bhongir	02.00	05.00	03.00	EL	Tree branches fallen on the line	No
3		Anathram	Manchukonda	11KV	Bhongir	08.00	11.25	03.25	EL	11KV Insulator failed	No
4		Kodad town	Tammara	11KV	Huzurnagar	13.00	16.00	03.00	EL	11KV Line snapped	No
5		Siripuram	Vallapuram	11KV	Huzurnagar	11:00	13:00	2:00	EL	11KV Insulator failed	No
1	MDK	Thogita	Kuchanpally	11KV	Medak	4:30	10:35	6:05		B/D due to Jumper Cut at Kuchanpally village	No
2		Rajpally	Rajpally	11KV	Medak	11.40	15.30	03.50		B/D due to 11KV Insulator Fail at Rajpally Villge	No
3		Rajpally	Balanagar	11KV	Medak	05.35	13.50	08.15		B/D due to Tree Fallan on 11Kv Line	No
4		Rajpally	Khajipally	11KV	Medak	11.45	14.10	02.25		B/D due to 11KV Insulator Fail at Khajipally village	No
5		Gavvalapally	Shankarampet R	11KV	Medak	11.10	12.00	00.50		B/D due to 11Kv conductor snapped at Shankarampet village	No
6		Narsapur	Narayanpur	11KV	Medak	07.00	13.20	06.20		B/D due to Tree Fallan on 11Kv Line	No
7		Chippalthurthy	Chippalthurthy	11KV	Medak	04.40	15.00	10.20		B/D due to 11KV Conductor snapped at Nagulapally villge	No
8		Moosapet	Nagulapally	11KV	Medak	06.00	09.00	03.00		B/D due to Tree Fallan on 11Kv Line	No
9		Kothapally	Kothapally	11KV	Medak	06.30	10.30	04.00		B/D due to Insulator fail at Kothapally village	No
10		Medikunda	Medikunda	11KV	Medak	09.05	11.30	02.25		B/D due to Insulator fail	No
11		Gadipeddapur	Gadipeddapur	11KV	Medak	15.10	17.00	01.50		B/D due to Disk fail at peddapur village	No
12		Gajawada	Shad nagar	11KV	Medak	04.00	09.30	05.30		B/D due to Insulator fail	No
13		Shankarampet	Uthloor	11KV	Medak	06.30	11.30	05.00		B/D due to Insulator fail at Uthloor	No
14		Shivampet	Chandi	11KV	Toopran	14.55	15.15	00.20		B/D due to Disk fail	No
15		Yeldurthy	Kukunoor	11KV	Toopran	13.00	18.00	05.00		B/D due to Disk fail	No
16		Chegunta	Bheemraopally	11KV	Toopran	8:15	12:12	3:57		B/D due to Jumper Cut	No
1	RR S	Ibrahimbagh	Peddamangalram (IBGH)	11KV	Rajendranagar	10:25	11:40	1:15	B/D	11KV Insulator failed at Sowbagyanagar	No
2		Gandhamguda	Hydharshakote	11KV	Rajendranagar	10.20	11.40	01.20	B/D	Tree branches fallen on 11KV line at Military area	No
3		Gaganpahad	Meenakshi	11KV	Rajendranagar	11.55	13.20	01.25	B/D	11KV Pin Insulator failed at Priyanka Oil mill	No
4		Kattedan-I	Feeder-II	11KV	Rajendranagar	09.30	10.42	01.12	B/D	11KV Disc Insulator failed at Vishwakarma Industry	No
5		CBIT	Movietower	11KV	Rajendranagar	03.15	04.35	01.20	B/D	11KV Disc failed at Gold fish LAB Switch opened	No
6		Kokapet	Ocean park	11KV	Rajendranagar	10:25	12:15	1:50	B/D	11KV Insulator failed at Villa green	No

1	RR N	Vijayanagar	Aruna Society	11KV	KKP	4:20	5:20	1:00		No Visible Fault	No
2		Vemana Colony	Bishapathi Enclave	11KV	KKP	03.00	05.36	02.36		11kv Disk Failure At Shanker Nagar{Due TO Heavy Rain}	No
3		Bachupally	Nizampet	11KV	KKP	03.30	04.30	01.00		11kv Pin insulator Failure At Bachupally{due To Heavy Rain}	No
4		G Vikas	CoCo Cola	11KV	KKP	03.24	05.14	01.50		11kv D T R post insulator failed	No
5		G Vikas	Volvo	11KV	KKP	00.46	02.00	01.14		11kv Jumper cut	No
6		Vijayanagar	Allwyn Colony	11KV	KKP	18.35	20.35	02.00		Disc failed	No
7		Devarayamjal	Kottapet	11KV	MEDCL	06.30	09.30	03.00		Tree fallen on the 11KV Line at DMC Devarayamjal Village	No
8		Thurkapally	Thurkapally	11KV	MEDCL	06.00	08.55	02.55		Bird fallen on the 11KV Line at Thurkapally Village	No
9		Kandlakoya	Saigeetha	11KV	MEDCL	07.20	09.30	02.10		Tree fallen on the 11KV Line at Sowmya seeds Company	No
10		Athiwelly	Athiwelly	11KV	MEDCL	08.40	11.00	02.20		11KV Disc failed & Replacement at Balaji Nagar Road No.3	No
11		Keshavaram	Potharam	11KV	MEDCL	08.00	10.55	02.55		11KV Pin insulator failed at MPTC Bhavi, Anantharam Village	No
12		Laxmapur	Laxmapur	11KV	MEDCL	06.20	09.15	02.55		11KV Pin insulator failed at Laxmapur Cheruvukatta	No
13		Kandlakoya	Kandlakoya	11KV	MEDCL	09.30	10.35	01.05		No Visible Fault	No
14		Kompally	Canteen Park	11KV	MEDCL	10.45	11.38	00.53		Tree Branch fallen on the 11KV Line at NCL Water Tank	No
15		Kolthur	Mallanakatta	11KV	MEDCL	12.00	13.15	01.15		11KV Pin Insulator & 11KV Line Cut	No
16		Ravalkole	IDA Ravalkole	11KV	MEDCL	13:55	15:25	1:30		11KV Disc failed at Rajabollaram	No

1	RR E	Bagathsingh Nagar	Bagathsingh Nagar	11KV	Saroornagar	8:49	9:53	1:04		11KV Insulator failed	
2		Fruit Market	Ganeshpuri Colony	11KV	Saroornagar	09.25	10.10	00.45		11KV Insulator failed	
3		Autonagar	Siris	11KV	Saroornagar	09.40	12.30	02.50		Tree branches fallen on the line	
4		Autonagar	High Court Colony	11KV	Saroornagar	09.40	12.30	02.50		11KV Insulator failed	
5		Autonagar	Autonagar	11KV	Saroornagar	04.45	07.25	02.40		11KV Insulator failed	
6		Maruthi Nagar	Alkapuri	11KV	Saroornagar	04.00	06.30	02.30		Jumper cut	
7		Maruthi Nagar	Yadav Nagar	11KV	Saroornagar	03.34	08.16	04.32		Disc failed	
8		Bandlaguda	Rock Town	11KV	Saroornagar	11.45	13.20	01.35		Tree branches fallen on the line	
9		Bandlaguda	Rock Town	11KV	Saroornagar	03.22	05.10	01.48		Tree branches fallen on the line	
10		Mother Dairy	Veerabadranagar	11KV	Saroornagar	09.25	11.20	01.55		11KV Insulator failed	
11		Abdullapurmet	Batasingaram	11KV	Ibrahimpnam	05.20	08.40	03.20		Bird fallen on the 11KV Line	
12		NGRI	Scientist Colony	11KV	Habsiguda	08.15	09.42	01.27		Tree Branches fallen near ICICI Bank at Habsiguda	
13		Nagaram	Bandlaguda	11KV	Keesara	06.05	07.05	01.00		Insulator failed and Tree Branches fallen at Praja Sai Garden	
14		Keesara	Ankireddypally	11KV	Keesara	09.20	14.30	05.10		Tree fallen at Thatha Hospital at Ankireddypally	
15		P&T Colony	Canara Nagar	11KV	Keesara	04.20	05.30	01.10		Disc failed at Canara Nagar	
16		Narapally	Parvathapur	11KV	Keesara	06.20	08.35	02.15		Disc failed at CPRI	
17		Rampally Dayara	Karimguda	11KV	Keesara	06.20	08.25	02.05		11KV Disc failed at Mohan Reddy Poultry Farm	
18		Moula-Ali	Mirzalguda	11KV	Sainikpuri	06.51	07.46	00.55		Tree fallen on 11Kv line at RSC Compound ZTS Main Road	
19		NN Colony	Bavanarushi	11KV	Sainikpuri	11.55	12.55	01.00		HT/LT line twisting at Maruthi Nagar Dhammaiguda (LM Bhasker)	
20		Sainikpuri	Eshwarpuri	11KV	Sainikpuri	7:45	8:25	0:40		11Kv Pin Insulator failed at OET Colony	
1	HYD N	Chilalguda	New Boiguda	11KV	Sec'bad	03.25	05.10	01.45	EL	Foreign material fallen on Lines at Priyanka Towers	No
2		Vasanthapuri	Shesha Phadi	11KV	Sec'bad	5:50	7:43	1:53	EL	AB Cable End Kit fault at Muslim Grave Yard, Lalapet	No

1	HYD S	Santosh Nagar	Jahangir Nagar	11KV	Asmangadh	23.02	00.36	01.34	EL,OL-Rph	HG fuse fault at Akthar PT	partial feeder charged (23:59) & Added 4nos DTR loads on 11KV Moin Bagh feeder
2		E.N.T	E.N.T	11KV	Begumbazar	5:35	8:00	2:25	EL	Cable fault	Arranged partial loads B/F on 11KV Ram Koti fdr
3		Sulthan Bazar	Sulthan Bazar	11KV	Begumbazar	6:20	10:25	4:05	EL,OL-Rph	RMU Cable End Klit fault at Badi Chowdi	Arranged partial loads B/F on 11KV Kendriya Sadan fdr
4		C.R.P.F.	Keshavgiri	11KV	Charminar	9:45	10:50	1:05	EL,OL	Tree branches fallen on lines at SS backside	No
5		Kandikal Gate	Gazimillath Colony	11KV	Charminar	5:02	7:20	2:18	EL	Cable End Kit failed at Saleem Baig PT	No
6		Koti Womens College	Quthbiguda	11KV	Begumbazar	04.25	05.50	01.25	EL	No Visible Fault	No
1	HYD C	Nampally	Nampally Hospital	11KV	Mehdipatnam	02.37	04.05	01.28	EL,OL-Bph	Pin Insulator flash over Afzal Sagar	No
2		Nizam College	Babu Khan Estate	11KV	Saifabad	03.00	06.02	03.02	EL,OL-Bph	Brass Patti B/O & Jumper cut at Deccan Towers	No
3		Industrial Area	Barkhathpura	11KV	Azamabad	04.20	06.50	02.30	EL	Cable End Kit failed near SS & tree branches fallen on lines at Padma Colony	No
4		Hyderguda	Abids	11KV	Saifabad	05.30	07.30	02.00	EL	Pin Insulator flash over & Jumper cut at Hanuman PT	No
5		Lumbini Park	Avanthi Nagar	11KV	Saifabad	07.10	08.50	01.40	EL	Pin Insulator flash over at Shan Bagh Hotel	No
6		S.D.Hospital	Khadi Bandar	11KV	Mehdipatnam	08.36	10.02	01.26	EL,OL-R&Bph	Cable End Kit failed at Golconda Apts	No
7		Hussain Sagar	A.G.Office	11KV	Saifabad	08.35	10.18	01.43	All Indication	Tree branches fallen on lines at Opp. A.G.Office	No
8		Fever Hospital	Fever Hospital	11KV	Azamabad	09.58	11.57	01.59	OL-Bph	Tree branches fallen on lines at Park	No
9		Asif Nagar	Jyothi Nagar	11KV	Mehdipatnam	10.35	12.10	01.35	OL-Rph	Tree branches fallen on lines at Khader Bagh	No
10		Karwan	Langer House Cable	11KV	Mehdipatnam	11.55	13.35	01.40	EL,OL-Rph	Cable fault	Arranged B/F on 11KV Military fdr
11		Langer House	Fathe Darwaja	11KV	Mehdipatnam	9:15	14:10	4:55	EL	Pole fell down at GHMC Park, Fathe Darwaja	11:32 Hrs partial loads arranged B/F on 11KV Balancer fdr
12		Nampally	Pearls Regency	11KV	Mehdipatnam	14.16	15.42	01.26	EL,OL-Rph	Breaker fault at SS	Arranged B/F on 11KV Nilofer & Red Hills fdrs

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		6		6		6			
5	RR(N)	82	407		16		16		16			
6	RR(E)	38	360		20		20		20			
7	Hyd	186	1014		20		20		20			
	Total	504	2929	0	62	0	62	0	62	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969		2		2		2			
2	NLG	150	948		5		5		5			
3	MDK	87	828	3	16	3	16	3	16			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	3	23	3	23	3	23	0	0	
	Grand Total	908	6149	3	85	3	85	3	85	0	0	