

TSSPDCL - LMRC / Corporate office

Date: 12.01.2017

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|-----------------------|-----------------------|-----------------------|---------------------------|
| 1 | MDK | Ramayampet | Konapur | 33KV | Toopran | 18.35 | 20.30 | 01.55 | B/D due to Jumper cut | B/D due to Jumper cut | | - |

TSSPDCL - LMRC / Corporate office

Date: 12.01.2017

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|--|
| 1 | MBNR | Peddakadmoor | Nagal Kadmoor | 11KV | Mahabubnagar | 14.30 | 15.00 | 00.30 | | 11KV Jumper cut at Nagal Kadmoor (V) | - |
| 2 | | Kalwakurthy | Town 1 | 11KV | Jadcherla | 14.50 | 16.00 | 01.10 | | Tree Fallen On the 11KV Line Near Cotton Mill Side | - |
| 1 | NLG | Adivemla | Adivemla | 11KV | Suryapet | 09.00 | 12.00 | 03.00 | E/L | Line cut | - |
| 2 | | Thogarrai | Kuchipudi | 11KV | Huzurnagar | 09.55 | 12.05 | 02.10 | EL | 11 KV Line snapped at kuchipudi village | - |
| 3 | | Sirikonda | Ravipahad | 11KV | Huzurnagar | 11.50 | 14.00 | 02.10 | EL | 11 kv jumper cut at Ravipahad village | - |
| 4 | | Chandampet | Siddapur | 11KV | Devarakonda | 08.00 | 11.00 | 03.00 | E/L | 11kv jumper cut | - |
| 1 | MDK | Palvatla | Nirjipla | 11KV | Medak | 06.00 | 12.00 | 06.00 | | B/D Due to 11KV conductor snapped | - |
| 1 | RR S | Gandhamguda | Kalimandir | 11KV | RJNR | 18.38 | 19.35 | 00.57 | OL | Tree branches fallen on 11KV line at Shiva sai nagar | - |
| 1 | RR N | Kolthur | Anatharam | 11KV | Medchal | 00.00 | 03.10 | 03.10 | BD | 11KV Line Snapped and 11KV Pin Insulator Failed at Laxma Reddy Thota, Anatharam | - |
| 2 | | Madhinaguda | J P N Nagar | 11KV | Kukatpally | 18.51 | 20.03 | 01.12 | BD | 11kv Pin Insultor Failure At Nagarjuna homes | - |
| 3 | | Bahadurapally | I D A-2 | 11KV | Kukatpally | 19.25 | 20.50 | 01.25 | BD | Tree Branches fallen on The 11kv Line At Jyothi Milk | - |
| 4 | | Borabanda | Gayathrinagar | 11KV | Gachibowli | 18.44 | 19.50 | 01.06 | BD | 11kv End kit failed at Neuton School, Vivekananda nagar | - |
| 5 | | Kothaguda | Botanical Garden | 11KV | Gachibowli | 18.55 | 20.25 | 01.30 | BD | 11kv Pin- Insulator failed at Ratndeeep supermarket, Kothaguda | - |
| 6 | | SEZ | Siddique Nagar | 11KV | Gachibowli | 18.50 | 20.15 | 01.25 | BD | Insulator failed at Masjid circle, Siddique Nagar | - |
| 1 | RR E | Anandbagh | Balaram Nagar | 11KV | Sainikpuri | 19.10 | 20.20 | 01.10 | | 11Kv Disk failure at Mohan Dhaba Anandbagh (AE/OP) | - |
| 2 | | MARUTHI NAGAR | ALKAPURI | 11KV | SAROOR NAGAR | 02.25 | 03.35 | 01.10 | EL | 11KV JUPER CUT AT RK PURAM RD NO 3 | - |
| 3 | | BANDLAGUDA | CHANIKYAPURI | 11KV | SAROOR NAGAR | 19.16 | 20.38 | 01.42 | OL/EL | 11KV PIN INSULATER FAIL AT NAGOLE | - |
| 4 | | Rampally Dayara | Vanaiguda | 11KV | Keesara | 07.55 | 08.40 | 00.45 | | Bird fallen on 11KV Line at Manney Enng Company | - |
| 1 | HYD N | Prasasan Nagar | Navya Vihar | 11KV | Banjarahills | 19.40 | 20.50 | 01.10 | EL,OL-Rph | No Visible Fault | - |
| 2 | | Muffakamja College | Venkateswara Hills | 11KV | Banjarahills | 19.15 | 20.45 | 01.30 | EL,OL | Phase to Phase touch at Tata Tele Services | - |
| 1 | HYD S | Falaknuma | Fathima Nagar | ST | III | 16.45 | 18.25 | 01.40 | EL | No Visible Fault | Arranged B/F on 11KV Farooq Nagar fdr |
| 2 | | Salarjung | Madina | ST | III | 21.05 | 23.45 | 02.40 | All Indication | Cable fault at Pushpa Medical Hall | - |
| 3 | | Gosha Mahal | Hindi Nagar | ST | IX | 22.35 | 00.20 | 01.45 | All Indication | I/C Cable fault | Arranged B/F on 11KV Shivakumarlal Stadium fdr |

Status Report on Breakdowns (Urban / Rural)**Urban**

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 48 | 158 | | | | | | | | | |
| 2 | NLG | 18 | 406 | | | | | | | | | |
| 3 | MDK | 92 | 383 | | | | | | | | | |
| 4 | RR(S) | 40 | 201 | | 1 | | 1 | | 1 | | | |
| 5 | RR(N) | 82 | 407 | | 6 | | 6 | | 6 | | | |
| 6 | RR(E) | 38 | 360 | | 4 | | 4 | | 4 | | | |
| 7 | Hyd | 186 | 1014 | | 5 | | 5 | | 5 | | | |
| | Total | 504 | 2929 | 0 | 16 | 0 | 16 | 0 | 16 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 110 | 969 | | 2 | | 2 | | 2 | | | |
| 2 | NLG | 150 | 948 | | 4 | | 4 | | 4 | | | |
| 3 | MDK | 87 | 828 | 1 | 1 | 1 | 1 | 1 | 1 | | | |
| 4 | RR(S) | 31 | 338 | | | | | | | | | |
| 5 | RR(N) | 8 | 48 | | | | | | | | | |
| 6 | RR(E) | 18 | 89 | | | | | | | | | |
| | Total | 404 | 3220 | 1 | 7 | 1 | 7 | 1 | 7 | 0 | 0 | |
| | Grand Total | 908 | 6149 | 1 | 23 | 1 | 23 | 1 | 23 | 0 | 0 | |