

TSSPDCL - LMRC / Corporate office

Date: 13.08.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	T.Giri	N.B Thanda		Suryapet	10.00	12.35	02.35	E/L	Insulator failed	-
2		Ravulapally	Manapuram		Suryapet	07.30	10.00	02.30	E/L	Disk Failed	-
3		Dirincherla	Dirincherla		Huzurnagar	13.45	16.00	02.15	EI	11kv jumper cut	-
4		Munagala	Kokkereni-2		Huzurnagar	10.15	13.15	03.00	EI	11 KV Jumper cut at Kokkireni village	-
5		Marriguda	Thamdapally		Devarakonda	06.00	08.30	02.30	EI	11kv jumper cut	-
1	RR S	Kokapet	Babukhan		RJNR	14.10	15.20	01.10	B/D	11kv Insulator Failed at GMR	-
1	RR N	Chandanagar	Shankarnagar	11kv	KKP	15.20	16.20	01.00	BD	A bird Fallon the 11kv line T/F at Gayathri Nilayam ,ShankarNagar	-
2		Aleap	Panchavathi	11kv	KKP	09.00	10.50	01.50	BD	Tree Branches fallen on The 11kv Line At Plot:555, pragathinagar	-
3		Jeedimetla-II	Apurupa colony	11kv	KKP	15.25	16.35	01.10	BD	11kv line Pin Insulator Failure at Mody Builder SR Naik Nagar	-
4		Jeedimetla-I	NITCO	11kv	KKP	15.35	17.35	02.00	BD	11kv line AB Cable Messangar Cut at Bear Company, phase-V&{Due to Rain }	-
5		Jeedimetla-I	SudharShan Drugs	11kv	KKP	15.15	17.35	02.20	BD	Akshya Polymores HG Fuse Cut at Phase-I & { Due to Rain }	-
6		Jeedimetla-I	Maheshwari	11kv	KKP	15.20	16.55	01.35	BD	Tree Branches fallen on The 11kv Line at Suya Mirchi Masala, Subhash anagr	-
7		Madinaguda	Miyapur	11kv	KKP	15.50	17.26	01.36	BD	11kv line AB Cable Messangar Cut at Allwyn X Road &{Due to Rain }	-
8		Gachibowli	Gopanpally	11kv	GCB	00.47	02.55	02.08	BD	11KV Jumper Cut and 11KV Insulator Failed at Aparna Opposite.	-
9		Borabanda	Gayathrinagar	11kv	GCB	18.44	19.50	01.06	BD	11kv End kit failed at Neuton School, Vivekananda nagar	-
10		Kothaguda	Botanical Garden	11kv	GCB	18.55	20.25	01.30	BD	11kv Pin- Insulator failed at Ratndeeep supermarket, Kothaguda	-
11		SEZ	Siddique Nagar	11kv	GCB	18.50	20.15	01.25	BD	Insulator failed at Masjid circle, Siddique Nagar	-
12		Gachibowli	Kothaguda	11kv	GCB	20.10	21.35	01.25	BD	11kv Pin- Insulator failed at Masjid banda	-
13		Bandamadaram	Railapur	11kv	Medchal	04.45	05.30	00.45	BD	11KV Disc Failed at Mallanna Temple,Girmapur Village	-
14		Shameerpet	Devarayamjal	11kv	Medchal	10.05	12.50	02.45	BD	11KV Pin Insulator failed at Thumkunta, Near HBL	-
15		Kolthur	Kolthur	11kv	Medchal	10.40	11.20	00.40	BD	Tree Branches fallen on the 11KV Line at Vishwa Company	-
16		UMCC	HAL Colony	11kv	Medchal	15.35	17.25	01.50	BD	11KV Pin Insulator failed at Majeed RM Nagar	-
1	RR E	VP Nagar	Brundhavan Colony	11kv	Sainikpuri	15.42	17.12	01.30		11Kv Pin Insulator failed at Brundhavan Colony	-
2		Moula ali	Malkajgiri	11kv	Sainikpuri	16.10	18.15	02.05		Tree fallen on HT/LT line at Malkajgiri	-
3		Cherlapally	Rampally	11kv	Keesara	15.15	18.10	02.55		Pin insulator fail at SJ company & heavey wind & Rain rampally	-
1	HYD C	Fever Hospital	Barkathpura Bus Depot	11kv	Azamabad	00.03	01.43	01.40	EL	DTR fault at Raghavendra Tiffin Center	-
2	HYD S	Laxmi Nagar	S.B.H.	11kv	Asmangadh	14.37	16.10	01.33	EL	2Nos Pin Insulators flash over at Edga Road ,Madannapet	-

TSSPDCL - LMRC / Corporate office

Date: 13.08.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR				NIL							-
2	NLG				NIL							-
3	MDK				NIL							-
4	RRS				NIL							-
5	RR N				NIL							-
6	RR E				NIL							-
7	HYD				NIL							-

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		1		1		1			
5	RR(N)	82	407		16		16		16			
6	RR(E)	38	360		3		3		3			
7	Hyd	186	1014		2		2		2			
	Total	504	2929	0	22	0	22	0	22	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		5		5		5			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	0	5	0	5	0	5	0	0	
	Grand Total	908	6149	0	27	0	27	0	27	0	0	