

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Marriguda	T.P. Gouraram	33kv	Devarakonda	15.20	18.20	03.00	E/L	33Kv Jumper Cut	T.P. Gouraram	-
1	MDK	Thunki Bollaram	Vantimamidi	33kv	SIDDIPET	08.01	09.21	01.20		B/d due to Bird fallen on the line.	Vantimamidi	-
2		Thukkapur	Dommat	33kv	SIDDIPET	19.57	Still			B/D due to Continue.	Dommat	-

TSSPDCL - LMRC / Corporate office

Date: 14.08.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Kudakuda	Iylapuram	11KV	Suryapet	08.30	11.20	02.50	E/L	11Kv Insulator Failed	-
2		Mattapally	Sulthanpur Thanda	11KV	Huzurnagar	05.15	08.45	03.30	E/L	11Kv Disk Failed at Bojyathanda	-
3		Munagala	Kokkereni-2	11KV	Huzurnagar	02.00	06.00	04.00	E/L	11Kv Insulator Failed at Kokkereni-2 (V)	-
4		Bethavolu	Chennarigudem	11KV	Huzurnagar	02.00	06.00	04.00	E/L	11Kv Disk Failed at Bojyathanda	-
5		Marriguda	Y.G. Pally	11KV	Devarakonda	08.00	11.00	03.00	E/L	11Kv Jumper cut	-
6		K.M.Pally	C.A.Pally	11KV	Devarakonda	07.00	10.00	03.00	E/L	11Kv Insulator Failed	-
1	RR S	Kokapet	Babukhan	11KV	RJNR	14.10	15.20	01.10	B/D	11kv Insulator Failed at GMR	-
1	RR N	Madhinaguda	F C I	11KV	Kukatpally	14.43	16.18	01.35	BD	11kv AB Cable failure At Allwyn Colony X Road { Arrange Back Fedding Supply Pragathi EnclaveFeeder}	-
2		Devarayamjal	Kottapet	11KV	Medchal	05.25	08.20	02.55	BD	11KV Disc Failed at Dhamodhar Reddy T/F,Devarayamjal	-
1	RR E	Keesara	Keesara Town	11KV	Keesara	03.27	04.33	01.06		Line Patrolling but no visible fault	-
1	HYD S	Kanchanbagh	Riyasath Nagar	11KV	Charminar	05.26	08.25	02.59	OL-R&Bph	Cable fault	Arranged B/F on 11KV Omer Colony & 11KV Rakshapuram feeders

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		1		1		1			
5	RR(N)	82	407		2		2		2			
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014		1		1		1			
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948	1	6	1	6	1	6			
3	MDK	87	828	2		2		1		1		1No. 33kv still
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>3</b>	<b>6</b>	<b>3</b>	<b>6</b>	<b>2</b>	<b>6</b>	<b>1</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>3</b>	<b>11</b>	<b>3</b>	<b>11</b>	<b>2</b>	<b>11</b>	<b>1</b>	<b>0</b>	