

TSSPDCL - LMRC / Corporate office

Date: 15.08.17

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|-----------------------|---------------------------|
| 1 | MBNR | Wanaparthy | Narsiapally | 33KV | Wanaparthy | 15.15 | 17.55 | 02.40 | E/L | Pin binding replacment near 220KV SS Wanaparthy | Narsiapally | No |

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|--|
| 1 | NLG | Dondapahad | Vajinepally | 11KV | Huzurnagar | 5:15 | 10:00 | 4:15 | EL | 11 kv Jumper cut at Vajinepally village | No |
| 2 | | Kalmalcheruvu bro | Ganganagar | 11KV | Huzurnagar | 14.00 | 19.00 | 05.00 | EL | 11 kv line snapped at Ganganagar village | No |
| 3 | | Marriguda | Y.G.Pally | 11KV | Devarakonda | 07.00 | 10.00 | 03.00 | EL | 11kv jumper cut | No |
| 4 | | IDA | Bommaipally | 11KV | Bhongir | 12.00 | 15.00 | 03.00 | EL | 11KV Jumper snapped at bommaipally | No |
| 1 | MDK | Ch Ghanpur | Ch Ghanpur | 11KV | Medak | 11:25 | 14:25 | 03.00 | | Insulator failed | No |
| 2 | | Podchanpally | Podchanpally-I | 11KV | Medak | 06.20 | 11.00 | 04.40 | | Jumper Cut | No |
| 3 | | Gajulagudem | Chithiriyal AGL | 11KV | Medak | 13.55 | 15.25 | 01.30 | | Conductor snapped | No |
| 4 | | Gadipeddapur | Gadipeddapur | 11KV | Medak | 07.30 | 08.30 | 01.00 | | Conductor snapped | No |
| 5 | | Gadipeddapur | Muslapur | 11KV | Medak | 01.15 | 02.15 | 01.00 | | Jumper Cut | No |
| 6 | | Yeldurthy | Mangalparthy | 11KV | Toopran | 18.35 | 19.50 | 01.15 | | AB Switch failed | No |
| 7 | | Yeldurthy | Damarancha | 11KV | Toopran | 18.35 | 19.50 | 01.15 | | Conductor snapped | No |
| 8 | | Katriyal | Dantheppally | 11KV | Toopran | 15:45 | 17:20 | 01.35 | | Jumper Cut | No |
| 1 | RR S | Kokapet | Babukhan | 11KV | Rajendranagar | 14:10 | 15:20 | 01.10 | | Insulator failed | No |
| 1 | RR N | Bommarajpet | Karkalamma | 11KV | Medchal | 11:15 | 13:15 | 02.00 | | 11KV Jumper Cut & Replaced at Bommarajpet | |
| 2 | | Madhinaguda | BK Enclave | 11KV | Kukatpally | 16.38 | 17.58 | 01.20 | | 11kv AB Cable failure At Prashanthnagar | Arrange back feed supply JPN Nagar feeder at 17:58 |

Status Report on Breakdowns (Urban / Rural)**Urban**

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 48 | 158 | | | | | | | | | |
| 2 | NLG | 18 | 406 | | | | | | | | | |
| 3 | MDK | 92 | 383 | | | | | | | | | |
| 4 | RR(S) | 40 | 201 | | 1 | | 1 | | 1 | | | |
| 5 | RR(N) | 82 | 407 | | 2 | | 2 | | 2 | | | |
| 6 | RR(E) | 38 | 360 | | | | | | | | | |
| 7 | Hyd | 186 | 1014 | | | | | | | | | |
| | Total | 504 | 2929 | 0 | 3 | 0 | 3 | 0 | 3 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 110 | 969 | 1 | | 1 | | 1 | | | | |
| 2 | NLG | 150 | 948 | | 4 | | 4 | | 4 | | | |
| 3 | MDK | 87 | 828 | | 8 | | 8 | | 8 | | | |
| 4 | RR(S) | 31 | 338 | | | | | | | | | |
| 5 | RR(N) | 8 | 48 | | | | | | | | | |
| 6 | RR(E) | 18 | 89 | | | | | | | | | |
| | Total | 404 | 3220 | 1 | 12 | 1 | 12 | 1 | 12 | 0 | 0 | |
| | Grand Total | 908 | 6149 | 1 | 15 | 1 | 15 | 1 | 15 | 0 | 0 | |