

TSSPDCL - LMRC / Corporate office

Date: 16.08.17

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Habsipur	Raghothampally	33KV	Siddipet	2:35	8:00	5:25		B/D due to Insulator failed	Raghothampally	No

TSSPDCL - LMRC / Corporate office

Date: 16.08.17

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	KCR	Town-II	11KV	Mahabubnagar	20.05	22.15	02.10		Insulator damaged near KCR SS	No
1	NLG	Gurradandi	Jampally	11KV	Bhongir	9:40	13:30	3:50	EL	11Kv Jumper snapped at Thanda	No
2		Rajapet	Pamukunta	11KV	Bhongir	05.00	09.00	03.00	EL	11Kv Line snapped at Pamukunta	No
1	MDK	Kallakal	Kallakal AGL	11KV	Toopran	5:10	10:00	4:50		Jumper cut & Bird fallen on the line	No
1	RR S	Ibrahimbagh	Military-I	11KV	Rajendranagar	15:30	17:10	1:40		Cable failed at Ibrahimbagh	At 17:10 hrs. Alternative supply arranged from 11KV Daller Hills feeder
1	RR E	Chengicherla	RTC	11KV	Keesara	6:45	7:45	1:00		AB swicth full sparking at Indra nagar colony	No
1	HYD C	Nizam College	Little Flower	11KV	Saifabad	05.10	06.13	01.03	EL	No Visible Fault	No
2		Fever Hospital	C.C Shroff Hospital	11KV	Azamabad	16.45	19.10	02.25	All Indication	No Visible Fault	No

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		1		1		1			
5	RR(N)	82	407									
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014		2		2		2			
	Total	504	2929	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969		1		1		1			
2	NLG	150	948		2		2		2			
3	MDK	87	828	1	1	1	1	1	1			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	1	4	1	4	1	4	0	0	
	Grand Total	908	6149	1	8	1	8	1	8	0	0	