

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407	1	3	1	3	1	3			
6	RR(E)	38	360	4		4		4				
7	Hyd	186	1014		2		2		2			
	Total	504	2929	5	5	5	5	5	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	2		2		2				
2	NLG	150	948		2		2		2			
3	MDK	87	828		1		1		1			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	2	3	2	3	2	3	0	0	
	Grand Total	908	6149	7	8	7	8	7	8	0	0	

TSSPDCL - LMRC / Corporate office

Date: 17.08.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparthy	Peddmandadi	33KV	Wanaparthy	16.15	17.25	01.10	E/L	AB Switch open near Peddamandadi SS and Loads Daiviting to 33KV Veltoor Feeder Supply Stud Ok	Peddmandadi	Loads Daiviting to 33KV Veltoor Feeder Supply Stud Ok
2		Nagarkurnool	lthole	33KV	Nagarkurnool	17.36	18.26	00.50	E/L	Tree Branches Touched to the 33KV Line at Pullareddy	lthole	-
1	RR N	Shapurnagar	Jagadgirigutta	33KV	Kukatpally	15.33	18.20	02.47	BD	33KV jumper cut at 220KV shapur Nagar	Jagadgirigutta	-
1	RR E	MARUTHI NAGAR	YADAV NAGAR	33KV	SAROOR NAGAR	15.00	15.50	00.50	OL	11KV INSULATOR FAIL AT YADAV NAGAR RD NO 9	YADAV NAGAR	-
2		Ramanthapur	Gokhale Nagar	33KV	Habsiguda	14.04	14.58	00.54	OL	Tree Branches fallen on 11KV Line near D-Mart Backside at Indira Nagar	Gokhale Nagar	-
3		Vasanthapuri	Durga Nagar	33KV	Sainikpuri	02.58	04.06	01.08		11Kv line cut at Linga Reddy House (ADE/Goutham Nagar)	Durga Nagar	-
4		Vasanthapuri	Ganesh Temple	33KV	Sainikpuri	15.45	17.13	01.28		11Kv line cut at Ramalayam (L.Insp Venkateshwarulu/Mirzalguda)	Ganesh Temple	-

TSSPDCL - LMRC / Corporate office

Date: 17.08.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Chityal	Chityal (T)	11KV	Nalgonda	07.56	09.45	01.49	E/L	11Kv Line Conductor Snaped SS-2	-
2		Tekumatla	Pillalamarri	11KV	Suryapet	13.50	15.05	01.15	E/L	11Kv Jumper Cut	-
1	MDK	Kadloor	Kadloor	11KV	Medak	06.00	08.30	02.30		B/D due to Tree Branches fallen on 11KV line at Kadloor village	-
1	RR N	Medicity	Rajabollaram	11KV	Medchal	01.00	02.20	01.20	BD	11KV Line cut and replaced at Rajabollaram Thanda	-
2		Athiwelly	SPIC	11KV	Medchal	04.55	06.55	02.00	BD	Bird fallen on the 11KV Line at Somaram Village	-
3		Medchal	Rural Medchal	11KV	Medchal	07.25	08.20	00.55	BD	11KV Cable failed at IDA Bus Stop, Medchal	-
1	HYD N	H.M.T	Sri Sai Colony	11KV	VI	08.45	10.25	01.40	EL	Tree branches fallen on lines at H.M.T Wall	-
1	HYD C	Vittalwadi	Basanth Colony	11KV	II	03.50	06.30	02.40	EL	Faulty 2Nos DTR's at Basanth Colony	-