

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		4		4		4			
6	RR(E)	38	360									
7	Hyd	186	1014		2		2		2			
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969		2		2		2			
2	NLG	150	948		6		6		6			
3	MDK	87	828	2	2	2	2	2	2			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>2</b>	<b>10</b>	<b>2</b>	<b>10</b>	<b>2</b>	<b>10</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>2</b>	<b>16</b>	<b>2</b>	<b>16</b>	<b>2</b>	<b>16</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 18.08.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Minpur	Minpur	33KV	Medak	14.05	17.10	03.05		B/d due to Jumper cut	Minpur	-
2		Habsipur	Pothareddypet	33KV	Siddipet	10.36	12.10	01.34		B/d due to Tree branches fallen on the line	Pothareddypet	-

## TSSPDCL - LMRC / Corporate office

Date: 18.08.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Uttoor	Maqdumpur	11KV	Mahabubnagar	07.15	09.30	02.15		11KV Phase to Phase Near Maqdumpur (V)	-
2		Parpally	Chendrspally	11KV	Mahabubnagar	10.00	13.40	03.40		11KV Jumper cut at chenmanonpally (v)	-
1	NLG	Nuthankal	Yarrapahad	11KV	Suryapet	11.45	13.55	02.10	E/L	Jumpar Cut	-
2		Repala	Narsimhalagudam	11KV	Huzurnagar	09.15	11.40	02.25	O/L	Jumpar Cut	-
3		Mattapally	Sulthanpuram	11KV	Huzurnagar	09.40	13.40	04.00	E/L	Insulator Failure	-
4		Siripuram	Vallapuram	11KV	Huzurnagar	10.30	14.15	03.45	E/L	Disk Failure	-
5		SLBC	Kothapally	11KV	Nalgonda	11.30	15.30	04.00	E/L	Insulator Failiure	-
6		Marriguda	Kondur	11KV	Devarakonda	08.30	11.30	03.00	E/L	Jumpar Cut	-
1	MDK	Islampur	Rathnapur	11KV	Toopran	13.15	14.15	01.00		B/d due to Jumper Cut & Tree branch fallen on line	-
2		Danthanapally	Hastalpur	11KV	Toopran	11.00	13.45	02.45		B/d due to Jumper Cut & Tree branch fallen on line	-
1	RR N	Huda Truck Park	Raghavendra Colony	11KV	Gachibowli	15.18	16.18	01.00	BD	11KV Line touched to pole at D Mart	-
2		Chandanagar	Huda Colony	11KV	Gachibowli	16.55	18.20	01.25	BD	160KV Radha Krishna T/F Bush Rod Cut at Huda Colony	-
3		Aleap	Doctor's colony Cable	11KV	Kukkatpally	12.10	13.00	00.50	BD	HT Cable failure near pt no 573,574 at Pragathinagar	-
4		Nuthankal	Bharathi	11KV	Medchal	14.25	15.20	00.55	BD	11KV Disc failed at Rice Mill,Nuthankal Village	-
1	HYD S	Panjasha	Metherwadi	11KV	III	22.45	01.10	02.25	All Indication	AB Cable fault at Owasi School	-
2		Karwan	Karwan	11KV	IX	23.05	00.30	01.25	EL,OL-R&Bph	Pin Insulator flash over at Nehru Children School	-