

TSSPDCL - LMRC / Corporate office

Date: 19.08.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Kodangal	Dudyal	33KV	Mahabubnagar	04.15	05.30	01.15		No Visible fault due to Heavy Wind & Gail & Rain	Kodangal	-
1	MDK	Gajwel	Shivams	33KV	Toopran	13.05	15.35	02.30		B/D due to Insulator failed	Gajwel	-
2		Gajwel	BB Pur	33KV	Toopran	13.40	16.40	03.00		B/D due to Tree branch fallen on the line	Gajwel	-
3		Thukkapur	Dommata	33KV	Siddipet	18.35	24.00	05.25		Uder Breakdown	Thukkapur	-
4		Bollaram	ITC	33KV	Sangareddy	20.05	24.00	03.55		Uder Breakdown	Bollaram	-

TSSPDCL - LMRC / Corporate office

Date: 19.08.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Jadcherla	Nagasala	11KV	Jadcherla	15.00	17.00	02.00		11kv jumper cut near Nagasala	-
2		Boothpur	Amistapur	11KV	Jadcherla	06.00	12.00	06.00		11kv wire cut near Siddaipally	-
3		Thimmajipet	Marikal	11KV	Jadcherla	11.00	14.00	03.00		11kv wire cut near Gummakonda	-
4		Thimmajipet	Gummakonda	11KV	Jadcherla	11.00	15.00	04.00		11kv wire cut near Govt Hospital	-
1	NLG	SV College	Loyal X press	11KV	Suryapet	12.20	14.20	02.00	E/L	Insulator failed	-
2		Akkenapally	Ammanabole	11KV	Nalgonda	17.00	19.00	02.00	E/L	Tree fallen on line	-
3		Shivanngudem	R.R.Pally	11KV	Devarakonda	06.10	10.10	04.00	E/L	11KV Insulator failure	-
4		Thogarrai	Kuchipudi	11KV	Huzurnagar	08.45	10.50	02.05	EL	11 kv line snapped at Kuchipudi village	-
1	MDK	Satwar	Charakpally	11KV	Sangareddy	11.00	15.00	04.00		B/D due to Conductor snapped	-
2		Gadipeddapur	Gadipeddapur	11KV	Sangareddy	11.50	18.00	06.10		B/D due to wire cut.	-
3		Kadlur	Bodmatpally	11KV	Sangareddy	13.30	15.40	02.10		B/d due to jumper cut.	-
4		Suraram	Dharpally	11KV	Sangareddy	00.00	15.00	15.00		B/d due to 11 KV line cut and breaker problem	-
5		Bollaram-II	Rupa	11KV	Sangareddy	16.10	18.35	02.25		B/D due to conductor snapped at Balaji Company	-
6		Patancheru	Hypower	11KV	Sangareddy	08.05	09.48	01.43		B/D due to insulator failed at Company	-
1	RR N	Devarayamjal	DMC	11KV	Medchal	02.30	03.40	01.10		11KV Pin Insulator failed at Ram Reddy Bhavi, Near Likker Godown	-
2		Medicity	Rajabollaram	11KV	Medchal	15.40	18.40	03.00		11KV Pin Insulator failed at Rajabollaram Village	-
3		Dulapally	Karthika vanam	11KV	Medchal	16.50	18.40	01.50		11KV UG Cable End kit failed at Indian Petrol pump	-
4		Laxmapur	Laxmapur	11KV	Medchal	16.10	17.25	01.15		11KV Pin Insulator failed at Uddmarry	-
5		Ravalkole	IDA	11KV	Medchal	15.15	17.35	02.20		11KV Disc failed at Madhu farm	-
6		Bandamadaram	Railapur	11KV	Medchal	15.45	17.35	01.50		11KV Jumper cut & replacement in SS	-
7		Devarayamjal	Pothaipally	11KV	Medchal	15.20	16.20	01.00		11KV Disc failed at Devarayamjal Village	-
8		Bandamadaram	Railapur	11KV	Medchal	18.30	19.50	01.20		11KV Disc failed at Girimapur	-
9		Devarayamjal	Pothaipally	11KV	Medchal	18.50	20.20	01.30		11KV Disc failed at DMC	-
10		GP Pally	APIIC	11KV	Medchal	19.25	21.25	02.00		No fault	-
11		J D M SS-III	U S P Organic	11KV	Jeedimetla	14.30	15.10	00.40		11kv AB Cable Endy Kit Failure OPP Standard Company	-
12		Bowrampet	Bowrampet	11KV	Jeedimetla	16.12	18.20	02.08		11kv Pin Insultor Failure At Mallampet Road	-
13		Vikas	Kendiryavihar	11KV	Kukatpally	02.00	02.55	00.55		11kv Pin Insultor Failure at Raju D T R near KendiryaVihar school	-

1	RR E	Moula-Ali	Kailasagiri	11KV	Sainikpuri	18.00	19.00	01.00		11Kv Pin Insulator failed at Sagar Construction (AE/Moula-Ali)	-
2		BANDLAGUDA	GSI	11KV	Saroor nagar	01.35	03.35	02.00	OL	TREE BRACHANS FALL ON 11KV LINE AT BANDLAGUDA	-
3		HAYATH NAGAR	ANAND NAGAR	11KV	Saroor nagar	08.45	10.45	02.00	OL	11KV LINE CUT AT HAYATH NAGAR	-
1	HYD N	Gymkhana	Vasavi Nagar	11KV	Sec-Bad	19.15	20.40	01.25	EL,OL-Bph	Disc Insulator flash over at New Vasavi Nagar	-
2		Madhapur	Vaishnavi Residence	11KV	Banjarahills	23.35			EL,OL-Rph	Cable fault	Arranged B/F on 11KV Fdr
1	HYD S	Ch' Baradari	SRT Colony	11KV	Charminar	01.50	04.00	02.10	EL,OL-Bph	Post type Insulator flash over at Darga	-
2		Falaknuma	Vattepally	11KV	Charminar	04.05	06.20	02.15	EL,OL-Rph	No Visible Fault	-

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		13		13		13			
6	RR(E)	38	360		3		3		3			
7	Hyd	186	1014		4		4		4			
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>0</b>	<b>20</b>	<b>0</b>	<b>20</b>	<b>0</b>	<b>20</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	1	4	1	4	1	4			
2	NLG	150	948		4		4		4			
3	MDK	87	828	4	6	4	6	4	6			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>5</b>	<b>14</b>	<b>5</b>	<b>14</b>	<b>5</b>	<b>14</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>5</b>	<b>34</b>	<b>5</b>	<b>34</b>	<b>5</b>	<b>34</b>	<b>0</b>	<b>0</b>	