

Status Report on Breakdowns (Urban / Rural)**Urban**

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 48 | 158 | | | | | | | | | |
| 2 | NLG | 18 | 406 | | | | | | | | | |
| 3 | MDK | 92 | 383 | | | | | | | | | |
| 4 | RR(S) | 40 | 201 | | 2 | | 2 | | 2 | | | |
| 5 | RR(N) | 82 | 407 | | 7 | | 7 | | 7 | | | |
| 6 | RR(E) | 38 | 360 | | 4 | | 4 | | 4 | | | |
| 7 | Hyd | 186 | 1014 | | | | | | | | | |
| | Total | 504 | 2929 | 0 | 13 | 0 | 13 | 0 | 13 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 110 | 969 | 1 | 1 | 1 | 1 | 1 | 1 | | | |
| 2 | NLG | 150 | 948 | 1 | 8 | 1 | 8 | 1 | 8 | | | |
| 3 | MDK | 87 | 828 | 4 | 15 | 4 | 15 | 4 | 15 | | | |
| 4 | RR(S) | 31 | 338 | | | | | | | | | |
| 5 | RR(N) | 8 | 48 | | | | | | | | | |
| 6 | RR(E) | 18 | 89 | | | | | | | | | |
| | Total | 404 | 3220 | 6 | 24 | 6 | 24 | 6 | 24 | 0 | 0 | |
| | Grand Total | 908 | 6149 | 6 | 37 | 6 | 37 | 6 | 37 | 0 | 0 | |

TSSPDCL - LMRC / Corporate office

Date: 20.08.2017

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|------------|--------------------|----------------------|--------|----------------------|-------|-------|----------|------------------|---|--|
| 1 | MBNR | Badepally | Nagasala | 11KV | Jadcherla | 13.35 | 16.10 | 02.35 | | 11KV Jumper cut near Nagasala (V) | - |
| 1 | NLG | Chandur | Tummalapally | 11KV | Nallagonda | 05.40 | 11.50 | 06.10 | E/L | 11KV line insulator failed | - |
| 2 | | Kudakuda | M.G Nagar Thanda | 11KV | Suryapet | 09.30 | 11.45 | 02.15 | E/L | Line Cut | - |
| 3 | | M.R gudem | Gangasanipally | 11KV | Bhongir | 02.00 | 07.00 | 05.00 | EI | 11KV Line snapped at gangasanipally | - |
| 4 | | M.R gudem | Baswapur | 11KV | Bhongir | 02.00 | 07.00 | 05.00 | EI | 11KV Diskfailed near Baswapur | - |
| 5 | | Anatharam | Hanmapur | 11KV | Bhongir | 05.00 | 10.30 | 05.30 | EL | HT/LT | - |
| 6 | | Rajapet | Nemila | 11KV | Bhongir | 06.00 | 10.30 | 04.30 | EL | 11KV insulator failed | - |
| 7 | | Karvirala | Karvirala | 11KV | Huzurnagar | 07.10 | 12.40 | 05.30 | EL | Due to 11Kv line cutted cutted near Karvirala village | - |
| 8 | | Dirsincherla | Dirsincherla | 11KV | Huzurnagar | 12.00 | 17.00 | 05.00 | EL | Due to 11kv line cutted near Dirsincherla village | - |
| 1 | | MDK | Medak | Komtur | 11KV | Medak | 15.25 | 17.20 | 01.55 | | B/D due to AB Switch Open at Malkapur Thanda |
| 2 | Thogirta | | Kuchanpally | 11KV | Medak | 00.00 | 11.50 | 11.50 | | B/D Due to 11KV Insulator Failed | |
| 3 | B.B. Pur | | Burugupally | 11KV | Medak | 02.40 | 12.10 | 09.30 | | B/D Due to Tree fallen on 11KV Line | |
| 4 | Nagapur | | Thimmaipally | 11KV | Medak | 02.00 | 11.30 | 09.30 | | B/D Due to 11KV Disc Failed | |
| 5 | Shalipet | | Chennaipally | 11KV | Medak | 13.00 | 19.00 | 06.00 | | B/D Due to Conductor snapped | |
| 6 | Dharipally | | Achampet | 11KV | Medak | 12.00 | 18.00 | 06.00 | | B/D Due to 11KV Insulaor Failed | |
| 7 | Avancha | | Ramchandrapuram | 11KV | Medak | 08.45 | 14.00 | 05.15 | | B/D Due to 11KV Jumper Cut | |
| 8 | Reddypally | | Khajipet | 11KV | Medak | 02.30 | 09.40 | 07.10 | | B/D Due to 11KV Insulator Failed | |
| 9 | Narsingi | | Narsingi | 11KV | Medak | 15.50 | 18.00 | 02.10 | | B/D Due to 11KV Disc Failed | |

TSSPDCL - LMRC / Corporate office

Date: 20.08.2017

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|-----------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|---------------------------|
| 10 | MDK | Alladurg | Rampur | 11KV | Medak | 00.00 | 06.45 | 06.45 | | B/D Due to 11KV Jumper Cut | - |
| 11 | | Gadipeddapur | Gadipeddapur | 11KV | Medak | 02.30 | 10.30 | 08.00 | | B/D Due to 11KV Jumper Cut | - |
| 12 | | Tekmal | Tamploor | 11KV | Medak | 04.00 | 18.00 | 14.00 | | B/D due to 11KV Line Cutting and Disc Failed | - |
| 13 | | Pedda Shankarampet | Gotimukkula | 11KV | Medak | 00.00 | 12.50 | 12.50 | | B/D due to 11KV Disc Failed and Jumper Cut | - |
| 14 | | Burugupally | Burugupally | 11KV | Medak | 09.40 | 16.40 | 07.00 | | B/D Due to 11KV Jumper Cut | - |
| 15 | | Bollaram III | Sulakshana-II | 11KV | Sangareddy | 02.15 | 08.51 | 06.36 | | B/D Due to Jumper Cut AT COMPANY SIDE | - |
| 1 | RR S | Indira Gandhi Society | Indirashivashakti | 11KV | RJNR | 02.50 | 04.50 | 02.00 | B/D | Stick fallen on 11kv line at G Kattedan Lambadi Basti | - |
| 2 | | Gaganpahad | Meenakshi | 11KV | RJNR | 05.50 | 07.20 | 01.30 | B/D | 11KV Insulator failed at Priyanka Oil mill | - |
| 1 | RR N | Gachibowli | Sudharshan Nagar | 11KV | Gachibowli | 09.15 | 10.15 | 01.00 | BD | 11kv Pin-insulator failed at Chira Public School back side | - |
| 2 | | IJM | 9th Phase | 11KV | Gachibowli | 10.49 | 12.40 | 01.51 | BD | 11kv Line AB-Switch insulator failed at Srujana mall Opposite, 9th Phase | - |
| 3 | | K P HB | Gowthmi Nagar | 11KV | Kukatpally | 04.14 | 06.03 | 01.49 | BD | 11kv Pin Insultor Failure At Vinayaka Resdency Gowthinagar | - |
| 4 | | J D M SS-III | U S P Organic | 11KV | Jeedimetla | 14.30 | 15.10 | 00.40 | BD | 11kv AB Cable Endy Kit Failure OPP Standard Company | - |
| 5 | | Bowrampet | Bowrampet | 11KV | Jeedimetla | 16.12 | 18.20 | 02.08 | BD | 11kv Pin Insultor Failure At Mallampet Road | - |
| 6 | | J DM -SsII | N R SA | 11KV | Jeedimetla | 21.48 | 23.10 | 01.22 | BD | 11kv Line Ground Petroling No Foutl {Arange To Supply Back Feeding 11Kv Apiic Colon Due Heavy rain} | - |
| 7 | | Kompally | Canteen Park | 11KV | Medchal | 05.03 | 05.43 | 00.40 | BD | 11KV Pin Insulator Failed at Canteen Park | - |
| 1 | RR E | MARUTHI NAGAR | YADAV NAGAR | 11KV | SAROORNAGAR | 19.13 | 20.16 | 01.03 | OL | TRRE BRACHANS FALL ON 11KV LINE AT ALKAPURI RD NO 16 | - |
| 2 | | CRPF | Chennapur | 11KV | Sainikpuri | 08.15 | 09.35 | 01.20 | | 11Kv Jumper Open on 3 11Kv Pole Damaged on DCM Dashed at Dumping Yard (AE/OP) | - |
| 3 | | Keesara | Vardhana | 11KV | Keesara | 03.25 | 05.25 | 02.00 | | 11KV Pin Insulator failed at Kundanapally | - |
| 4 | | Keesara | Vardhana | 11KV | Keesara | 07.40 | 11.30 | 03.50 | | 11KV Pin Insulator failed at Oil Vampu | - |

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|-----------------------|---------------------------|
| 1 | MBNR | Kalwakurthy | Bolampally | 33KV | Jadcherla | 03.55 | 06.50 | 02.55 | E/L & O/L | Tree Branches Fallen on the 33KV Line near Veldanda (V) | Bolampally | - |
| 1 | NLG | Marriguda | Shivannagudem | 33KV | Devarakonda | 05.40 | 07.00 | 01.20 | | Insulator failure | Shivannagudem | - |
| 1 | MDK | Zaheerabad | Hadnoor | 33KV | Zaheerabad | 00.06 | 14.30 | 14.24 | | B/D due to Jumper cut & supply given from Mirzapur feeder | Hadnoor | - |
| 2 | | Zaheerabad | Chota Hyderabad | 33KV | Zaheerabad | 06.25 | 10.30 | 04.05 | | B/D due to Tree fallen on the Line | Chota Hyderabad | - |
| 3 | | Siddipet | Narayanraopet | 33KV | Siddipet | 03.45 | 11.45 | 08.00 | | B/D due to Disk failed | Narayanraopet | - |
| 4 | | Habsipur | Khajipur | 33KV | Siddipet | 00.00 | 08.30 | 08.30 | | B/D due to 2 no.s Pin Insulators failed | Khajipur | - |