

TSSPDCL - LMRC / Corporate office

Date: 21.08.17

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Makthal	Jaklair	33KV	Mahabubnagar	13.56	18.35	04.39		Due to Y phase Limb Blast	Jaklair	Alternate Supply Arranged from 132KV SS Marikal at 18:35Hrs

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Eklaspur	Jinnaram	11KV	Mahabubnagar	11.50	15.45	03.55		Tree fallen on 11KV conductor Near Jinnaram(V)	No
1	NLG	Kadaparthi	Chandampally	11KV	Suryapet	2:45	5:45	3:00	E/L	Tree branch fallen on the line	No
2		Keethavarigudem	Ranigudem	11KV	Huzurnagar	01.00	05.00	04.00	E/L	11KV Jumper cut at Kasarigudem (v)	No
3		Janpahad	Janpahad	11KV	Huzurnagar	19.20	22.20	03.00	E/L	11KV line snapped at Janpahad (v)	No
4		Madgulapally	Kukkadam	11KV	Nallagonda	03.00	08.20	05.20	E/L	11 KV Jumper Cut Under SS-10 at Kukkadam (V)	No
5		Marriguda	Y.G.Pally	11KV	Devarakonda	7:00	10:00	3:00	E/L	11KV Jumper cut	No
1	RR N	Medicity	Munirabad	11KV	Medchal	17:10	20:40	3:30		11KV Disc failed near Munirabad Village	No
1	RR E	Bandaravirala	Bandaravirala Agl	11KV	Ibrahimpattam	7:01	9:59	2:58	OL	11KV Insulator failed	No
1	HYD S	Falaknuma	Vattepally	11KV	Charminar	04.40	06.20	01.40	EL,OL	RMU Cable fault at Guntalsha Darga	No

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		1		1		1			
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014		1		1		1			
	Total	504	2929	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	1	1	1	1	1	1			
2	NLG	150	948		5		5		5			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	1	6	1	6	1	6	0	0	
	Grand Total	908	6149	1	9	1	9	1	9	0	0	