

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Sh.Gowraram	Utkooru	11KV	Suryapet	9:05	12:05	03.00	E/L	11Kv Jumper cut	No
2		Sharajipet	Saigudem	11KV	Bhongir	02.00	06.00	04.00	E/L	11KV Line snapped near Saigudem	No
3		Nandanam	Tukkapuram	11KV	Bhongir	08.00	11.20	03.20	E/L	11KV Line snapped near Navathaply	No
4		Pallemla	K.Kondaram	11KV	Nalgonda	05.30	08.00	04.00	E/L	11 KV Jumper Cut SS-2	No
5		Madgulapally	Kukkadam	11KV	Nalgonda	9:30	12:30	03.00	E/L	11KV Line Insulator Fail	No
1	RR S	Ibrahimbagh	Peddamangalaram	11KV	RJNR	20:55	22:05	1:10	B/D	No visible fault	No
2		Ibrahimbagh	Osmansagar	11KV	RJNR	21.04	22.30	01.26	B/D	No visible fault	No
1	RR N	Chandanagar	Sriramnagar	11KV	Medchal	17:25	18:10	0:45		11kv line endkit failed at VNR Apt , Sriramnagar	No
2		Suraram	Rajeev Gandhinagar	11KV	RRN	00.14	02.04	01.50		11kv Line Disc failed near Ambedakar Hall at Shivalayam nagar	No
3		Jeedimetla-I	APIIC Colony	11KV	RRN	14.01	15.27	01.26		11kv Line Pole Damaged & AB cable cut	No
4		Jeedimetla-I	JETL	11KV	RRN	14.01	15.35	01.34		11kv Line Pole Damaged & AB cable cut	No
1	HYD C	Nampally	Yousufian Darga	11KV	Mehdipatnam	21.19	23.55	02.36	EL	2No. Pin insulators flashed over at Yousufian Darga	No
2		Vittalwadi	Gandhi Kuteer	11KV	Azamabad	21.35	22.50	01.15	All Indication	DTR Cable fault at City Home Apts	No

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		2		2		2			
5	RR(N)	82	407		4		4		4			
6	RR(E)	38	360									
7	Hyd	186	1014		2		2		2			
	Total	504	2929	0	8	0	8	0	8	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		5		5		5			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	0	5	0	5	0	5	0	0	
	Grand Total	908	6149	0	13	0	13	0	13	0	0	