

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		7		7		7			
6	RR(E)	38	360	1	2	1	2	1	2			
7	Hyd	186	1014	1	4	1	4	1	4			
	Total	504	2929	2	13	2	13	2	13	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969		3		3		3			
2	NLG	150	948	1	6	1	6	1	6			
3	MDK	87	828		3		3		3			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	1	12	1	12	1	12	0	0	
	Grand Total	908	6149	3	25	3	25	3	25	0	0	

TSSPDCL - LMRC / Corporate office

Date: 24.08.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	K.M.Pally	SLBC	33KV	Devarakonda	07.00	08.00	01.00		33KV jumper cut		-
1	RR E	Moulali	Cherlapally	33KV	Sainikpuri	08.56	10.26	01.30		No Visible Fault	Cherlapally	-
1	HYD N	132KV Madhapur	Sundew	33KV	Kalyan Ngr	01.00	08.00	07.00	EL,OL	Cable Joint failed at Raheja Gate	Sundew	Loads transferred onto 132KV J' Hills SS via 33KV Intime Properties fdr

TSSPDCL - LMRC / Corporate office

Date: 24.08.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Peddakadmoor	Nagal Kadmoor	11KV	Mahabubnagar	06.15	07.35	01.20		11KV Disk failure at Nagal Kadmoor (V)	-
2		Doulthabad	Doulthabad (R)	11KV	Mahabubnagar	12.30	16.00	03.30		11KV Jumper cut Near Yamki (V)	-
3		Kalwakurthy	Kurmidda	11KV	Jadcherla	12.45	17.00	04.15		AB Switch Fault at Chilapally	-
1	NLG	Gattuppal	Theratpally	11KV	Nalgonda	03.30	08.40	05.10	E/L	11KV Jumper cut at SS-6	-
2		Aitipamula	Rasoolgudem	11KV	Suryapet	06.00	09.30	03.30	E/L	Jumper cut	-
3		Gondriyala	Chimiryala	11KV	Huzurnagar	14.30	17.55	03.25	EL	Due to 11kv insulator Failure near Chimiryala village	-
4		N.B.Gudem	Redlakunta	11KV	Huzurnagar	13.35	17.40	04.05	EL	Due to Control AB Switch Fault occur near Redlakunta village	-
5		Kandibanda	Gandi nagar thanda	11KV	Huzurnagar	13.20	17.00	03.40	EL	Due to 11kv Jumper cutted near Gandi nagar thanda village	-
6		Ghanpuram	G.B.Pally	11KV	Devarakonda	04.00	08.00	04.00	E/L & O/L	11kv jumper cut	-
1	MDK	Rajpally	Balanagar	11KV	Medak	07.25	11.30	04.05		B/D due to 11Kv Jumper cut.	-
2		Suraram	Jangarai	11KV	Medak	00.00	11.00	11.00		B/D due to 11Kv Conductor Snapped.	-
3		Shankarampet	Cheelapally	11KV	Medak	13.35	16.10	02.35		B/D due to 11KV Jumper cut	-
1	RR N	HMT Hills	Sriramnagar	11KV	KKP	00.35	02.10	01.35	BD	11kv line AB Cable failure near Sai charan colony	-
2		HMT Hills	Addagutta	11KV	KKP	15.46	16.40	00.54	BD	11kv line UG Cable failure near Ramalayam temple at Addagutta	-
3		Mayurinagar	Laxminagar	11KV	KKP	07.20	08.00	00.40	BD	11kv line AB Cable failure at Laxminagar	-
4		RGK Suraram	Suraram Village	11KV	JDM	04.30	05.40	01.10	BD	Line Petroling No Visble Falt	-
5		Aleap	Panchavathi	11KV	JDM	16.17	17.00	00.43	BD	Tree Branches Fallon the 11kv line plot:273 at Le Q Colony	-
6		Dulapally	Karthika vanam	11KV	Medchal	16.55	18.05	01.10	BD	11KV Pin Insulator failed at Forest Area,Dulapally	-
7		UMCC	Gajularamaram	11KV	Medchal	17.00	17.40	00.40	BD	11KV Disc Failed at Andhra Bank,Gajularamaram	-
1	RR E	Saketh	Pranam	11KV	Sainikpuri	16.05	16.40	00.35		11Kv Pin Insuletor failure at Saketh Phase-II (L Insp Padma Rao)	-
2		AUTO NAGAR	MANSOORABAD	11KV	Saroor Nagar	15.19	16.25	01.06		11KV DISK FAIL AT NEAR AUTO NAGAR SS	-
1		Yakuthpura	Somnath Temple	11KV	VIII	03.30	04.53	01.23	EL,OL-Yph	Cable fault at Sadath Nagar	-

2	HYD S	Yakuthpura	Murtuza Nagar	11KV	VIII	03.40	04.53	01.13	EL	Cable fault at Murthuza Nagar	Arranged B/F on 11KV Sadath Nagar & 11KV Bhavani Nagar feeders
3		Yakuthpura	Bada Bazar	11KV	VIII	09.36	10.47	01.11	EL,OL-Yph	Cable fault at Bada Bazar	Arranged B/F on 11KV Chowni fdr
1	HYD C	Golconda	O.U.Colony	11KV	VII	18.15	19.45	01.30	EL	Pin Insulator flash over at Darga	-