

Status Report on Breakdowns (Urban / Rural)**Urban**

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 48 | 158 | | | | | | | | | |
| 2 | NLG | 18 | 406 | | | | | | | | | |
| 3 | MDK | 92 | 383 | | | | | | | | | |
| 4 | RR(S) | 40 | 201 | | 3 | | 3 | | 3 | | | |
| 5 | RR(N) | 82 | 407 | | 7 | | 7 | | 7 | | | |
| 6 | RR(E) | 38 | 360 | | 3 | | 3 | | 3 | | | |
| 7 | Hyd | 186 | 1014 | | 18 | | 18 | | 18 | | | |
| | Total | 504 | 2929 | 0 | 31 | 0 | 31 | 0 | 31 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 110 | 969 | | | | | | | | | |
| 2 | NLG | 150 | 948 | | 6 | | 6 | | 6 | | | |
| 3 | MDK | 87 | 828 | | | | | | | | | |
| 4 | RR(S) | 31 | 338 | | | | | | | | | |
| 5 | RR(N) | 8 | 48 | | | | | | | | | |
| 6 | RR(E) | 18 | 89 | | | | | | | | | |
| | Total | 404 | 3220 | 0 | 6 | 0 | 6 | 0 | 6 | 0 | 0 | |
| | Grand Total | 908 | 6149 | 0 | 37 | 0 | 37 | 0 | 37 | 0 | 0 | |

Circle Wise Fuse off Calls**URBAN**

| Sl.No | Circle | PREVIOUS PENDING | TODAY | TOTAL | 30min. | 1hr | 2hrs | 2hrs Above | TOTAL | Balance |
|-------|--------------|------------------|-------------|-------------|-------------|------------|------------|------------|-------------|------------|
| 1 | MBNR | 0 | 172 | 172 | 140 | 18 | 14 | 0 | 172 | 0 |
| 2 | NLG | 0 | 23 | 23 | 21 | 1 | 1 | 0 | 23 | 0 |
| 3 | MDK | 0 | 51 | 51 | 22 | 18 | 10 | 1 | 51 | 0 |
| 4 | RR -South | 0 | 51 | 51 | 22 | 18 | 10 | 1 | 51 | 0 |
| 5 | RR -North | 0 | 134 | 134 | 105 | 29 | 0 | 0 | 134 | 0 |
| 6 | RR -East | 0 | 175 | 175 | 100 | 75 | 0 | 0 | 175 | 0 |
| 7 | Hyd | 779 | 2314 | 3093 | 1563 | 330 | 600 | 134 | 2627 | 466 |
| | TOTAL | 779 | 2920 | 3699 | 1973 | 489 | 635 | 136 | 3233 | 466 |

RURAL

| Sl.No | Circle | PREVIOUS PENDING | TODAY | TOTAL | 30min. | 1hr | 2hrs | 2hrs Above | TOTAL | Balance |
|-------|--------------|------------------|------------|------------|------------|-----------|-----------|------------|------------|----------|
| 1 | MBNR | 0 | 166 | 166 | 144 | 13 | 9 | 0 | 166 | 0 |
| 2 | NLG | 0 | 25 | 25 | 23 | 1 | 1 | 0 | 25 | 0 |
| 3 | MDK | 0 | 53 | 53 | 19 | 23 | 10 | 1 | 53 | 0 |
| 4 | RR -South | 0 | 18 | 18 | 9 | 7 | 2 | 0 | 18 | 0 |
| 5 | RR -North | 0 | 17 | 17 | 11 | 6 | 0 | 0 | 17 | 0 |
| 6 | RR -East | 0 | 35 | 35 | 20 | 15 | 0 | 0 | 35 | 0 |
| | TOTAL | 0 | 314 | 314 | 226 | 65 | 22 | 1 | 314 | 0 |

TSSPDCL - LMRC / Corporate office

Date: 25.08.2017

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|-----------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|---------------------------|
| 1 | NLG | Thungathurty | Pasnoor | 11KV | Suryapet | 09.05 | 11.20 | 02.15 | E/L | Insulator failed | - |
| 2 | | IDA SS | IDA Indus | 11KV | Bhongir | 06.30 | 08.30 | 02.00 | EL | Bird Fallen On Line | - |
| 3 | | Chinthapally | Varakala | 11KV | Devarakonda | 05.30 | 08.30 | 03.00 | EL | 11kv jumper cut | - |
| 4 | | Repala | V R Puram | 11KV | Huzurnagar | 03.00 | 07.00 | 04.00 | EL | 11Kv11 kv line cut | - |
| 5 | | Kandibanda | Gandi nagar thanda | 11KV | Huzurnagar | 13.35 | 17.05 | 03.30 | EL | 11kv Jumper cutted near Gandi nagar thanda(v) | - |
| 6 | | Gattuppal | Lachammagudem | 11KV | Nalgonda | 05.30 | 08.40 | 03.10 | EL | 11 KV Jumper Cut Under SS-2 at Lachugudem (V). | - |
| 1 | RR S | Gaganpahad | Gaganpahad | 11KV | RJNR | 11.40 | 14.23 | 02.43 | B/D | 11kv Disc Failed at Modi Industrial | - |
| 2 | | Indira Gandhi Society | Padmashalipuram | 11KV | RJNR | 15.56 | 17.02 | 01.06 | B/D | Tree branches fallen on 11kv Line at Madhuban colony | - |
| 3 | | Manikonda | Panchavathi colony | 11KV | RJNR | 21.04 | 22.22 | 01.18 | B/D | Tree branches fallen on 11kv Line at Panchavathi colony Road No.19 | - |
| 1 | RR N | HMT Hills | Sriramnagar | 11KV | KKP | 00.35 | 02.10 | 01.35 | BD | 11kv line AB Cable failure near Sai charan colony | - |
| 2 | | HMT Hills | Addagutta | 11KV | KKP | 15.46 | 16.40 | 00.54 | BD | 11kv line UG Cable failure near Ramalayam temple at Addagutta | - |
| 3 | | Mayurinagar | Laxminagar | 11KV | KKP | 07.20 | 08.00 | 00.40 | BD | 11kv line AB Cable failure at Laxminagar | - |
| 4 | | RGK Suraram | Suraram Village | 11KV | JDM | 04.30 | 05.40 | 01.10 | BD | Line Petroling No Visble Falt | - |
| 5 | | Aleap | Panchavathi | 11KV | JDM | 16.17 | 17.00 | 00.43 | BD | Tree Branches Fallon the 11kv line plot:273 at Le Q Colony | - |
| 6 | | Dulapally | Karthika vanam | 11KV | Medchal | 16.55 | 18.05 | 01.10 | BD | 11KV Pin Insulator failed at Forest Area,Dulapally | - |
| 7 | | UMCC | Gajularamaram | 11KV | Medchal | 17.00 | 17.40 | 00.40 | BD | 11KV Disc Failed at Andhra Bank,Gajularamaram | - |
| 1 | RR E | Cherlapally-II | Jannuram | 11KV | Sainikpuri | 21.50 | 23.35 | 01.45 | | 11Kv Insulator failed & replacement at Near Kukat Nagar T/F (Foc Bhasker) | - |
| 2 | | Moula-Ali | Kailasagiri | 11KV | Sainikpuri | 21.43 | 23.07 | 01.24 | | 11Kv Cable fault at Alluri Sitharamraj HB Colony (AE/Moula-Ali) | - |
| 3 | | HAYATH NAGAR | KALVANCHA | 11KV | SAROORNAGAR | 07.40 | 08.50 | 01.10 | EL/OL | TREE BRACHANS FALL ON 11KV LINE AT SAMA NAGAR | - |

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|---------------------------------------|
| 1 | HYD N | Lalaguda | St.Anns | 11KV | V | 19.55 | 21.45 | 01.50 | EL | Tree branches fallen on lines at Sagi College | - |
| 2 | | Kalyan Nagar | Vengal Rao Nagar | 11KV | X | 20.21 | 21.45 | 01.24 | EL,OL-Rph | No Visible fault due to Rain | - |
| 3 | | Prashanth Nagar | Shakthipuram | 11KV | VI | 20.55 | 23.10 | 02.15 | OL-Bph | No Visible fault due to Rain | - |
| 4 | | Gymkhana | Pared Ground | 11KV | V | 21.05 | 00.15 | 03.10 | EL | Tree branches fallen on lines at Tivoli | - |
| 5 | | Nehru Nagar | Rezimental Bazar | 11KV | V | 22.01 | 23.53 | 01.52 | EL | End Kit failed at A.K.Chary Appt | - |
| 6 | | R.P.Nilayam | Saraswathi Nagar | 11KV | VI | 22.05 | 23.45 | 01.40 | EL | Insulator flash over at Saraswathi Nagar | - |
| 7 | | Thirumalgiri | Chinna Kamela | 11KV | VI | 22.45 | 00.28 | 01.43 | EL,OL-Rph | No Visible fault due to Rain | - |
| 8 | | Nehru Nagar | H.H.Kala Bhavan | 11KV | V | 22.59 | 00.42 | 01.43 | All Indication | Jumper Cut at Yashoda Hospital | - |
| 9 | | Lalaguda | Chenna Reddy | 11KV | V | 23.10 | 00.20 | 01.10 | EL | 5No DTR's Kept off at Garuda Appt | - |
| 10 | | Yousufguda | Hylom Colony | 11KV | X | 23.30 | 01.15 | 01.45 | EL,OL-Rph | Tree branches fallen on lines & Pin Insulator flash over at Venkatagiri W.W | - |
| 1 | HYD S | Malakpet | Bibi Ka Alawa | 11KV | VIII | 18.53 | 21.40 | 02.47 | EL,OL-Bph | AB Cable fault beside SS | Arranged B/F on 11KV Yakuthpura fdr |
| 2 | | Hyderguda | Attapur | 11KV | III | 22.10 | 00.27 | 02.17 | EL | No Visible fault due to Rain | Arranged B/F on 11KV Janapriya OH fdr |
| 3 | | Miralam | Jahanuma | 11KV | III | 22.30 | 23.50 | 01.20 | EL,OL | Tree branches on lines at Gouse Nagar | ----- |
| 1 | HYD C | Asif Nagar | N.S.F Colony | 11KV | VII | 19.25 | 20.40 | 01.15 | OL-Bph | Tree branches fallen on lines at Meeraj Colony | - |
| 2 | | Golconda | Darga OH | 11KV | VII | 22.35 | 23.55 | 01.20 | EL,OL-Bph | Pin Insulator flash over at Water Works | - |
| 3 | | Langer House | Netaji Nagar | 11KV | VII | 22.55 | 00.20 | 01.25 | EL,OL-Rph | Tree branches fallen on lines at Sardhar Bagh | - |
| 4 | | S.D.Hospital | Ahmed Nagar Cable | 11KV | VII | 23.20 | 00.25 | 01.05 | EL | No Visible fault due to Rain | - |
| 5 | | Asif Nagar | Military | 11KV | VII | 23.30 | 01.30 | 02.00 | OL-Bph | Tree branches fallen on lines at Military | - |