

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Kangal	Kopple	33KV	Devarakonda	03.00	07.30	04.30	E/L	33kv jumper cut	Kangal	-
1	MDK	Bollaram	Bollaram - II	33KV	Sangareddy	01.40	07.30	05.50		B/D due to Breakar probleam	Bollaram	-
2		Bollaram	Agarwal Globle Steel	33KV	Sangareddy	01.40	09.20	07.40		B/D due Insulator failure	Bollaram	-
3		Gummadidala	GPSS-2	33KV	Sangareddy	00.35	09.25	08.50		B/D Due to tree branch fallen on the line near Annaran Village.	Gummadidala	-
4		Kandi	Alkabeer	33KV	Sangareddy	23:00 (25.8.2017)	11.15	12.15		B/D Due to Insulator failure	Kandi	-
5		Zaheerabad	Mannapur	33KV	Zaheerabad	00.02	07.30	07.28		B/D Due to Insulator failure	Zaheerabad	-
6		Jogipet	Dakur	33KV	Jogipet	04.50	07.35	02.45		B/D Due to tree branch fallen on the line	Jogipet	-
7		Naraspur	RWS	33KV	Medak	04.30	07.45	03.15		B/D Due to tree branch fallen on the line near Magapur Village.	Naraspur	-
1	RR N	220KV Gachibowli	IIIT OH	33KV	Gachibowli	22.23	02.30	04.07		Tree fallen on line	220KV Gachibowli	-
2		220KV Gachibowli	HCU	33KV	Gachibowli	22.50	06.52	08.02		Pin insulater failed at Gangaram charuvu	220KV Gachibowli	-
3		220KV Gachibowli	IIIT UG-II	33KV	Gachibowli	09.52	11.22	01.30		line petroling	220KV Gachibowli	-
4		Miyapur	IJM	33KV	Gachibowli	22.52	08.59	10.07		Tripped on EL indication duto rain line petroling.,NBFC isued Ae\lines KPHB Interl AB switch problem nesar Sujana Mal	Miyapur	-
5		Medchal	33KV GP Pally-II	33KV	Medchal	00.09	05.55	05.46		Tripped on OL YB Phase Indication, PTR-I & II Pullout, BD declared to Ae/Op/Medchal for 2 Nos Lighting Arrester failed at Inbisco Company	Medchal	-

## TSSPDCL - LMRC / Corporate office

Date: 26.08.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Wanaparthy	Gopalpet	11KV	Wanaparthy	22.20	10.00	11.40		11KV Insulator failed Munnatur Road	-
2		Srinivasapur	Chandapur	11KV	Wanaparthy	18.35	09.10	14.35		11KV Disc failed near poultry form at chandapur	-
3		Mahandapur	Dondaipally	11KV	Wanaparthy	22.15	10.00	11.45		11KV Jumper cut & touched to the x aram at the dondaipally	-
4		ponnakal	Rachala	11KV	Wanaparthy	02.45	06.10	03.25		11KV insulator failed at rachala agl	-
5		Peddmandaddi	Manigilla	11KV	Wanaparthy	19.20	06.40	11.20		No visibule fault due to heavy Rain	-
1	NLG	B.Banda	N.G Kothapally	11KV	Suryapet	07.00	10.20	03.20	E/L	11Kv Conductor snapped	-
2		Ravulapally	Manapuram	11KV	Suryapet	06.00	08.40	02.40	E/L	11Kv Insulator failed	-
3		Keethavarigudem	Velidanda	11KV	Huzurnagar	10.10	12.40	02.30	O/L	11kv Jumper cut near Velidanda (v)	-
4		Mattapally	Sulthanpuram	11KV	Huzurnagar	13.30	15.45	02.15	E/L	11kv line Snapped near Sulthanpuram (v)	-
5		Narayanapur	K.K.Gudem	11KV	Nalgonda	02.00	06.00	04.00	E/L	HT / LT Melting	-
6		Narketpally	Mandra	11KV	Nalgonda	03.00	07.00	04.00	E/L	11 KV Jumper Cut	-
7		Bhongir Town	Raigiri Indus	11KV	Bhongir	02.00	05.00	03.00	E/L	11KV Insulator failed at Raigiri	-
8		Voligonda	Nagaram	11KV	Bhongir	02.00	05.00	03.00	E/L	11KV Insulator failed at Nagaram	-
1	MDK	Ismailkhanpet	Goudicherla	11KV	Sangareddy	08.45	15.33	06.48		B/D Due to EL OL no falt found	-
2		Ismailkhanpet	Arutla	11KV	Sangareddy	08.20	12.34	04.14		B/D Due to bird fallen on the line at Arutla	-
3		Ismailkhanpet	Erdanoor	11KV	Sangareddy	09.50	17.30	07.40		B/D Due to insulators burst & rectification of lines at Byathole tandaB/D Due to insulators burst & rectification of lines at Byathole tandaB/D Due to insulators burst & rectification of lines at Byathole tandaB/D Due to insulators burst & rectification of lines at Byathole tanda	-
4		BOLLARAM-II	VASAVIDATTA	11KV	Sangareddy	04.25	07.10	02.45		B/D due to JUMPER CUT	-
5		BOLLARAM-II	VIPLA	11KV	Sangareddy	04.25	07.10	02.45		B/D due to AB SWITCH JUMPER CUT	-
6		BOLLARAM-II	KOTTAM	11KV	Sangareddy	09.45	10.32	00.47		B/D due to SRIKRISHNA COMPANY JUMPER CUT	-
1		RR S	Gaganpahad	Gaganpahad	11KV	RJNR	11.40	14.23	02.43	B/D	11kv Disc Failed at Modi Industrial
2	Indira Gandhi Society		Padmashalipuram	11KV	RJNR	15.56	17.02	01.06	B/D	Tree branches fallen on 11kv Line at Madhuban colony	-
3	Manikonda		Panchavathi colony	11KV	RJNR	21.04	22.22	01.18	B/D	Tree branches fallen on 11kv Line at Panchavathi colony Road No.19	-

1	RR N	Medicity	IDA-I	11KV	Medchal	01.50	03.35	01.45	BD	Line AB Switch opened at Pudur Village	-
2		Medicity	Rajabollaram	11KV	Medchal	02.05	03.10	01.05	BD	11KV Jumper cut at Rajabollaram Thanda	
3		Town Medchal	Country Club	11KV	Medchal	00.00	02.50	02.50	BD	11KV Pin Insulator failed at Country Club	
4		Town Medchal	NGOs Colony	11KV	Medchal	00.30	02.40	02.10	BD	Tree fallen on the 11KV Line Reliance Company	
5		Subash Nagar	Jairam nagar	11KV	Medchal	00.40	01.45	01.05	BD	No fault	
6		Subash Nagar	Ramaraj Nagar	11KV	Medchal	00.40	01.35	00.55	BD	Tree fallen on the 11KV Line Spring Field Colony	
7		UMCC	Mahadevapuram	11KV	Medchal	00.15	01.00	00.45	BD	11KV Pin Insulator failed at Shiridi Hills	
8		Kompally	Jaibheri	11KV	Medchal	03.05	04.25	01.20	BD	11KV Disc failed at Srinivasa Nagar, Kompally	
9		Kandlakoya	Saigeetha Asramam	11KV	Medchal	01.30	04.10	02.40	BD	Tree fallen on the 11KV Line Geetanjali School, Kandlakoya	
10		Dulapally	IDA-I	11KV	Medchal	01.55	04.30	02.35	BD	11KV Jumper cut at Deccan Kwanta, IDA Dulapally	
11		Dulapally	IDA-II	11KV	Medchal	02.10	04.35	02.25	BD	11KV Pin Insulator failed at Petrol Pump, Dulapally	
12		Medchal	Rural Medchal	11KV	Medchal	01.26	07.36	06.10	BD	11KV Disc failed & Pin Insulator failed at CMR College	-
13		GP Pally	APIIC	11KV	Medchal	06.10	09.30	03.20	BD	11KV Polymer Disc failed at GMG Company Backside	-
14		Athiwelly	Somaram	11KV	Medchal	06.00	08.00	02.00	BD	AB Switch opened at Donda Thota	-
15		Shameerpet	Thumkunta	11KV	Medchal	06.30	08.45	02.15	BD	11KV Disc failed at Mandaipally Road	-
16		Bandamadaram	Barmajiguda	11KV	Medchal	04.30	06.40	02.10	BD	No fault	-
17		Chinthal	Dwaraka nagar	11KV	Medchal	06.45	07.05	00.20	BD	11KV Line AB Swich Opened at Manikya Nagar Common(11KV Pin Insulator failed)	-
18		Athiwelly	Athiwelly	11KV	Medchal	12.05	13.37	01.32	BD	11KV Disc Replaced at Balaji Nagar Road No.3	-
19		Kandlakoya	Saigeetha Asramam	11KV	Medchal	12.55	13.55	01.00	BD	Tree Branches fallen on the 11KV Line at Chaitanya School Opposite	-
1	RR E	Nacharam	Muktha Metal	11KV	Habsiguda	13.22	14.40	01.18	OL	11KV Incoming AB Switch bus T-Clamp snapped & 11KV outgoing AB switch Jumper cut in SS Yard & 11KV 3Nos HG Fuses failed near Pioneer Company	-
2		Kushaiguda	Kamala Nagar	11KV	Sainikpuri	01.00	03.30	02.30		Tree branches fallen on 11Kv line AND 11KV Disk failed at Kamala Nagar (LM Srinivas Reddy)	-
3		RGK	Nissa	11KV	Sainikpuri	02.47	07.30	04.43		Tree branches fallen on 11Kv line and line snapped at Nissa (LM Rajendar)	-
4		BANDLAGUDA	WAMBAY COLONY	11KV	SAROORNAGAR	13.20	14.25	01.05		CLOTHU FALL ON 11KV LINE AND 11KV JUPER CUT AT BALAJI NAGAR	-
5		BANDLAGUDA	Chanakyapuri	11KV	SAROORNAGAR	20.55	22.55	02.00	EL/OL	11kv Disk Failed at Sai Nagar Road No 3	-
6		Yadgarpally	Yadgarpally	11KV	Keesara	00.05	07.35	07.30		Tree fallen on 11KV Line at Narsampally	-
7		Singapur	RGK	11KV	Keesara	00.10	01.45	01.35		11KV AB Switch Insulator failed at RGK-36 Block	-
8		BANJARA COLONY	BEERAPPATEMPLE	11KV	SAROOR NAGAR	07.20	08.25	01.05	EL	CT BT FAIL AT SAI NAGAR	-

1	HYD N	K.I.M.S	D.V Colony	11KV	Sec-Bad	00.00	04.03	04.03	EL,OL-Rph	Tree fallen on lines at D.V Colony	-
2		Gymkhana	Vayu Sena	11KV	Sec-Bad	00.35	01.49	01.14	EL,OL	HT Service fault	-
3		Yousufguda	Police Lines	11KV	Banjarahills	01.55	03.20	01.25	All Indication	Tree branches fallen on lines at Police Line	-
4		Gymkhana	Vikrampuri	11KV	Sec-Bad	01.58	04.28	02.30	EL,OL	No Visible Fault	Opened line AB Switch at Text Book Coloy
5		Mothi Nagar	N.R.R Puram	11KV	Erragadda	00.52	02.40	01.48	EL,OL-Rph	Tree branches fallen on lines at Sri Nilayam Apts	-
6		H.A.L	I.A.L	11KV	Bowenpally	01.25	02.32	01.07	EL,OL-Rph	No Visible Fault	Arranged B/F on 11KV IAF fdr
7		Gymkhana	Mud Fort	11KV	Sec-Bad	03.05	05.05	02.00	EL,OL	Tree branches fallen on lines at Mud Fort	-
8		Gymkhana	Vasavi Nagar	11KV	Sec-Bad	03.08	04.45	01.37	EL,OL	No Visible Fault	Arranged B/F on 11KV Vikrampuri fdr
9		Gunrock	Lal Bazar	11KV	Bowenpally	00.45	04.05	03.20	EL,OL-Bph	No Visible Fault	-
10		Gunrock	Surya Enclave	11KV	Bowenpally	00.10	04.25	04.15	EL,OL-Bph	Tree branches fallen on lines at Surya Enclave	-
11		Gunrock	Gymkhana	11KV	Sec-Bad	03.10	05.55	02.45	EL,OL-Bph	Tree branches fallen on lines at Surya Nagar	-
12		Gymkhana	Mud Fort	11KV	Sec-Bad	05.42	07.00	01.18	EL,OL	Disc Insulator flash over at BHEL Colony	-
13		Nehru Nagar	Hara Hara Kala Bhavan	11KV	Sec-Bad	04.41	14.15	09.34	All Indication	Water gon in RMU at 4th Pole Structure, Paradise & C.M.R	-
14		James Street	Asrani Hotel	11KV	Sec-Bad	09.00	11.20	02.20	EL,OL-Rph	HT Jumper cut near SS	-
1	HYD S	Miralam	Water Works	11KV	Charminar	01.20	03.05	01.45	EL,OL	2No. HG fuses & Bushings at Miralam Water Works	-
2		Chanchalguda	Anand Nagar	11KV	Asmangadh	03.15	04.35	01.20	OL-Rph	Tree branches fallen on lines at Anand Nagar	-
3		Santosh Nagar	Moon Star	11KV	Asmangadh	03.30	04.35	01.05	EL,OL-Rph	No Visible Fault	-
4		Womens College	Quthbiguda	11KV	Begumbazar	10.18	14.08	03.50	EL	Cable fault at IMA Hall	-
5		Malakpet	M.M.H	11KV	Asmangadh	14.10	15.40	01.30	OL-Bph	Disc Insulator flash over, Cable fault	-
6		Gunj	Farhath Nagar	11KV	Asmangadh	18.05	19.23	01.18	OL-RPh	No Visible Fault	-
7		Malakpet "B" Block	Akbar Bagh	11KV	Asmangadh	18.17	20.13	01.56	All Indication	Disc flash over at New Gafoor Apts	-
1	HYD C	S.D Hospital	Ahmed Nagar Cable	11KV	Mehdipatanam	00.35	01.50	01.15	EL	AB Cable End Kit failed at Bismillah PT	-
2		S.D Hospital	Crescent Hospital	11KV	Mehdipatanam	00.50	02.08	01.18	All Indication	HG fuse burntout at Pramila Enclave	-
3		S.D Hospital	Police Mess	11KV	Mehdipatanam	02.50	04.04	01.14	All Indication	No Visible Fault	Arranged B/F on 11KV Ahmed Nagar OH feeder
4		A.C.Gaurds	Shanthi Nagar	11KV	Mehdipatanam	18.05	20.20	02.15	OL-Bph	Breaker fault	Arranged B/f on 11KV Afzal Sagar feeder
5		Vittalwadi	Taj Mahal Hotel	11KV	Saifabad	18.10	19.30	01.20	EL	Tree branches on lines at King Koti Hospital	-

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		3		3		3			
5	RR(N)	82	407	5	19	5	19	5	19			
6	RR(E)	38	360		8		8		8			
7	Hyd	186	1014		26		26		26			
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>5</b>	<b>56</b>	<b>5</b>	<b>56</b>	<b>5</b>	<b>56</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969		5		5		5			
2	NLG	150	948	1	8	1	8	1	8			
3	MDK	87	828	7	6	7	6	7	6			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>8</b>	<b>19</b>	<b>8</b>	<b>19</b>	<b>8</b>	<b>19</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>13</b>	<b>75</b>	<b>13</b>	<b>75</b>	<b>13</b>	<b>75</b>	<b>0</b>	<b>0</b>	