

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Kowdipally	Amsanpally	33kv	Medak	06.30	08.30	02.00		B/D Due to Conductor Snapped	Amsanpally	-
2		Zaheerabad	Mannapur	33kv	Zaheerabad	21.35	00.00	02.25		Still under continue	Mannapur	Not arranged
1	RR N	Bollaram	Kukatpally	33kv	Kukatpally	16.10	00.30	07.50	BD	33kv jumper cut and 33kv Cable failed	Kukatpally	-

## TSSPDCL - LMRC / Corporate office

Date: 27.08.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Devarkadra	Gaddegudem	11kv	Mahabubnagar	07.00	10.00	03.00		11KV Conductor cut Near Balsupally (Vi)	-
2		Marikal	Theelair	11kv	Mahabubnagar	21.00	23.00	02.00		11KV Insulator Damage near Marikal.	-
1	NLG	Mamidala	Aregudem	11kv	Nalgonda	11.45	14.20	02.35	E/L	11 KV line cut SS.64	-
2		Appajipeta	Appajipeta	11kv	Nalgonda	11.45	13.20	01.35	E/L	11 KV line insulator failed SS.2	-
3		Penpahad	Annaram	11kv	Suryapet	12.00	13.15	01.15	E/L	Tree branch fallen	-
4		Siripuram	Vallapuram	11kv	Huzurnagar	00.00	05.00	05.00	EL	Due to 11Kv Insulator Failure near Vallapuram village	-
5		Keethavarigudem	Rainigudam	11kv	Huzurnagar	14.10	18.20	04.10	EL	Due to 11kv Jumper cutted near Rainigudam village	-
1	MDK	Chinnthamadaka	Chinnthamadaka	11kv	Siddipet	01.30	08.30	07.00		B/D Due to AB Switch failure Near Dammachru village	-
2		Gonepally	Mandapally	11kv	Siddipet	10.30	13.00	02.30		B/D Due to Conductor Snapped at Mandapally Village	
3		Chellapur	Chellapur	11kv	Siddipet	00.00	06.00	06.00		B/D Due to Jumper Cut	
4		Chellapur	Rajakkapet	11kv	Siddipet	00.00	06.00	06.00		B/D Due to Jumper Cut	
5		Jangapally	Veera Reddy Pally	11kv	Siddipet	00.00	13.00	13.00		B/D Due to Insulator failure Veera Reddy Pally Village	
6		Jangapally	Jangapally	11kv	Siddipet	12.00	12.30	00.30		B/D Due to AB Switch failure Near Dammachru village	
7		Mirdoddy	Mirdoddy AGL	11kv	Siddipet	06.00	11.30	05.30		B/D Due to Jumper Cut at Laxmi Nagar Village	
8		M. Bhupathipur	Guttakindipally	11kv	Medak	10.11	14.30	04.19		B/D Due to Conductor Snapped	
9		Chippalthurthy	Chippalthurthy	11kv	Medak	15.20	18.00	02.40		B/D Due to Insulator failure	
10		Venktraopet	Thunki	11kv	Medak	16.00	18.10	02.10		B/D Due to Insulator failure	-
11		Alladurg	Rampur	11kv	Medak	10.10	13.40	03.30		B/D Due to Insulator failure	-
12		Gadipeddapur	Gadipeddapur	11kv	Medak	07.20	13.00	05.40		B/D Due to Jumper Cut	-

13

Bollaram-I	Sulakshna	11kv	Sangareddy	08.30	12.05	03.35		B/D Due to Jumper Cut	-
------------	-----------	------	------------	-------	-------	-------	--	-----------------------	---

1	RR N	Bachupally	S M S	11kv	Kukatpally	16.30	17.50	01.20	BD	11kv Pin Insultor Failure At AnaPurana Company	-
2		J D M Ss-I	Subashanagar	11kv	Jeedimetla	16.25	17.45	01.20	BD	11kv Line Petroling No fault [Due To Heavy Rain }	-
3		HMT	Manikya Nagar	11kv	Medchal	16.40	18.25	01.45	BD	11KV Pin Insulator failed at Srinivas Nagar	-
4		Athiwelly	Spic	11kv	Medchal	20.45	22.20	01.35	BD	11kv jumper touch to the Kasaram at yellampet X road	-
1	RR E	Moula-Ali	HMT	11kv	Sainikpuri	15.05	15.45	00.40		Tree branches fallen on 11Kv line at Thirumala Nagar (AE/OP)	-
2		Cherlapally-I	Phase-II	11kv	Sainikpuri	09.30	10.10	00.40		Parrot fallen on 11Kv line at VRL Industry (AE/OP)	-
3		Cherlapally-I	Phase-I	11kv	Sainikpuri	17.50	18.25	00.35		11Kv line jumper cut at Gansh Winding Compony (LM Kashiram)	-
4		Mallapur	IDA	11kv	Habsiguda	05.00	06.40	01.40		Disc Failed at Joflo Company	-
5		Yadgarpally	Yadgarpally	11kv	Keesara	16.30	19.00	02.30		Insulator failed at Yadgarpally Village	-
6		Yadgarpally	Timmaipally	11kv	Keesara	15.20	19.20	04.00		HT/LT Line Lopped and removed at Timmaipally Village	-
1	HYD N	H.A.L	Samrat	11kv	Bowenpally	16.50	18.30	01.40	EL	No Visible Fault	Arranged B/F on 11KV B.B.R Hospital feeder
2		Macha Bollaram	Reddy Enclave	11kv	Bowenpally	17.50	20.00	02.10	EL	Cable fault	Arranged B/F on 11KV Allwal fdr
3		Chinna Thokatta	C.E Colony	11kv	Bowenpally	17.54	20.20	02.26	EL,OL-Bph	Disc Insulator flash over at MRK Towers	-----
4		Tirumalagiri	Kanajiguda	11kv	Bowenpally	18.58	20.15	01.17	EL,OL-Bph	Cable fault	Arranged B/F on 11KV Medchal feeder
5		Gunrock	Thirumalgiri	11kv	Bowenpally	20.25	22.00	01.35	EL,OL	Disc Insulator flash over at 1st line AB Switch	-----
1	HYD S	Moosarambagh	Moosarambagh	11kv	Asmangadh	06.55	09.30	02.35	EL,OL-Yph	RMU Cable End Kit failed at Hegde Nursing Home	Partial fdr charged & remaining loads added on 11KV Shalivahana Nagar feeder
2		Malakpet	Yashoda Hospital	11kv	Asmangadh	07.10	08.30	01.20	All Indication	No Visible Fault	-----
3		Kandikal Gate	Indira Nagar	11kv	Charminar	23.16	00.24	01.08	OL-Rph	HT Lines Twisted & Kite stick fallen on lines at Janda PT	-----

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407	1	4	1	4	1	4			
6	RR(E)	38	360		6		6		6			
7	Hyd	186	1014		8		8		8			
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>1</b>	<b>18</b>	<b>1</b>	<b>18</b>	<b>1</b>	<b>18</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969		2		2		2			
2	NLG	150	948		5		5		5			
3	MDK	87	828	2	13	2	13	1	13	1		1No. 33kv Still
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>2</b>	<b>20</b>	<b>2</b>	<b>20</b>	<b>1</b>	<b>20</b>	<b>1</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>3</b>	<b>38</b>	<b>3</b>	<b>38</b>	<b>2</b>	<b>38</b>	<b>1</b>	<b>0</b>	