

TSSPDCL - LMRC / Corporate office

Date: 30.08.17

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Gadwal	Dharoor	33KV	Gadwal	21.30	23.40	02.10	E/L	Tree fallen on the Line and Tree Branches Removed near at Dharoor SS	Dharoor	No
2		leeza	Madelabanda	33KV	Gadwal	19.55	00.55	05.00	E/L	Pin insulator failed near KR Chervu Road	Madelabanda	No
1	MDK	Sadashivapet	Jogipet	33KV	Sangareddy	20:20	21:40	1:20		Jumper cut	Jogipet	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Teegalapally	Kakarlpad	11KV	Mahabubnagar	10.00	11.00	01.00		11KV Tree fallen on conductor at Siddotom (V)	No
2		Nawabpet	Gurkunta	11KV	Mahabubnagar	06.00	11.30	05.30		11KV Insulator damage at Kamaram (V)	No
3		Pallerla	Parsapur	11KV	Mahabubnagar	06.30	13.00	06.30		11KV Tree fallen on conductor at Chendrai thanda (V)	No
4		Doultabad	G F Wada	11KV	Mahabubnagar	02.30	05.50	03.20		11KV Conductor cut at Polkampally (V)	No
1	NLG	GT Giri	G T Giri	11KV	Suryapet	06.35	09.00	02.25	E/L	Insulator failed	No
2		Dondapahad	Kakatiya	11KV	Huzurnagar	09.20	10.20	01.00	EI	11KV Conductor snapped at Kakatiya village	No
3		Ponugodu	Ponugodu	11KV	Huzurnagar	08.40	09.50	01.10	EI	11KV Line snapped at ponugodu village	No
4		Timmareddy gudem	Timmareddy gudem	11KV	Huzurnagar	13.50	15.25	01.35	EI	11KV Line snapped at Timmareddygudem village	No
5		Repala	Narsimhalagudem	11KV	Huzurnagar	09.00	12.00	03.00	EI	11KV Insulator failed at Narsimhalagudem village	No
1	MDK	Peddacheekode	Achumaipally	11KV	Siddipet	00.00	06.00	06.00		Tree Braches fallen on the 11 KV line	No
1	RR S	NPA	Babulreddy nagar	11KV	Rajendranagar	23:22	2:50	3:28		11KV Cable failed at Madras plastic	No
1	RR N	Vijayanagar	AS raju nagar	11KV	KKP	08.15	09.50	01.35		11KV AB cable failed	No
2		KPHB	HyderNagar	11KV	KKP	16.16	19.00	02.44		No visible fault	No
3		Chinthal	Dwaraka nagar	11KV	Medchal	23.35	01.10	01.30		11KV Cable failed	No
4		Chinthal	Surya Nagar	11KV	Medchal	23.40	01.10	01.30		11KV Cable failed	No
5		Aliabad	Bommarajpet	11KV	Medchal	05.30	07.30	02.00		No visible fault	No
6		Thurkapally	Thurkapally	11KV	Medchal	12:55	14:00	1:05		Bird fallen on the 11KV Line	No
1	RR E	Peerzadiguda	Chenna Reddy Thota	11KV	Keesara	11:25	12:36	1:11		11KV Insulator failed at Boduppal Kaman	No
1	HYD N	Film Nagar	B.V.Bhavan	11KV	Jublee Hills	04.50	06.43	01.53	EL,OL-Bph	Cable fault	Partial fdr charged & remaining loads added on 11KV Padmalaya Studio fdr

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		1		1		1			
5	RR(N)	82	407		6		6		6			
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014		1		1		1			
	Total	504	2929	0	9	0	9	0	9	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	2	4	2	4	2	4			
2	NLG	150	948		5		5		5			
3	MDK	87	828	1	1	1	1	1	1			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	3	10	3	10	3	10	0	0	
	Grand Total	908	6149	3	19	3	19	3	19	0	0	