

TSSPDCL - LMRC / Corporate office

Date: 31.08.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Penpahad	Potlapahad	11KV	Suryapet	10.10	12.15	02.05	E/L	11Kv Jumper cut	-
2		Chilkuru	Bethavolu	11KV	Huzurnagar	14.45	15.45	01.00	E/L	11Kv Jumper cut near Bethavolu (v)	-
3		Veliminedu	Veliminedu	11KV	Nalgonda	06.00	08.00	02.00	E/L	11Kv Jumper cut	-
4		Aroor	A.R Pally	11KV	Bhogir	06.30	10.30	04.00	E/L	11KV Jumper snapped	-
5		Rajapet	Pamukunta	11KV	Bhogir	11.30	15.30	04.00	E/L	11KV Line snapped & Insultor failed	-
6		Shivannagudem	R.R.Pally	11KV	Devarakonda	15.00	17.30	02.30	E/L	11kv Insulator failure	-
7		Marriguda	Vattipally	11KV	Devarakonda	03.00	06.00	03.00	E/L	11kv jumper cut	-
1	RR N	Vijayanagar	AS RajuNagar	11KV	Kukatpally	01.05	03.40	02.35	BD	11kv line AB Cable Failure at Venkateshwer Temple {B/F V V N Nagar }	-
2		Kandlakoya	Godrej	11KV	Medchal	10.50	11.45	00.55	BD	11KV Line Cut at Kaveri Seeds	-
3		Yellampet	IDA	11KV	Medchal	15.35	16.46	01.11	BD	Tree fallen on the 11KV Line at Bisco Seeds Company	-
1	RR E	Peerzadiguda	Chenna Reddy Thota	11KV	Keesara	11.25	12.36	01.11		11KV Insulator failed at Boduppall Kaman	-

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBN				NIL							-
2	NLG				NIL							-
3	MDK				NIL							-
4	RRS				NIL							-
5	RR N				NIL							-
6	RR E				NIL							-
7	HYD				NIL							-

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		3		3		3			
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014									
	Total	504	2929	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		7		7		7			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	0	7	0	7	0	7	0	0	
	Grand Total	908	6149	0	11	0	11	0	11	0	0	