

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		1		1		1			
5	RR(N)	82	407		4		4		4			
6	RR(E)	38	360									
7	Hyd	186	1014		2		2		2			
	Total	504	2929	0	7	0	7	0	7	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		4		4		4			
3	MDK	87	828	1	3	1	3	1	3			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	1	7	1	7	1	7	0	0	
	Grand Total	908	6149	1	14	1	14	1	14	0	0	

TSSPDCL - LMRC / Corporate office

Date: 01.12.17

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Sadasivpet	Manjeera	33KV	Sangareddy	14:50	18:55	4:05		AB Switch failed and conductor snapped	Manjeera	No

TSSPDCL - LMRC / Corporate office

Date: 01.12.17

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Cheedella	Cheedella	11KV	Suryapet	5:00	8:30	3:03	EL	Line Cut	No
2		Raghunadapalem	Nakkagudam	11KV	Huzurnagar	00.00	07.15	07.15	EL	HT/LT Line touched at Raghunadapalem village	No
3		Nadigudam	Ratnavaram	11KV	Huzurnagar	08.15	11.25	03.10	EL	11 kv line snapped at Ratnavaram village	No
4		Anatharam	Hanumapuram	11KV	Bongir	10.45	11.55	01.10	EL	11KV Jumper snapped at Yad	No
1	MDK	Chittapur	Enagurthy	11KV	Siddipet	22:40	6:20	7:40		Tree branches fallen on the line	No
2		Chittapur	Enagurthy	11KV	Siddipet	08.50	11.00	02.10		Tree branches fallen on the line	No
3		Podchanpally	Laximinager	11KV	Medak	00.00	08.00	08.00		Jumper cut and conductor snapped	No
1	RR S	Ibrahimbagh	Military-I	11KV	Ibrahimbagh	16:32	17:45	1:13		No visible falut	No
1	RR N	Jeedimetla-III	Pipe line Road	11KV	Jeedimetla	5:05	6:25	1:20	EL	Incoming jumper cut at M M Plastic	No
2		Mayurinagar	Cable	11KV	Kukatpally	07.15	08.50	01.35	EL&OL	No visible falut	No
3		Chinthal	Ganesh Nagar	11KV	Medchal	09.40	10.15	00.35	BD	Tree fallen on the 11KV Line at Ganesh Nagar Kaluva	No
4		Gowdavelly	IDA	11KV	Medchal	09.30	10.20	00.50	BD	Bird fallen on the 11KV Line at VIVA Company	No
1	HYD N	Lalaguda	Chenna Reddy	11KV	V	02.30	03.30	01.00	EL	UG Cable fault at SBH Nalla, Metro Station	No
1	HYD S	Asmangadh	Shiva Ganga	11KV	VIII	00.50	02.30	01.40	EL,OL-Rph	RMU Cable fault at Red X Hospital & Disc Insulator flashed over	No