

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407									
6	RR(E)	38	360									
7	Hyd	186	1014	1	1	1	1	1	1			
	Total	504	2929	1	1	1	1	1	1	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	1	2	1	2	1	2			
2	NLG	150	948		9		9		9			
3	MDK	87	828	2		2		2				
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	3	11	3	11	3	11	0	0	
	Grand Total	908	6149	4	12	4	12	4	12	0	0	

TSSPDCL - LMRC / Corporate office

Date: 02.12.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Ghanpur	Solipur	33KV	Wanaparthi	07.58	09.54	01.56	E/L	Tree Branches Touched to the Line near at 33KV SS Ghanpur	Ghanpur	-
1	MDK	Duddeda	Bandaram	33KV	Siddipet	05.00	08.15	03.15		BD due to Jumper cut	Duddeda	-
2		Manoharabad	Shivampet	33KV	Toopran	04.30	06.30	02.00		BD due to Insulator failed	Manoharabad	-
1	HYD C	132KV Asif Nagar	Kulsumpura	33KV	AsifNagar	12.10	12.20	00.10	EL,OL-Yph	Cable Joint failure Opp SBI Bank, Amba Garden, Medhipatnam	132KV Asif Nagar	Loads transferred onto 132KV Imlibun - Goshamahal

TSSPDCL - LMRC / Corporate office

Date: 02.12.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Gudeballore	Mudmall	11KV	Mahabubnagar	11.00	11.45	00.45		11KV Conductor cut Near Monnappa Temple	-
2		Badepally	Burugupally	11KV	Jadcherla	13.00	17.00	04.00		11 KV Wire Cut Near Burgupally Tanda side.	-
1	NLG	Arlagaddagudem	N.R.Gudem	11KV	Nalgonda	02.00	06.30	04.30	E/L	11KV jumper cut	-
2		Arlagaddagudem	Mangalapally	11KV	Nalgonda	04.35	08.30	03.55	E/L	11KV jumper cut	-
3		Kolanupaka	Somaram	11KV	Bhongri	13.45	16.30	02.45	E/L	11KV Jumper snapped at D.R gudem	-
4		N.G.Bandala	Gandhamalla	11KV	Bhongri	12.20	13.45	01.25	E/L	11KV Line sanpped at Gandhamalla	-
5		Maryala	Mailaram	11KV	Bhongri	01.00	05.20	04.20	E/L	11Kv Jumper snapped at Mailaram	-
6		Mukundapuram	Somaram	11KV	Huzurnagar	08.00	12.00	04.00	E/L	Bird fall on 11Kv line near Somaram (v)	-
7		Mattampally	Allipuram	11KV	Huzurnagar	03.00	07.00	04.00	E/L	11kv insulator failure near Allipuram (v)	-
8		Urulugonda	Thummagudem	11KV	Huzurnagar	16.00	17.20	01.20	E/L	11Kv Jumper cutted nearThummagudem (v)	-
9		Gudimalkapuram	Chintalapalem	11KV	Huzurnagar	16.00	17.40	01.40	E/L	11Kv line Cutted near Chintalapalem (v)	-
1	HYD C	Hussain Sagar	Lakadi-Ka-Pool	11KV	Saifabad	12.30	15.40	03.10	EL,OL	Cable Fault	Arranged B/F on 11KV Meera Theater feeder