

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		1		1		1			
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014		1		1		1			
	Total	504	2929	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	1		1		1				
2	NLG	150	948		4		4		4			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	1	4	1	4	1	4	0	0	
	Grand Total	908	6149	1	7	1	7	1	7	0	0	

TSSPDCL - LMRC / Corporate office

Date: 03.12.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Ghanpur	Lattupally	33KV	Wanaparthu	08.52	09.43	00.51	E/L	No Visible Fault	Lattupally	AB Switch Opened at Chegunta at 9:43Hrs Supply OK

TSSPDCL - LMRC / Corporate office

Date: 03.12.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Yerkaram	Ramannagudem	11KV	Suryapet	09.00	10.20	01.20	E/L	Line Cut	-
2		IDA	Bommaipally	11KV	Bhongir	05.00	08.00	03.00	EL	11KV Jumper snapped at singannagudem	-
3		Mattampally	Choutapally	11KV	Huzurnagar	02.00	06.00	04.00	EL	11 kv inslater failed at Choutapally village	-
4		Kandibanda	N.B Gudem	11KV	Huzurnagar	06.00	08.30	02.30	EL	11 inslater failed at NB Gudem village	-
1	RR N	Jeedimetla-III	Pipe line Road	11KV	Jeedimetla	05.05	06.25	01.20	EL	Incoming Jumper Cut at M M Plastic	-
1	RR E	Mohan Nagar	R.K Puram	11KV	SAROORNAGAR	10.42	12.05	01.23	OL	11KV Line Snapped at Mohan Nagar Govt School Backside	-
1	HYD C	Bathkamma Kunta	D.D.Colony	11KV	II	20.40	00.08	03.28	OL-Rph	Big Tree fallen on lines at D.D.Colony	-