

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		4		4		4			
6	RR(E)	38	360									
7	Hyd	186	1014		1		1		1			
	Total	504	2929	0	5	0	5	0	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	1		1		1				
2	NLG	150	948		9		9		9			
3	MDK	87	828	1	4	1	4	1	4			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	2	13	2	13	2	13	0	0	
	Grand Total	908	6149	2	18	2	18	2	18	0	0	

TSSPDCL - LMRC / Corporate office

Date: 05.12.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Kodangal	Kothur	33KV	Mahabubnagar	14.25	15.20	00.55	O/L	AB Switch Open at Kothur SS toward Bomraspet Line	Kothur	-
1	MDK	Gajwel	Shivam smelters	33KV	Toopran	11.45	13.10	01.25		B/D Due to Conductor Snapped	Shivam smelters	-

TSSPDCL - LMRC / Corporate office

Date: 05.12.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Yerkaram	Das thanda	11KV	Suryapet	03.00	06.30	03.30	E/L	Jumper cut	-
2		Bibinagar	Raghavapur	11KV	Bhongir	11.10	14.30	03.20	EL	11KV DTR Failure at raghavapur	-
3		Addaguduru	Ch.Ramaram	11KV	Bhongir	23.00	02.00	03.00	EL	11KV Line snapped at ch.ramaram	-
4		Maryala	Wadaparthi	11KV	Bhongir	12.00	15.30	03.30	EL	11KV Line snapped at Wadaparthi	-
5		Rajapeta	Rajpet AGL	11KV	Bhongir	07.00	10.30	03.30	EL	11KV Jumper snaped at Rajapeta	-
6		Rajapeta	Narasapuram	11KV	Bhongir	02.00	05.00	03.00	EL	11KV Insulator failed at Narsuparam	-
7		Pedaveedu	Lothuvagu	11KV	Huzurnagar	10.30	13.00	02.30	EL	11 kv line snapped at Lothuvagu village	-
8		Chilukur	Janakinagar	11KV	Huzurnagar	08.20	10.40	02.20	EL	11 Disk failed at Seethal thanda village	-
9		Ravipahad	Burkacherla	11KV	Huzurnagar	14.00	16.00	02.00	EL	11 kv line snapped at Burkacherla village	-
1	MDK	Kallakal	Kallakal AGL	11KV	Toopran	11.00	13.00	02.00		B/D Due to tree branches fallen on line	-
2		Narsapur	Kagazmaddur	11KV	Medak	13.01	18.00	04.59		B/D Due to Jumper Cut	-
3		Seelampally	Chilipched	11KV	Medak	11.40	12.24	00.44		B/D Due to 11KV line Cut	-
4		Gadipeddapur	Muslapur	11KV	Medak	11.20	12.15	00.55		B/D Due to tree branches fallen on line	-
1	RR N	Subash Nagar	Jeedimetla	11KV	Medchal	05.35	06.25	00.50		Tree branch fallen on the 11KV Line at HDFC Bank, Jeedimetla	-
2		Nuthankal	Oyster	11KV	Medchal	06.50	09.45	02.55		Tree branch fallen on the 11KV line & Pin Insulator failed at Lingapur	-
3		Kandlakoya	Kandlakoya	11KV	Medchal	14.50	15.50	01.00		11KV Fourth wire touched with Kaasaram at Outer Ringroad	-
4		Athiwelly	SPIC	11KV	Medchal	19.35	20.20	00.45		Bird fallen on the 11KV Line at SPIC Company	-
1	HYD N	Madhapur	HUDA	11KV	Jubilee Hills	17.05	18.45	01.40	EL,OL	RMU fault at Metro Station	