

## Status Report on Breakdowns (Urban / Rural)

Urban

| S.No | Circle       | No.of Feeders Existing Urban |             | Breakdowns occurred during the day |          | Attended during the day |          | Time taken for restoring the supply |          |                                |          | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
|      |              | 33KV                         | 11KV        | 33KV                               | 11KV     | 33KV                    | 11KV     | Rectified (Within 24 Hours)         |          | Not Rectified (Above 24 Hours) |          |                   |
|      |              |                              |             |                                    |          |                         |          | 33KV                                | 11KV     | 33KV                           | 11KV     |                   |
| 1    | MBN          | 48                           | 158         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 2    | NLG          | 18                           | 406         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 3    | MDK          | 92                           | 383         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 4    | RR(S)        | 40                           | 201         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 5    | RR(N)        | 82                           | 407         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 6    | RR(E)        | 38                           | 360         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 7    | Hyd          | 186                          | 1014        |                                    |          |                         |          |                                     |          |                                |          |                   |
|      | <b>Total</b> | <b>504</b>                   | <b>2929</b> | <b>0</b>                           | <b>0</b> | <b>0</b>                | <b>0</b> | <b>0</b>                            | <b>0</b> | <b>0</b>                       | <b>0</b> |                   |

Rural

| S.No | Circle             | No.of Feeders Existing Rurals |             | Breakdowns occurred during the day |          | Attended during the day |          | Time taken for restoring the supply |          |                                |          | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
|      |                    | 33KV                          | 11KV        | 33KV                               | 11KV     | 33KV                    | 11KV     | Rectified (Within 24 Hours)         |          | Not Rectified (Above 24 Hours) |          |                   |
|      |                    |                               |             |                                    |          |                         |          | 33KV                                | 11KV     | 33KV                           | 11KV     |                   |
| 1    | MBN                | 110                           | 969         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 2    | NLG                | 150                           | 948         | 1                                  | 3        | 1                       | 3        | 1                                   | 3        |                                |          |                   |
| 3    | MDK                | 87                            | 828         | 1                                  |          | 1                       |          | 1                                   |          |                                |          |                   |
| 4    | RR(S)              | 31                            | 338         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 5    | RR(N)              | 8                             | 48          |                                    |          |                         |          |                                     |          |                                |          |                   |
| 6    | RR(E)              | 18                            | 89          |                                    |          |                         |          |                                     |          |                                |          |                   |
|      | <b>Total</b>       | <b>404</b>                    | <b>3220</b> | <b>2</b>                           | <b>3</b> | <b>2</b>                | <b>3</b> | <b>2</b>                            | <b>3</b> | <b>0</b>                       | <b>0</b> |                   |
|      | <b>Grand Total</b> | <b>908</b>                    | <b>6149</b> | <b>2</b>                           | <b>3</b> | <b>2</b>                | <b>3</b> | <b>2</b>                            | <b>3</b> | <b>0</b>                       | <b>0</b> |                   |

## TSSPDCL - LMRC / Corporate office

Date: 06.12.2017

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol  | Name of the Division | From  | To    | Duration | Relay Indication | Cause of Breakdown                  | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|-------------------------------------|---------------------------|
| 1    | NLG    | Kandagatla         | Guttakinda           | 11KV | Suryapet             | 03.30 | 06.25 | 02.55    | E/L              | Tree branch fallen on the line      | -                         |
| 2    |        | Kondamadugu        | Kondamadugu          | 11KV | Bhongir              | 08.30 | 10.30 | 02.00    | E/L              | Bird fallen On Line at Kondamadugu  | -                         |
| 3    |        | Azeempet           | Azeempet             | 11KV | Bhongir              | 11.30 | 15.50 | 04.20    | E/L              | 11Kv Disk Failed, HT/LT Near Veldvi | -                         |

TSSPDCL - LMRC / Corporate office

Date: 06.12.2017

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol  | Name of the Division | From  | To    | Duration | Relay Indication | Cause of Breakdown                            | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|-----------------------|---------------------------|
| 1    | MDK    | Bollaram            | Shathavahana         | 33kv | Sangareddy           | 03.30 | 07.35 | 04.05    |                  | B/D due to Insulator fail.                    | Shathavahana          | -                         |
| 1    | NLG    | Miryalguda          | Huzurnagar           | 33kv | Miryalguda           | 07.10 | 10.45 | 03.35    | O/L              | 33KV Pin Insulator failed at Rudraram village | Huzurnagar            | -                         |