

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		1		1		1			
5	RR(N)	82	407		1		1		1			
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014									
	Total	504	2929	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		2		2		2			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	0	2	0	2	0	2	0	0	
	Grand Total	908	6149	0	5	0	5	0	5	0	0	

TSSPDCL - LMRC / Corporate office

Date: 07.12.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Gundepuri	Gundepuri	11KV	Suryapet	14.00	16.30	02.30	E/L	Line cut	-
2		Athmakur	Tukkapuram	11KV	Bhongir	02.00	07.20	05.20	EL	11KV Insulator failed , 11KV Jumper snapped at Tukkapuram	-
1	MDK	kallakal	immapur	11KV	Toopran	11.20	16.00	04.40		B/D Due to Jumper Cut.	-
1	RR S	Puppalaguda	Alkapuri	11KV	IBGH	08.10	09.10	01.00	B/D	No Visible Fault	-
1	RRN	Kandlakoya	Saigeetha Ashramam	11KV	Medchal	11.45	14.20	02.35	BD	Bird fallen on the 11KV Line at Saigeetha Ashramam Backside	-
1	RR E	Cherelapally-I	Phase-I	11KV	Sainikpuri	14.55	15.25	00.30		Lezard fallen on 11Kv line at Pharmaha Industry Phase-II (L Insp Satyanarayan)	-