

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		1		1		1			
5	RR(N)	82	407		1		1		1			
6	RR(E)	38	360									
7	Hyd	186	1014		1		1		1			
	Total	504	2929	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	1	1	1	1	1	1			
2	NLG	150	948		3		3		3			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	1	4	1	4	1	4	0	0	
	Grand Total	908	6149	1	7	1	7	1	7	0	0	

TSSPDCL - LMRC / Corporate office

Date: 08.12.17

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Nagarkurnool	Bijinapally	33KV	Nagarkurnool	00.30	02.30	02.00	EL	Jumper cut at Bijinapally SS	Bijinapally	No

TSSPDCL - LMRC / Corporate office

Date: 08.12.17

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Bhoothpur	Bhoothpur®	11KV	Jadcherla	13.00	17.05	04.05		11KV Jumper cut near Bhoothpur Tanda side	No
1	NLG	Alair	Ch.kandukur	11KV	Bhongir	12:30	17:15	4:45	EL	Insulator failed	No
2		Raghunadapalem	Gundlapally	11KV	Huzurnagar	05.00	09.00	04.00	EL	11KV Jumper cut near Raghunadapalem village	No
3		Ananthagiri	Shantinagar	11KV	Huzurnagar	07.40	11.35	03.55	EL/OL	Jumper cut	No
1	RR S	Appa	Himayathsagar	11KV	Rajendranagar	6:00	7:25	1:25		Bird fallen on 11 KV line at Sadan College	No
1	RR N	Kandlakoya	Saigeetha Ashramam	11KV	Medchal	5:20	6:20	1:00		11KV Pole damaged by Lorry at Yaganti Seeds, KV Reddy Nagar	No
1	HYD S	Malakpet	Bibi Ka Alawa	11KV	Asmangadh	02.35	03.50	01.15	All Indication	Cable damaged	Arranged B/F on 11KV Farath Nagar & Yakuthpura feeders