

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		4		4		4			
6	RR(E)	38	360									
7	Hyd	186	1014	1	1		1		1			
	Total	504	2929	1	5	0	5	0	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969		1		1		1			
2	NLG	150	948	1	3	1	3	1	3			
3	MDK	87	828		2		2		2			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	1	6	1	6	1	6	0	0	
	Grand Total	908	6149	2	11	1	11	1	11	0	0	

TSSPDCL - LMRC / Corporate office

Date: 09.12.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Bibinagar	Bhongir	33KV	Bhongir	12.45	14.30	01.45	OL/EL	33KV Jumper snapped near TDR Polytechnic College	Bibinagar	-
1	HYD S	220KV Shivarampally	Miralam UG	33KV	Malakpet	16.05	16.20	00.15	EL	2no Cable Joint failed at M.J Palace, Kurnool Road by HMWS&SB Wing	220KV Shivarampally	Loads transferred onto 220KV Shivarampally - Ch' Baradari OH

TSSPDCL - LMRC / Corporate office

Date: 09.12.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Pedda Revally	Industrial	11KV	Jadcherla	14.00	15.00	01.00		Tree follon the line Chinna Revally	-
1	NLG	Penpahad	Macharam	11KV	Suryapet	14.00	15.00	01.00	EL	Line cut	-
2		Kethepally	Kasanagode	11KV	Nalgonda	07.00	10.00	03.00	EL	11 KV line jumper cut	-
3		Nadigudem	Ramapuram	11KV	Huzurnagar	15.30	16.30	01.00	EL	11 KV line snapped at Ramapuram village	-
1	MDK	Gonepally	Mandapally	11KV	Siddipet	06.00	09.00	03.00		B/D Due to 11KV Wire cutting at Mandapally Village	-
2		Gonepally	Mandapally	11KV	Siddipet	13.30	15.00	01.30		B/D Due to 11KV Wire cutting at Mandapally Village	-
1	RR N	Mayurinagar	Mayurinagar	11KV	Kukatpally	04.30	05.35	01.05	EL&OL	11kv AB cable failed At mandram residency Mayurinagar	-
2		J D M -SS-4	Bhagylaxmi	11KV	Jeedimetla	05.16	06.30	01.14	OL	11kv Pin Insultor Failed at Bhagylaxmi	-
3		Bandamadaram	Srirangavaram	11KV	Medchal	06.10	07.40	01.30		11KV Jumper cut and replaced at Venkataiah Bavi,Bandamadaram	-
4		Athiwelly	Somaram	11KV	Medchal	10.45	13.40	02.55		11KV Pin Insulator near PHI Company	-
1	HYD N	Marredpally	Nehru Nagar	11KV	sec-bad	14.30	17.05	02.35	EL	HT Conductor snapped at Sweet House	-