

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		1		1		1			
6	RR(E)	38	360									
7	Hyd	186	1014		2		2		2			
	Total	504	2929	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		5		5		5			
3	MDK	87	828	2		2		2				
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	2	5	2	5	2	5	0	0	
	Grand Total	908	6149	2	8	2	8	2	8	0	0	

TSSPDCL - LMRC / Corporate office

Date: 10.12.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Duddeda	Bandaram	33KV	Siddipet	09.50	11.10	01.20		B/D due to lighting arrester failed at Bandaram 33/11KV SS	Bandaram	-
2		Gummadidala	Jinnaram	33KV	Sangareddy	19:48 (09.12.2017)	21:35 (09.12.2017)	01.47		B/D due to Pole Damaged	Jinnaram	-

TSSPDCL - LMRC / Corporate office

Date: 10.12.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Thungathurthi	Banda Ramaram	11KV	Suryapet	07.20	09.00	01.40	EL	Bird Fallen on the 11KV Line	-
2		Mukundapuram	Somaram	11KV	Huzurnagar	04.00	10.44	06.44	EL/OL	11KV Line Jumper Cut Near Somaram Village	-
3		Mukundapuram	Dacharam	11KV	Huzurnagar	07.00	15.50	08.50	EL	11KV Line Line Snaped & HT< Fault Near Dacharam Village	-
4		Gaddipally	Ponugodu	11KV	Huzurnagar	07.30	10.00	02.30	EL	11KV Line Snaped Near Ponugodu Village	-
5		Gaddipally	Medaram	11KV	Huzurnagar	00.10	07.30	07.20	EL	11KV Line Cut Medaram Village	-
1	RR N	UMCC	Crusher	11KV	Medchal	05.15	05.45	00.30		11KV Pole Damaged at kaiser Nagar(11KV Jumper Opened)	-
1	HYD S	Kandikalgate	Indira Nagar	11KV	III	07.20	08.40	01.20	EL,OL	2No. HT Jumpers cut at Zeeshan Hotel, Al Jable Colony	At 7.40 hrs Partial feeder charged after opening line AB Switch (60%)
1	HYD C	Durga Nagar	Prem Nagar	11KV	II	16.30	18.10	01.40	EL	LT conductor snapped at STP Water Plant, Prem Nagar	-