

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		2		2		2			
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014		3		3		3			
	Total	504	2929	0	6	0	6	0	6	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	1	2	1	2	1	2			
2	NLG	150	948		1		1		1			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	1	3	1	3	1	3	0	0	
	Grand Total	908	6149	1	9	1	9	1	9	0	0	

TSSPDCL - LMRC / Corporate office

Date: 12.12.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Koukuntla	Muchinthalla	11kv	Mahabubnagar	10.00	13.55	03.55		11KV Conductor cut Near Muchinthalla (Vi)	-
2		Pomal	Pomal	11kv	Jadcherla	09.30	14.30	05.00		11KV Wire Cut Near Puttonipally Tanda Side.	-
1	NLG	Penpahad	Dubbathanda	11kv	Suryapet	06.50	10.00	03.10	EL	Jumper cut	-
1	RR N	Uddamarry	Usharpally	11kv	Medchal	15.15	16.45	01.30		11KV Pole Damaged and replaced at Uddamarry (V)	-
2		Dp pally	Bowrampet	11kv	Jeedimetla	15.32	16.32	01.00	EL	HT /Lt Line touched 11kv line At Bowrampet	-
1	RR E	Keesara	Anki Reddy Pally	11kv	Keesara	09.20	10.20	01.00		Line patrolling but no visible fault	-
1	HYD C	Nampally	FAPCCI	11kv	Mehdipatnam	10.07	11.23	01.16	EL,OL	Cable fault at FAPCCI Building	10:43 Hrs Opened AB Switch, partial feeder charged (50%)
2		Osm. University	Boudha Nagar	11kv	Azamabad	10.10	13.21	03.11	EL	Cable fault at SS	13:15 Hrs Arranged partial loads on 11KV Medibavi fdr & 13:21Hrs remaining partial loads added on 11KV Jamai Osmania feeder
3	HYD N	Osm. University	Mettuguda	11kv	Sec'bad	12.15	13.25	01.10	OL-Yph	Jumper cut near Osm. University SS	-----

TSSPDCL - LMRC / Corporate office

Date: 12.12.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Marikal	Koukuntla	33kv	Mahabubnagar	16.45	17.50	01.05	E/L	Pin Insulater Damaged Near Marikal	Koukuntla	-