

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		3		3		3			
6	RR(E)	38	360									
7	Hyd	186	1014		1		1		1			
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	1	1	1	1	1	1			
2	NLG	150	948		4		4		4			
3	MDK	87	828	1		1		1				
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>2</b>	<b>5</b>	<b>2</b>	<b>5</b>	<b>2</b>	<b>5</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>2</b>	<b>9</b>	<b>2</b>	<b>9</b>	<b>2</b>	<b>9</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 13.12.17

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Maddur	Kothapally	33KV	Mahabubnagar	15:55	17:55	02:00	O/L	33KV Line cut near Nidjinta Village	Kothapally	No
1	MDK	Narayankhed	Poosalpad	33KV	Jogipet	16:55	18:45	1:50		B/D Due to CT blast Jumper cut	Poosalpad	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Sanginonipally	Ankilla	11KV	Mahabubnagar	07.00	09.30	02.30		11KV Phase to Phase at Ubbal Thanda (V)	No
1	NLG	Raghunadapalem	Raghunadapalem	11KV	Huzurnagar	9:10	10:30	1:20	EL	11KV Insulator failed	No
2		Janpahad	Janpahad	11KV	Huzurnagar	08.50	12.15	03.25	EL	11KV Jumper cut	No
3		Nelamarri	Venkatrampuram	11KV	Huzurnagar	08.40	12.00	03.20	EL	11KV Jumper cut	No
4		Katangur	Mallaram	11KV	Nalgonda	06.00	08.30	02.30	EL	Jumper cut	No
1	RR N	Madinaguda	B k Enclave	11KV	Kukatpally	7:10	7:53	0:43	EL&OL	A Bird fallen on the 11kv line at B.K Enclave	No
2		Suraram	Sri ram nagar	11KV	Jeedimetla	07.56	08.56	01.00	EL	11KV Pin insulator failed at Diksha School Sriramnagar	No
3		Yellampet	IDA	11KV	Medchal	15.20	16.50	01.30	BD	11KV Pole damaged at DRS Company Yellampet	No
1	HYD N	Clock Tower	Railway Reservation	11KV	Secunderabad	23.30	00.40	01.10	EL,OL-Bph	Cable fault	Arranged B/F on 11KV Rezimental Bazar fdr