

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		2		2		2			
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014		1		1		1			
	Total	504	2929	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		5		5		5			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	0	5	0	5	0	5	0	0	
	Grand Total	908	6149	0	9	0	9	0	9	0	0	

TSSPDCL - LMRC / Corporate office

Date: 15.12.17

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Yerkaram	Dasthanda	11KV	Suryapet	13:30	15:30	2:00	EL	Jumper cut	No
2		Munagala	Bharakathgudem	11KV	Huzurnagar	04.20	08.15	03.55	EL	11KV Line snapped at Bharakathgudem village	No
3		Bethavolu	J P Gudem	11KV	Huzurnagar	02.00	07.50	05.50	EL	Single phase Transformer failed at J.P Gudem village	No
4		Burugadda	Burugadda	11KV	Huzurnagar	09.15	10.35	01.20	EL	11KV Line snapped at Burugadda village	No
5		Gaddipally	Medaram	11KV	Huzurnagar	3:00	7:50	4:50	EL	11KV Jumper cut at Pathepuram village	No
1	RR N	Jeedimetla SS - II	Phase-III	11KV	Jeedimetla	12:09	13:10	1:01		11KV Kompally Pharma feeder outgoing Jumper cut & End Kit failed in Sub Station	No
2		Jeedimetla SS - II	Kompally Pharma	11KV	Jeedimetla	12.09	13.10	01.01		11KV Kompally Pharma feeder outgoing Jumper cut & End Kit failed in Sub Station	No
1	RR E	IDA uppal	Airtel	11KV	Habsiguda	18:50	20:23	1:33	EL OL	Cable damaged at SS out side	No
1	HYD C	Indira Park	Gulshan Nagar	11KV	Saifabad	20.40	22.10	01.30	OL-Rph	2Nos HT Jumpers cut at SBI, Gandhi Nagar	No