

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407	2	1	2	1	2	1			
6	RR(E)	38	360									
7	Hyd	186	1014		1		1		1			
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>2</b>	<b>2</b>	<b>2</b>	<b>2</b>	<b>2</b>	<b>2</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		1		1		1			
3	MDK	87	828	1		1		1				
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>3</b>	<b>3</b>	<b>3</b>	<b>3</b>	<b>3</b>	<b>3</b>	<b>0</b>	<b>0</b>	

## TSSPDCL - LMRC / Corporate office

Date: 19.12.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Nuthankal	Yelkapally	11kv	Suryapet	15.15	17.00	01.45	E/L	Tree Branch fallen	-
1	RR N	Medchal	Victory	11kv	MDCL	21.35	22.35	01.00	BD	11KV Line cut and replaced at Sumangali Aluminium Company	-
1	HYD S	Kandikal Gate	Patel Nagar	11kv	Charminar	15.50	17.10	01.20	EL	AB Cable fault at GNR House	

TSSPDCL - LMRC / Corporate office

Date: 19.12.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Songoor	Mudaipet	33kv	Jogipet	15.10	18.15	03.05		B/d due to conductor sanpped near kodur (V)	Mudaipet	-
1	RR N	Medchal	Medchal	33kv	Medchal	01.45	02.10	00.25	BD	33KV Jumper Cut at Outer Ring Road ( Backfeeding arranged from 33KV Medchal-II )	Medchal	-
2		Bollaram	Kukatpally	33kv	Kukatpally	18.05	19.45	01.40	BD	tree branches fallon on the 33KV line at HMT colony	Kukatpally	-