

TSSPDCL - LMRC / Corporate office

Date: 20.12.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Palakaveedu	Bothalapalem	11kv	Huzurnagar	07.15	09.00	01.45	E/L	11kv jumper cut near Bothalapalem (v)	-
2		Mattampally	Allipuram	11kv	Huzurnagar	09.00	11.00	02.00	EL/OL	11kv line Cut near Allipuram (v)	-
3		Bethavolu	Bethavolu	11kv	Huzurnagar	11.30	13.00	01.30	EL/OL	11kv jumper cut near Bethavolu (v)	-
4		Velugupally	Pasnoor	11kv	Suryapet	04.00	06.30	02.30	E/L	11Kv Jumper cut	-
1	MDK	SRD-T-I	Thallapally	11kv	Sangareddy	04.25	15.10	10.45		B/D due to conductor snaped Vykuntapuram back side	-
1	RR S	APPA	Himayathsagar	11kv	RJNR	05.30	07.10	01.40	B/D	Coconut brancehes fallen on 11KV line at Danbasco School	-
2		Rajendranagar	Jalalbabanagar	11kv	RJNR	12.40	14.10	01.30	B/D	CT PT fault at Zoological HT Service	-

TSSPDCL - LMRC / Corporate office

Date: 20.12.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBN				NIL							-
2	NLG				NIL							-
3	MDK				NIL							-
4	RR S				NIL							-
5	RR N				NIL							-
6	RR E				NIL							-
7	HYD N				NIL							-
8	HYD S				NIL							-
9	HYD C				NIL							-

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		2		2		2			
5	RR(N)	82	407									
6	RR(E)	38	360									
7	Hyd	186	1014									
	Total	504	2929	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		4		4		4			
3	MDK	87	828		1		1		1			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	0	5	0	5	0	5	0	0	
	Grand Total	908	6149	0	7	0	7	0	7	0	0	