

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407									
6	RR(E)	38	360									
7	Hyd	186	1014									
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	2	1	2	1	2	1			
2	NLG	150	948		2		2		2			
3	MDK	87	828	1	1	1	1	1	1			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>3</b>	<b>4</b>	<b>3</b>	<b>4</b>	<b>3</b>	<b>4</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>3</b>	<b>4</b>	<b>3</b>	<b>4</b>	<b>3</b>	<b>4</b>	<b>0</b>	<b>0</b>	

## TSSPDCL - LMRC / Corporate office

Date: 27.12.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Vepoor	Vepoor	11KV	Mahabubnagar	06.00	09.00	03.00		11KV Conductor cut at Vepoor (V)	-
1	NLG	Ghanapuram	G. B. Pally	11KV	Devarakonda	02.55	05.10	02.15	E/L	11Kv Jumper cut	-
2		Gundepuri	Pasthala	11KV	Suryapet	09.00	11.30	02.30	E/L	11Kv Jumper cut	-
1	MDK	Mallaram	Sikindlapur	11KV	Siddipet	08.40	10.46	02.06		11 KV wire cutting at Dargapally Road	-

TSSPDCL - LMRC / Corporate office

Date: 27.12.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Marikal	Devarkadra	33KV	Mahabubnagar	02.55	04.40	01.45	E/L	Flash over disc Failed	Devarkadra	-
2		Nagarkurnool	Bijinapally	33KV	Nagarkurnool	15.10	18.10	03.00		No Visible Fault	Bijinapally	-
1	MDK	Habshipur	Pothareddtpet	33KV	Siddipet	09.34	10.10	00.36		Disk fail	Pothareddtpet	-