

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		2		2		2			
6	RR(E)	38	360									
7	Hyd	186	1014		2		2		2			
	Total	504	2929	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		2		2		2			
3	MDK	87	828		2		2		2			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	0	4	0	4	0	4	0	0	
	Grand Total	908	6149	0	8	0	8	0	8	0	0	

TSSPDCL - LMRC / Corporate office

Date: 29.12.17

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Velugupally	Pasnoor	11KV	Suryapet	5:00	8:00	3:00	E/L	Jumper cut	No
2		Palakeedu	Bothalapalem	11KV	Huzurnagar	05.50	10.50	05.00	EL/OL	11KV Insulator failed at Bothalapalem village	No
1	MDK	NSF	Mombojipally	11KV	Medak	6:30	7:10	0:40		Insulator failed	No
2		Rajpally	Komutor	11KV	Medak	08.00	14.00	06.00		Insulator failed	No
1	RR N	Kompally	Jaibheri	11KV	MDCL	11:35	12:15	0:40		11KV Pin Insulator failed at Nuziveedu Company Backside	No
2		HMT	Ganesh Nagar	11KV	MDCL	13.50	14.25	00.35		11KV Cable failed at Yellamma Temple	No
1	HYD N	Madhapur	Ohri's	11KV	Jublee Hills	05.45	06.50	01.05	EL,OL	Pin insulator flashed over at NCC Building	No
2		Madhapur	Van-N-Burg	11KV	Jublee Hills	11:25	15:15	3:50	EL,OL-Rph	O/G Cable fault near SS	Arranged B/F on 11KV Infotech fdr