

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		1		1		1			
5	RR(N)	82	407									
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014		1		1		1			
	Total	504	2929	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948	1	2	1	2	1	2			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	1	2	1	2	1	2	0	0	
	Grand Total	908	6149	1	5	1	5	1	5	0	0	

TSSPDCL - LMRC / Corporate office

Date: 02.07.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Katangur	Mallaram	11kv	Suryapet	05.00	08.00	03.00	E/L	11Kv Insulator failed	-
2		Y.gutta	Saidapur	11kv	Bhongir	07.40	10.40	03.00	E/L	HT/LT	-
1	RR S	Bairamalguda	Adhikar nagar	11kv	CPT	14.30	16.10	01.40	EL/OL/BD	Indi kit failed and replaced work at Altaf nagar	-
1	RR E	TARAMATHIPET	INDUSTRIAL	11kv	SAROOR NAGAR	08.13	09.45	01.27	EL/OL	11KV DTR CAPPER PUTTI CUT AT SADDUPALLY	-
1	HYD C	Petlaburz	Chowk	11kv	Charminar	11.05	12.24	01.19	OL-Rph	Cable fault	Arranged B/F on 11KV Gulzar House feeder

TSSPDCL - LMRC / Corporate office

Date: 02.07.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	K.M.Pally	Chinthapally	33kv	Devarakonda	4:00	7:30	3:30	E/L	33kv jumper cut	Chinthapally	-