

## TSSPDCL - LMRC / Corporate office

Date: 03.07.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Aipoor	Mukkudu Devula Pally	11KV	Suryapet	10:30	13:55	3:25	E/L	Insulator failed	-
2		Narkatpally IE	Vanipakala	11KV	Nalgonda	5:00	7:45	2:45	E/L	11KV jumper cut	-
3		Ramannapet	Bogaram	11KV	Nalgonda	6:00	9:15	3:15	E/L	11KV line melting at Bogaram(V)	-
4		Ch Laxmapur	Ch.laxamapur	11KV	Bhongir	14:00	17:00	3:00	E/L	11KV Insulator failed	-
5		Athmakur	Raheemkhanpet	11KV	Bhongir	7:00	10:30	3:30	EL	11KV Jumper snapped P.R Pally	-
6		Y.Singaram	Y.Singaram	11KV	Huzurnagar	8:00	10:00	2:00	EL	11kv Jumper cut near Y.Singaram village	-
1	RR S	Gandham Guda	Hydharshakote	11KV	RJNR	19.42	21.33	01.51	B/D	11kv Insulator Failed at Ppadmasree Hills	-
2		NPA	Babulreddy nagar	11KV	RJNR	21.10	22.40	01.30	B/D	11kv Insulator Failed at Saibaba nagar	-
1	RR E	Fruit Market	Ganga hosptial	11KV	SRNr	05.42	07.10	01.28		DTR AB Switch jumper Cut Near Probhathi Nagar	-
1	HYD S	Osm. Hospital	Puthli Bowli	11KV	Begum Bazar	7:15	9:05	1:50	OL-R&Bph	5way RMU fault at Trivani Lodge & Faulty loads of 11KV Gowliguda fdr	-
2		Malakpet	Farhath Nagar	11KV	Asmangadh	14:20	16:30	2:10	EL,OL-Rph	Cable fault	Arranged B/F on 11KV Bibi Ka Alwa fdr
3		Malakpet	Dabeerpura	11KV	Asmangadh	19:40	21:00	1:20	OL-Rph	Tree branches fallen on Lines at MCH Office	-
4	HYD N	MLA Colony	Lotus Pond	11KV	Jubilee Hills	19:15	20:35	1:20	All Indication	Cable fault	Arranged B/F on 11KV K.B.R.Park fdr
5		Patigadda	Ranigunj	11KV	Erragadda	22:30	0:05	1:35	EL,OL-R&Bph	HT Line snapped at Stay In Hotel	-

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Name of 33 KV Feeder	Alternate Supply Arranged
1	MBNR	Wanaparthi	Revally	33kv	Wanaparthi	20.50	21.20	00.30	E/L&O/L	Due to Wind & Rain	Revally	-
2		Marikal	Eklaspur	33kv	Mahabubnagar	20.25	23.00	02.35	E/L	Pin Insulator Failed at Jinnaram(V)	Eklaspur	-
3		Nagarkurnool	Peddakothapally	33kv	Nagarkurnool	23.45	05.20	05.35	E/L	Due to Wind & Rain	Peddakothapally	-

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		2		2		2			
5	RR(N)	82	407									
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014		5		5		5			
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	3		3		3				
2	NLG	150	948		6		6		6			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>3</b>	<b>6</b>	<b>3</b>	<b>6</b>	<b>3</b>	<b>6</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>3</b>	<b>14</b>	<b>3</b>	<b>14</b>	<b>3</b>	<b>14</b>	<b>0</b>	<b>0</b>	