

TSSPDCL - LMRC / Corporate office

Date: 04.07.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Devarkadra	Gudibanda	11KV	Mahabubnagar	08.30	14.30	06.00		11KV Conductor cut Near Gopanpally (V)	-
2		Rajapur	Chennavelli	11KV	Jadcherla	13.40	15.50	02.10		HT/LT Near Kucherkal (V)	-
3		Marikal	Marikal	11KV	Jadcherla	13.50	15.40	01.50		11KV Insulator Failure Near Pullagiri Thanda	-
4		Bhoothpur	Bhoothpur Rural	11KV	Jadcherla	12.15	15.25	03.10		Tree Fallen On The 11KV Line Near Gopannapalli (V)	-
1	NLG	Amaravaram	Yathavakilla	11KV	Huzurnagar	22.30	06.00	07.30	EL	11 Kv line snapped at Yathavakilla village	-
2		Nadigudem	Krishnanagar	11KV	Huzurnagar	00.00	06.30	06.30	EL	11 jumper cut at Krishnanagar village	-
3		Mushampally	Muthyalammagudem	11KV	Nalgonda	00.30	06.00	05.30	E/L	11 KV Line Insulator Failed	-
4		Pullemla	Pullemla	11KV	Nalgonda	06.00	12.30	06.30	E/L	11 KV Line Insulator Failed	-
1	MDK	Kowdipally	Devulapally	11KV	Medak	13.35	15.35	02.00		B/D Due to Jumper cut	-
2		Chitkul	Chitkul	11KV	Medak	11.00	15.00	04.00		B/D Due to Jumper cut	-
3		Hathnoora	Lingapur	11KV	Medak	05.00	08.30	03.30		B/D Due to Conductor snapped	-
1	RR E	RFC	Umar Khan Guda	11KV	Saroornagar	18.20	21.20	03.00	EL/OL	DTR FAIL AT GGAND ICHERU	-
1	HYD S	Chanchalguda	Anand Nagar	11KV	Asmangadh	09.35	10.50	01.15	OL-Rph	Tree branches fallen on Lines at D-Light Café	-
2		Malaket	M.M.H	11KV	Asmangadh	12.52	14.02	01.10	All Indicaton	No Visible Fault	Arranged B/F on 11KV Azampura fdr

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407									
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014		2		2		2			
	Total	504	2929	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969		4		4		4			
2	NLG	150	948		4		4		4			
3	MDK	87	828		3		3		3			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	0	11	0	11	0	11	0	0	
	Grand Total	908	6149	0	14	0	14	0	14	0	0	