

TSSPDCL - LMRC / Corporate office

Date: 05.07.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Narayankhed	Poosalpad	33KV	Jogipet	20.35	24.00	03.25		Under Breakdown	Poosalpad	-
1	RR N	Gachibowli	III OH	33KV	Gachibowli	15.39	16.28	00.49	OL/EL	Tripped OLEL RY indication BD declared due to Tree branches faallen near HCU		-
2		Bollaram	KPHB	33KV	Gachibowli	18.05	20.23	02.18	OL EL	Tripped OLEL indication BD declared conductor snapped &endkit jumper cut Near 132KV Bollaram SS		-

TSSPDCL - LMRC / Corporate office

Date: 05.07.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Nakrekal	Chandampally	11KV	Suryapet	08.10	11.00	02.50	E/L	11Kv Insulator failed	-
2		Urmadla	Elikate	11KV	Nalgonda	08.00	09.50	01.50	E/L	11 KV Line Insulator Failed	-
3		Rajapet	Pamukunta	11KV	Bhongir	13.00	16.00	03.00	EL	11KV Jumper snapped at Pamukunta	-
4		Bondugula	Godumakunta	11KV	Bhongir	05.30	08.30	03.00	EL	11KV Jumper snapped Near DB	-
5		Padamatpally	Thurupally	11KV	Devarakonda	05.00	08.00	03.00	EL	Jumper Cut	-
6		K.M.Pally	P.A.Pally	11KV	Devarakonda	08.00	11.00	03.00	EL	Insuletor Failed	-
1	MDK	Thogita	H Ghanpur	11KV	Medak	02.00	08.40	06.40		B/D Due to Condcutor snapped	-
2		Nagapur	Thimmaipally	11KV	Medak	09.30	10.30	01.00		B/D Due to Jumpercut at Thimmaipally village	-
1	RR S	CBIT	Movietower	11KV	RJNR	11.02	12.40	01.38	B/D	Tree branches fallen on 11KV line at Treasure land	-
2		Champapet	Sairamnagar	11KV	CPT	07.45	08.35	00.50	OL	11KV Line snapped at Sairamangar Park	-
3		Nandanavanam	Lalitha Nagar	11KV	CPT	12.53	13.25	00.32	OL	Tree branaches fallen on 11KV line at Gayathri nagar	-
4		Vanasthalipuram	NGO'Scolony	11KV	CPT	01.00	01.40	00.40	EL/OL	Line petroling no fault	-
5		Almasguda	Nandhi Hills	11KV	CPT	07.55	09.20	01.25	EL	11KV Jumper cut at TSR Colony	-
1	RR N	Devarayamjal	Kottapet	11KV	Medchal	17.15	18.30	01.15		11KV Pin Insulator failed near Devarayamjal Village	-
2		J D M -SSI	Apiic	11KV	Kukatpally	06.10	07.00	00.50		11kv Endy Kit Failure At Lion Club Apiic colony	-
3		Bahadurapally	Indirammacolony	11KV	Kukatpally	05.30	06.18	00.48		T/f HG fuse Cut touched To channel At Bahadurapally	-
4		Mathrusrinagar	Mathrusrinagar	11KV	Gachibowli	15.10	16.40	01.30	EL & OL	11KV Disc Failure Near Plot No -524 At Mathrusrinagar.	-
1	RR E	NGRI	NGRI	11KV	Habsiguda	15.10	17.22	02.12		Incoming cable burn at NGRI compund	-

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		5		5		5			
5	RR(N)	82	407	2	4	2	4	2	4			
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014									
	Total	504	2929	2	10	2	10	2	10	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		6		6		6			
3	MDK	87	828	1	2	1	2	1	2			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	1	8	1	8	1	8	0	0	
	Grand Total	908	6149	3	18	3	18	3	18	0	0	