

TSSPDCL - LMRC / Corporate office

Date: 08.07.17

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Ghanpur	33KV	Mahabubnagar	00.08	15.15	15.07	E/L	Replacing Of Jumper R&B Phases from Breaker to Bus Isolator & B Phase Break Pad Clamp towards to bus Isolator and Damaged Cable Removed at 132KV Out Side Yard	Ghanpur	Alternate Supply Arranged to 33KV Old Power House at 2:00Hrs
2		Wanaparthy	Buddaram	33KV	Wanaparthy	00.35	05.45	05.10	E/L	Due to heavy rain no visible fault	Buddaram	No
3		Kalwakurthy	Tarnikal	33KV	Jadcherla	00.02	01.50	01.48	O/L	Tree branches fallen on the line near gundoor (V)	Tarnikal	No
1	NLG	Guntipally	Chandampeta	33KV	Devarakonda	4:00	7:00	3:00	EL	Jumper cut	Chandampeta	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	K.Molgara	K.Molgara	11KV	Jadcherla	06.30	09.30	03.00		11KV Phase To Phase Near Pathamolgara (V)	No
2		Annasagar	Annasagar	11KV	Jadcherla	02.20	07.30	05.10		11KV Phase to Phase Near Balavardhan Land Side Annasagar.	No
1	NLG	Mukundapuram	G.Kothapally	11KV	Suryapet	4:30	7:00	2:30	E/L	Disc failed	No
2		Jammigadda	Durajpally	11KV	Suryapet	08.50	10.40	01.50	E/L	Jumper cut	No
3		Palakeedu	Bothalapalem	11KV	Huzurnagar	10.10	14.30	04.30	E/L	11 KV Insulator failed at Bothalapalem village	No
4		Garidepally	Appannapet	11KV	Huzurnagar	12.25	16.30	04.00	E/L	11 KV line snapped at Abbireddy gudem village	No
5		Nandanam	Thukkapur	11KV	Bhongir	07.00	10.00	03.00	E/L	Bird fallen on the line	No
6		Bollepally	Jampally	11KV	Bhongir	23:00	2:00	3:00	E/L	Jumper cut	No
1	MDK	Narsapur	Narayanapur	11KV	Medak	5:00	9:40	4:40		11 KV Conductor snapped at Naryanpur village	No
2		Chippalthruthy	Jakkapally	11KV	Medak	11.00	15.00	04.00		11 KV Jumper Cut at Jakkapally	No
3		Hathnoora	Hathnoora	11KV	Medak	02.00	07.00	05.00		11 KV Conductor snapped Hathnoora village	No
4		Hathnoora	Govindrajpally	11KV	Medak	05.00	09.00	04.00		Tree Branches fallen on the line.	No
1	RR N	Nanakramguda	Gowlidoddi	11KV	Gachibowli	1:28	2:56	1:28		11KV AB Cable failed At SBI Bank Backside.	No
2		Gachibowli	Kothaguda	11KV	Gachibowli	00.30	02.00	01.30		No visible fault	No
3		Suraram	Matrix	11KV	Kukatpally	00.30	02.00	01.30		No visible fault	No
4		Laxmapur	Laxmapur	11KV	Medchal	17.30	19.10	01.40		11 KV Pin Insulator failed at Laxmapur Village	No
1	RR E	Malkajiri	IN Nagar	11KV	Sainikpuri	2:35	3:22	0:47		11KV UG Cable failed at Goutham Nagar	No
1	HYD N	Yousufguda	Gayatri Hills	11KV	Banjarahills	00.02	03.20	03.18	EL	Cable End Kit failed at Konda Surekha House	No
2		Toli Chowki	Hanuman Temple	11KV	Banjarahills	1:01	2:35	1:34	EL	2No. Pin Insulators & 1No. Post type Insulator flashed over at Gulmohar Apts	No
3		Gymkhana	Vayu Sena	11KV	Sec'bad	11:10	12:31	1:21	EL,OL-Rph	I/C Jumper & Brass Patti cut at Vayusena	No
1	HYD S	Miralam	Hasan Nagar	11KV	Charminar	01.45	03.45	02.00	EL,OL	HT Line snapped near Miralam Tank	No

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		4		4		4			
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014		4		4		4			
	Total	504	2929	0	9	0	9	0	9	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	3	2	3	2	3	2			
2	NLG	150	948	1	6	1	6	1	6			
3	MDK	87	828		4		4		4			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	4	12	4	12	4	12	0	0	
	Grand Total	908	6149	4	21	4	21	4	21	0	0	