

TSSPDCL - LMRC / Corporate office

Date: 09.07.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	K.Molgara	Elkicherla	11KV	Jadcherla	06.30	09.30	03.00		11KV Jumper Cut NearRamreddyBavi Side.	-
1	NLG	Palakeedu	G G palem	11KV	Huzurnagar	9:10	11:10	2:00		11 kv line tapping at Gudugntlapalem village	-
2		Akupamula	Singaram	11KV	Huzurnagar	8:30	10:45	2:15		11 Disk failed at Singaram village	-
3		Gondiryala	Kothagudem	11KV	Huzurnagar	8:30	11:55	3:25		11 kv line snapped at Kothagudem village	
4		Mamillagudem	Mothey	11KV	Huzurnagar	7:20	11:20	4:00		11 kv line snapped at Mothey village	
5		Yerkaram	Ramannagudem	11KV	Suryapet	7:55	11:10	3:15		11Kv Line cut	
6		Kandagatla	Guttakinda	11KV	Suryapet	11:40	13:30	1:50		11Kv Line cut	-
7		Kethepally	Kasanagodu	11KV	Suryapet	7:00	8:30	1:30		11Kv Jumper cut	-
8		Nakalapally	Nakalapally	11KV	Nalgonda	9:00	13:00	4:00		11KV Line Insetera Fillare	-
9		Mamidala	Mamidala	11KV	Nalgonda	8:00	9:30	1:30		11 Kv Line jumpper Cutting	-
1	RR S	NPA	Babulreddy Nagar	11KV	RJNR	19.45	21.35	01.50		11kv Jumper cut Touching To Channel and insulator Failed at MS plastic Company ,madras plastic CTBT jumper cut and 11kv Line AB switch Jumper cut at Saibaba nagar	-
1	RR N	ChandaNagar	Madinaguda	11KV	GCB	09.15	11.30	02.15	BD	Madinaguda feeder cable failed near Sub-Station	-
2		ChandaNagar	Rail Vihar	11KV	GCB	09.15	10.15	01.00	BD	Due to Madinaguda feeder cable failed and touched to Rail Vihar feeder cable.(Railvihar feeder cable sparked)	-
3		ChandaNagar	Engineers Enclave	11KV	GCB	18.30	19.55	01.25	BD	11kv Disk failed near Falsa bar, Engineers Enclave	
4		Gachibowli	Nallagandla	11KV	GCB	16.03	17.23	01.20	BD	Due to heavy wind and rain(Line petrolling, No visible fault found)	
5		J D M-II	Phase-V	11KV	KKP	21.52	22.55	01.03	BD	11kv AB Cable Failure At Akonitech Company Near Sub -Station	
6		Chintal	Ganesh Nagar	11KV	Medchal	12.05	14.15	02.10	BD	11KV UG cable Failed at Ganesh Nagar	
7		Laxmapur	MC Pally	11KV	Medchal	10.00	11.30	01.30	BD	11KV Pin Insulator Failed at Mallikarjun Poultry farm,MC Pally	
8		Subash Nagar	Bank colony	11KV	Medchal	12.45	13.25	00.40	BD	Lizared fallen on the 11KV Line at Bank Colony	-
9		Medchal	Rural Medchal	11KV	Medchal	15.55	16.40	00.45	BD	Tree fallen on the 11KV Line at Ganga Kaveri Seeds Company	-
10		Kandlakoya	Saigeetha Asramam	11KV	Medchal	16.50	19.10	02.20	BD	Tree fallen on the 11KV Line near Kandlakoya	-
1	RR E	ABDULLAPERMET	ANAJPER	11KV	SAROOR NAGAR	18.00	19.15	01.15		11KV JUPER CUT AT ANAJPER	-
1	HYD S	Attapur	Shareef Nagar	11KV	III	15.25	18.40	03.15	EL	HT Cable failed & HT Insulator failed at Shareef Nagar	-----
2		Hyderguda	W.S.Colony	11KV	III	14.50	17.30	02.40	EL,OL	Cable fault	Arranged B/F on 11KV N.M.Guda OH fdr & 11KV Jana Priya OH & Cable fdrs

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Guntipally	Chandampet	33KV	Devarakonda	15:20	17:00	1:40	E/L	33Kv Insulator fauliure	Chandampet	-
1	MDK	Siddipet	Kamarlapally	33KV	Siddipet	02.45	07.45	05.00		B/D due to Insulator failed at Kamarlapally Village.	Kamarlapally	-

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		1		1		1			
5	RR(N)	82	407		10		10		10			
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014		2		2		2			
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>0</b>	<b>14</b>	<b>0</b>	<b>14</b>	<b>0</b>	<b>14</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969		1		1		1			
2	NLG	150	948	1	9	1	9	1	9			
3	MDK	87	828	1		1		1				
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>2</b>	<b>10</b>	<b>2</b>	<b>10</b>	<b>2</b>	<b>10</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>2</b>	<b>24</b>	<b>2</b>	<b>24</b>	<b>2</b>	<b>24</b>	<b>0</b>	<b>0</b>	