

TSSPDCL - LMRC / Corporate office

Date: 10.07.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Narayankhed	poosalpad	33KV	Jogipet	14.10	18.45	04.35		B/D Due to Conductor snapped and Jumper Cut		-
2		Habsipur	Raghothampally	33KV	Siddipet	06.30	09.30	03.00		B/D Due to Insulator failure		-

TSSPDCL - LMRC / Corporate office

Date: 10.07.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Peddakadmoor	Nagal Kadmoor	11KV	Mahabubnagar	16.30	19.30	03.00		11KV Insulator Damage at Nagal Kadmoor (V)	-
2		Kaverammamet	Town	11KV	Jadcherla	03.30	04.30	01.00		11KV Poledamaged at Bandamedipally (V)	-
1	NLG	Jalalpuram	Jalalpuram	11KV	Suryapet	13.15	14.20	01.05	E/L	Insulator failed	-
2		Nandanam	Thukkapur	11KV	Bhongir	13.00	15.00	02.00	EL	11KV Jumper snapped at 3 ph DTR	-
3		Kondamadugu	Kondamadugu	11KV	Bhongir	10.45	12.45	02.00	EL	11KV Line snapped near Kondamadugu	-
4		Garidepally	Kalmalchervu	11KV	Huzurnagar	09.40	11.30	01.50	EL	Due to 11Kv line cut near Kalmalchervu village	-
1	MDK	Kistareddypet	Patelguda	11KV	Sangareddy	05.00	11.00	06.00		B/D Due to Insulator failure at Patelguda	-
2		Kondapur	Kondapur	11KV	Sangareddy	07.35	10.00	02.25		B/D Due to Conductor snapped at Kondapur	-
3		Malkapur	Mallepally	11KV	Sangareddy	02.00	05.00	03.00		B/D Due to Jumper Cut at Gunthapally	-
4		B.B.Pur	Burugupally	11KV	Medak	14.40	15.50	01.10		B/D Due to Jumper Cut	-
1	RR S	Ibraheembagh	Military II	11KV	RJNR	03.11	04.04	00.53		Bird fallen 11 KV line at Fathima Majid	-
1	RR N	Nanakramguda	TNGO's Colony	11KV	Gachibowli	06.01	07.01	01.00		LABS Opend at Alay Baly X road	-
2		Jeedimetla SS I	Raghava	11KV	Kukatpally	04.00	06.10	02.10		11kv jumper cut at SS Yard & A B Cable failure near Vidyut Company	-
3		Jeedimetla SS III	Vinayaka Nagar	11KV	Kukatpally	05.20	07.20	02.00		11kv jumper cut at Auto Stand	-
4		Athiwelly	Somaram	11KV	Medchal	12.55	13.35	00.40		Tree Branch fallen on the 11KV Line at Yallampet Chowrasta	-
5		Medicity	IDA-I	11KV	Medchal	14.48	15.20	00.32		11KV Pole Damaged by Car at Pudur Village	-
1	RR E	Fruitmarket	Phinigiri Colony	11KV	Saroor Nagar	06.00	07.07	01.07	OL	11KV LINE PATROLLING NO FALT	-
2		Fruitmarket	Jainmandir	11KV	Saroor Nagar	19.03	17.12	01.09	OL	11KV LINE PATROLLING NO FALT	-
3		Abdullapurmet	Anajper	11KV	Saroor Nagar	17.00	18.00	01.00	EL	TREE BRCHANS FALLOW ON 11KV LINE AT KANKA DURGA COLONY	-
1	HYD N	Lalaguda	Chenna Reddy	11KV	Sec-bad	19.20	21.10	01.50	EL	Pin Insulator flash over at Aditya Super Market	-

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		1		1		1			
5	RR(N)	82	407		5		5		5			
6	RR(E)	38	360		3		3		3			
7	Hyd	186	1014		1		1		1			
	Total	504	2929	0	10	0	10	0	10	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969		2		2		2			
2	NLG	150	948		4		4		4			
3	MDK	87	828	2	4	2	4	2	4			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	2	10	2	10	2	10	0	0	
	Grand Total	908	6149	2	20	2	20	2	20	0	0	