

TSSPDCL - LMRC / Corporate office

Date: 12.07.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Kodangal	Hamsanpally	33KV	Rural	18.00	21.25	03.25	E/L	Breaker Problem & R Phase LA Failed & Disconnect the LA & Line Charged on Peddanandigama	Kodangal	-
2		Polepally	Gangapur	33KV	Jadcherla	22.45	23.24	00.39	E/L	Due to Rain	Polepally	-
1	MDK	Habsipur	Raghothampally	33KV	Siddipet	15.15	15.55	00.40		B/D Due to Pin Insulater Replaced at Boppapur SS	Habsipur	-
2		Habsipur	Pedda Chikoti	33KV	Siddipet	15.45	16.50	01.05		B/D Due to Tree Branches fallen on line at Potharm bus stand	Habsipur	-
1	RR N	LGM Pet	LGM Pet	33KV	Medchal	18.45	21.43	02.58	BD	Tree fallon on the 33KV line at Bharath Bio-Tech, Thurkaplly	LGM Pet	-
1	HYD S	220KV Shi.Pally	Miralam UG	33KV	Malakpet	13.13	13.23	00.10	EL,OL-Bph	Under Breakdown	220KV Shi.Pally	Loads transferred onto 33KV Shi.Pally - Ch' Baradari line

TSSPDCL - LMRC / Corporate office

Date: 12.07.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Dirsincherla	Dirsincherla	11KV	Huzurnagar	13.15	15.30	02.15	EL	AB Switch fault near Dirsincherla village	-
2		Padmatipally	Iddampally	11KV	Devarakona	07.35	11.00	03.25	EL	Insulator Failure	-
3		Sharajipet	Kollur	11KV	Bhongir	02.00	05.00	03.00	EL	3 Ph DTR Jumper snapped near Kollur	-
4		Raghunathpur	Raghunathpur	11KV	Bhongir	07.00	10.00	03.00	EL	SS-24, Diskfailed Dharmareddy gudem	-
5		Edloor	Naregudem	11KV	Suryapet	14.30	16.10	01.40	E/L	ss-3 jumpur cut	-
6		Laxmapuram	Laxmapuram AGL	11KV	Nalgonda	05.00	08.00	03.00	E/L	Insulator Failure	-
1	MDK	Fasalwadi	Fasalwadi New	11KV	Medak	09.00	11.00	02.00		B/D Due to phase to phase at FasalwadiVg	-
1	RR S	Vikarabad	A.G.Gutta	11KV	Vikarabad	08.02	10.10	02.08	E/L	1 No.11 kv line Pin insolater fail	-
1	RR N	Bahadurpally	Laxmi Nagar	11KV	Kukatpally	05.50	07.40	01.50	BD	Mallanna Temple T/F line cut at Laxminagar	-
2		Kistapur	Kistapur	11KV	Medchal	16.30	17.05	00.35	BD	Lizared fallen on the 11KV Line at Archana colony,Medchal Road	-
1	RR E	Bandlaguda	Chanikyapuri	11KV	Sarooranagar	17.22	18.20	00.58	EL/OL	11KV Line touching at Lalatha nagar	-
2		Abdullapermet	Anajper	11KV	Sarooranagar	17.00	18.00	01.00	EL	Tree Breachs fallow on 11KV line at kanka durga colony	-
1	HYD N	Hakimpet	H.A.F.	11KV	Bowenpally	02.40	03.56	01.16	EL,OL-Bph	Jumper cut at Shivalayam	-

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		1		1		1			
5	RR(N)	82	407	1	2	1	2	1	2			
6	RR(E)	38	360		2		2		2			
7	Hyd	186	1014	1	1	1	1	1	1			
	Total	504	2929	2	6	2	6	2	6	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	2		2		2				
2	NLG	150	948		6		6		6			
3	MDK	87	828	2	1	2	1	2	1			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	4	7	4	7	4	7	0	0	
	Grand Total	908	6149	6	13	6	13	6	13	0	0	