

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407	1	10	1	10	1	10			
6	RR(E)	38	360									
7	Hyd	186	1014		2		2		2			
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>1</b>	<b>12</b>	<b>1</b>	<b>12</b>	<b>1</b>	<b>12</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	2		2		2				
2	NLG	150	948		15		15		15			
3	MDK	87	828		2		2		2			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>2</b>	<b>17</b>	<b>2</b>	<b>17</b>	<b>2</b>	<b>17</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>3</b>	<b>29</b>	<b>3</b>	<b>29</b>	<b>3</b>	<b>29</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 14.07.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparthy	Narsaipally	33KV	Wanaparthy	18.03	18.30	00.27	E/L	Due to Heavy Gale & Rain & Feeder Tag on to 132KV Singotam SS	Narsaipally	Alternate Supply Arranged from 132KV Singotam SS at 18:30Hrs
2		Alampur	Shanthinagar -1	33KV	Gadwal	18.30	20.03	01.33	E/L	for Jumper open at Ramapuram Due to Heavy Rain	Shanthinagar -1	-
1	RR N	Madhapur	SLN Terminus	Gachibowli	33KV	01.55	07.40	05.45	BD	33kv Cable-II endkit failure at water mark	Gachibowli	-

TSSPDCL - LMRC / Corporate office

Date: 14.07.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Angadipet	Papally(Rural)	11KV	Devarakonda	04.00	07.00	03.00	E/L	11kv jumper cut	-
2		Reddygudem	Reddygudem	11KV	Suryapet	04.40	08.00	03.20	E/L	11Kv Pin Insulator Failed	-
3		Dirsincherla	Yellapuram	11KV	Huzurnagar	04.00	07.00	03.00	O/L	11Kv Disk failure near Yellapuram village	-
4		Alingapuram	Gundlapahad	11KV	Huzurnagar	07.00	10.00	03.00	E/L	11Kv Jumper cut near Gundlapahad village	-
5		Mattampally	Choutupally	11KV	Huzurnagar	02.50	06.00	03.10	EL/OL	11kv line cutted near Choutupally village	-
6		Mattampally	Allipuram	11KV	Huzurnagar	04.00	07.00	03.00	EL/OL	11Kv Disk failure near Allipuram village	-
7		Raghunadapalem	Raghunadapalem	11KV	Huzurnagar	06.10	07.30	01.20	E/L	11Kv Jumper cut near Raghunadapalem village	-
8		Mamillagudem	Mothey Agl	11KV	Huzurnagar	08.10	10.43	02.33	E/L	11Kv Jumper cut near Mothey agl village	-
9		Timmareddy gudem	Timmareddy gudem	11KV	Huzurnagar	02.05	06.00	03.55	E/L	11Kv Insulator failure near Timmareddy gudem (v)	-
10		Keetavarigudem	Kothagudem	11KV	Huzurnagar	06.00	09.10	03.10	E/L	11Kv Disk failure near Kothagudem village	-
11		Narketpally IE	Vattimarthy	11KV	Nalgonda	23.00	00.00	01.00	E/L	11KV Line Jumper Cut	-
12		Addagudur	Addaguduru	11KV	Bhongir	06.00	09.30	03.30	E/L	11KV Line snapped at SS-10	-
13		Motakondur	Cholleru	11KV	Bhongir	02.00	05.00	03.00	E/L	11Kv Jumper snapped at Mahoobpet	-
14		Anathram	Hanumapur	11KV	Bhongir	02.45	06.00	03.15	E/L	11KV Line snapped at SS-10	-
15		Addagudur	Ch.Ramaram	11KV	Bhongir	23.00	02.00	03.00	E/L	11KV Diskfailed at Ch.ramaram	-
1	MDK	NSF	Chityala	11KV	Medak	07.00	10.25	03.25		B/D Due to Jumper cut.	-
2		Hathnoora	Nawabpet	11KV	Medak	07.30	10.30	03.00		B/D Due to Insulator failure	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR N	Papireddy Colony	Prem Nagar	11KV	Gachibowli	02.30	03.55	01.25	EL	Kondapur 11KV Jumper's Opened near B' Block at Prem Nagar.	-
2		JNTU	SP Nagar	11KV	Gachibowli	00.45	02.20	01.35	EL	11KV Cable Fault Near Plot No 264 at SP Nagar.	-
3		JNTU	BS Nagar	11KV	Gachibowli	01.50	03.05	01.15	EL	AB Cable Fault Near Vasanth Nagar Society Office.	-
4		Nanakramguda	Manthri Developer's	11KV	Gachibowli	07.18	10.46	03.28	EL & OL	11KV HT Service UG Cable Failure In Sub-Station Yard.	-
5		Jeedimetla-III	Ramreddynagar	11KV	Kukatpally	00.15	03.00	02.45	BD	11kv line Endkit failure near DL Ice Company at Phase-V	-
6		Mayurinagar	Prashanthnagar	11KV	Kukatpally	17.35	19.30	01.55	BD	11kv line PinInsulater failure at Bhrundavan Colony	-
7		Aliabad	Ravileela	11KV	Medchal	23.45	03.20	03.35	BD	Tree fallen on the 11KV Line at LGM Pet Road	-
8		Devarayamjal	Kottapet	11KV	Medchal	00.40	01.40	01.00	BD	Tree Fallen on the 11KV Line at Radhika Garden, Devarayamjal	-
9		UMCC	Gajularamaram	11KV	Medchal	17.30	18.30	01.00	BD	11KV Pin Insulator Failed at Sriveni Enclave	-
10		Medchal	Housing Board	11KV	Medchal	20.30	21.10	00.40	BD	11KV PinInsulator Failed at Priyadharishini Hotel	-
1	HYD S	Salarjung	Salarjung Museum	11KV	III	13.12	15.10	01.58	All Indication	CT PT fault & O/G Cable fault at Salarjung Museum	-
1	HYD C	Erramanzil	I.C.Quarters	11KV	I	01.55	03.00	01.05	EL,OL	R.M.U fault	Arranged B/F on 11KV Erramanzil fdr