

## TSSPDCL - LMRC / Corporate office

Date: 17.07.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	G.T Giri	Bakthalapuram	11kv	Suryapet	4:00	7:30	3:30	E/L	11Kv Insulator failed	-
2		Athmakur(S)	Naseempet	11kv	Suryapet	6:05	9:30	3:25	E/L	11Kv Disk Failed	-
3		Padmatipally	Kandukur	11kv	Devarakonda	2:00	6:00	4:00	E/L	11Kv Disc insulator failure Near Kandukur	-
4		Nampally	Nampally(Town)	11kv	Devarakonda	13:50	16:45	2:55	E/L	11KV Jumper cutting	-
5		Garidepally	L B Nagar	11kv	Huzurnagar	0:30	3:00	2:30	E/L	11kv line Snapped near L B Nagar village	-
6		Gaddipally	Ponugodu	11kv	Huzurnagar	10:30	13:00	2:30	E/L	11Kv Insulator failure near Ponugodu Agl village	-
7		Janpahad	Janpahad	11kv	Huzurnagar	3:00	5:00	2:00	E/L	11Kv Insulator failure near Janpahad Agl village	-
8		Thogarrai	Kapugallu	11kv	Huzurnagar	13:43	15:32	1:49	E/L	11Kv Insulator failure near Kapugallu village	-
9		Ravipahad	Burkacherla	11kv	Huzurnagar	2:00	4:00	2:00	E/L	11 Kv Jumper cut near Burkacherla village	-
10		Timmareddy gudem	Timmareddy gudem	11kv	Huzurnagar	1:00	3:30	2:30	E/L	33Kv Disk and insulator failure near Timmareddy gudem village	-
11		Kandibanda	Gandi nagar thanda	11kv	Huzurnagar	2:00	4:45	2:45	E/L	11 Kv Jumper cut near Gandi nagar thanda village	-
12		Mattampally	Pedaveedu	11kv	Huzurnagar	11:30	14:00	2:30	E/L	11Kv Line Cut near Pedaveedu village	-
13		Chandur	Bodangiparthy	11kv	Nalgonda	13:00	14:40	1:40	E/L	11KV line cut	-
14		Ramannapeta	Bogaram	11kv	Nalgonda	12:00	14:30	2:30	E/L	11KV jumper cut	-
1	MDK	Danthanpally	Danthanpally	11kv	Toopran	18:00 (16.07.17)	10:00 (17.07.17)	16.00		B/d due to Insulator fail	-
2		Ramayanpet	Ramayanpet	11kv	Toopran	00.00	12.00	12.00		B/d due to Insulator fail	-
3		Ramayanpet	Damarachervu	11kv	Toopran	13.05	14.10	01.05		B/d due to Insulator fail	-
4		Ramayanpet	Venkatapur	11kv	Toopran	13.00	16.00	03.00		B/D due to Tree branches fallen on the line	-
5		Ramayanpet	Akkannapet	11kv	Toopran	14.30	15.35	01.05		B/D due to Jumper cut	-
6		Chatlapally	Chatlapally	11kv	Toopran	15.00	17.00	02.00		B/D due to Jumper cut	-
7		Bonala	Bonala	11kv	Toopran	13.00	17.00	04.00		B/D due to Jumper cut	-
1	RR S	RJNR	Suleman Nagar	11kv	RJNR	17.40	19.50	02.10		11 KV Insulator Failed at Kahja Hotal	-
1	RR N	Gachibowli	Mezquity	11kv	Gachibowli	14.30	16.35	02.05	BD	11KV Disc failed at Mezquity (Due To Rain)	-
2		Gachibowli	Sudharshan nagar	11kv	Gachibowli	14.45	16.35	01.50	BD	11KV Line twisted near SS	-
3		Chandanagar	Mythri Nagar	11kv	Gachibowli	17.05	19.00	01.55	BD	Tree Branch Fallen On 11Kv Line at Land mark Apts, Mythri Nagar	-
4		Madinaguda	Swaranapuri Colony	11kv	Kukatpally	09.37	10.20	00.43	BD	11kv AB Cable Failure At Krishana Sai Enclave	-
5		G Vikas	Volvo	11kv	Kukatpally	16.38	18.08	01.30	BD	11kv Pin Insultor Failure opp Volvo pravalika apt	-
6		Suraram	I D A Suraram	11kv	Kukatpally	16.32	18.18	01.46	BD	Tree Branches Fallen On the 11kv Line At Savera pipe Company	-
7		R G K Suraram	Suraram Vill	11kv	Kukatpally	17.20	19.20	02.00	BD	Tree Branches Fallen On the 11kv Line AT Suraram Village	-
8		Aleap	Doctor Colony Cable	11kv	Kukatpally	20.50	21.30	00.40	BD	Tree Branches Fallen On the 11kv Line AT PT No 83&94 Pragathinagar	-
9		Ushamullapudi	HAL Colony	11kv	Medchal	16.30	17.30	01.00	BD	11KV Pin insulator failed at Hanuman Temple	-
10		Aliabad	Ravileela	11kv	Medchal	07.10	10.10	03.00	BD	11KV Pin insulator failed at Yellempet Village	-
11		Aliabad	Ravileela	11kv	Medchal	14.40	17.30	02.50	BD	11KV Disc failed at Yellempet Bus stop	-
12		Laxmapur	Laxmapur	11kv	Medchal	08.00	10.30	02.30	BD	11KV Disc failed at Ramulagutta	-
13		Kandlakoya	Kandlakoya	11kv	Medchal	16.40	18.05	01.25	BD	11KV Pin insulator failed at Sutharguda	-
14		Kandlakoya	Sai Geetha	11kv	Medchal	17.30	18.45	01.15	BD	Tree branches fallon on the 11KV line at Rajarajeswari Temple	-
15		Medchal	Rural Medchal	11kv	Medchal	16.40	19.20	02.40	BD	11KV Pin insulator failed at Sutharguda	-

1	RR E	Narapally	Narapally Industrial	11kv	Medchal	18.20	19.15	00.55		11KV Pin Insulator failed near Revathi Rice Mill	-
2		Yadgarpally	Yadgarpally	11kv	Medchal	17.20	19.20	02.00		Insulator failed at Jai Bharath Industries	-
3		Chakripuram	Shilpa Nagar	11kv	Medchal	16.00	18.44	02.44		Line Patrolling but no fault	-
4		P&T Colony	Buddha Nagar	11kv	Medchal	15.44	16.30	00.46		Cloth fallen on 11KV Line at Buddha Nagar	-
5		Rampally Dayara	Karimguda	11kv	Medchal	17.10	20.15	03.05		Insulator failed at Outer Ring Road	-
6		Vasanthpuri	Durga Nagar Cable	11kv	Medchal	12.53	13.33	00.40		11Kv Post of Insuletor failure at SS Back Side (LM Anand)	-
7		NAGOLE	MAMATHA NAGAR	11kv	Saroornagar	15.49	16.49	01.00		11KV DISK FAIL AT MAMATHA NAGAR	-
8		MOHAN NAGAR	MOHAN NAGAR	11kv	Saroornagar	17.13	18.33	01.20		TREE BRCHANS FALLOW ON 11KV LINE AT MOHAN NAGAR	-
9		HAYATH NAGAR	LECTURERS COLONY	11kv	Saroornagar	14.40	15.40	01.00		IREN RADU FALLOW ON 11KV LINE AT LECTURERS COLONY	Arranged B/F on 11KV Jubilee Hills P.S feeder
1	HYD N	Jubilee Hills	Jubilee Hills	11kv	X	01.35	03.45	02.10	All Indication	Cable fault	Arranged B/F on 11KV Art Gallery fdr
2		Madhapur	Ohri's	11kv	X	08.45	09.51	01.06	EL,OL-Rph	Cable fault at Nector Garden	Arranged B/F on 11KV Shalivahana Nagar fdr
3		Yellareddyguda	Engineers Colony	11kv	X	15.44	17.40	01.56	All Indication	5No. DTR's fault	-----
4		MLA Colony	Cancer Hospital	11kv	X	16.40	18.30	01.50	All Indication	Line snapped at Namaste Telangana Office near TRS Bhavan	-----
5		Madhapur	APIIC-II	11kv	X	17.20	19.50	02.30	EL,OL-Rph	Tree branches fallen on Lines at Road No.2 & CT PT HG fuse B/O at Microsor Hospital & 2Nos Jumpers cut at HDFC Bank	-----
1	HYD S	Moosarambagh	S.B.I. Colony		VIII	16.10	19.30	03.20	EL	Cable fault	Arranged B/F on 11KV Moosaram Bagh feeder
2		Salarjung	Madina		III	16.42	18.15	01.33	EL	3No. Brass Patties B/O & Pin Insulator flash over at Madina	-----
3		C.R.P.F	Balapur		III	20.20	21.50	01.30	EL	Tree branches fallen on Lines at Balapur Turning DTR	-----
1	HYD C	Nizam College	Babu Khan Estate	11KV	I	13.44	15.04	01.20	EL	Cable fault at Deccan Towers	-----
2		Hussain Sagar	Gunfoundary	11KV	I	14.22	16.19	01.57	EL,OL-Rph	Faulty loads 11KV Nampally feeder	-----
3		Lumbini Park	Lumbini Park	11KV	I	15.40	23.01	07.21	All Indication	3Way R.M.U fault at Lumbini Park	-----
4		Bathkammakunta	Ahobilmutt	11KV	II	15.40	18.12	02.32	Without indication	Tree fallen on Lines at Hotel Management, Shivam Road	-----
5		Industrial Area	Mother Dairy	11KV	II	15.44	17.50	02.06	EL	Tree branches fallen on Lines at Mothers School	-----
6		Hussain Sagar	V.R.Colony	11KV	I	16.20	18.24	02.04	EL	AB Switch Insulator flash over & tree branches fallen on lines at Gandhi Tata Nagar	-----
7		Nizam College	S.B.N.Home	11KV	I	16.55	20.59	04.04	EL,OL	Cable fault	Arranged B/F on 11KV J.N. feeder
8		Nizam College	Big Bazar	11KV	I	16.55	19.20	02.25	EL,OL	Cable fault	Arranged B/F on 11KV Rosary Convent fdr
9		Nizam College	Rosary Convent	11KV	I	17.20	18.33	01.13	EL,OL	No Visible Fault	-----
10		Hussain Sagar	NTR Marg	11KV	I	22.39	00.23	01.44	All Indication	O/G AB Switch Bph Jumper cut at SS	-----

TSSPDCL - LMRC / Corporate office

Date: 17.07.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Kangal	Kopple	33kv	Devarakonda	13.00	17.00	04.00	E/L	33Kv Disk Failed	Kopple	-
1	RR N	LGM Pet	Aliabad.	33kv	Medchal	18.06	19.05	00.59	BD	33KV Pin Insulator failed at Aliabad	Aliabad.	-
2		RC Puram	Chanda Nagar	33kv	Kukatpally	16.45	19.30	02.45	BD	Due to Heavy rain and line Petriling no Visuable fount	Chanda Nagar	-
1	HYD C	132KV Erragadda	Hussain Sagar (HT Service)	33kv	Saifabad	20.35	00.00	03.25	OL-Rph	33KV Line snapped at Yousufguda Basti	Hussain Sagar (HT Service)	-

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		1		1		1			
5	RR(N)	82	407	2	15	2	15	2	15			
6	RR(E)	38	360		9		9		9			
7	Hyd	186	1014	1	18	1	18	1	18			
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>3</b>	<b>43</b>	<b>3</b>	<b>43</b>	<b>3</b>	<b>43</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948	1	14	1	14	1	14			
3	MDK	87	828		7		7		7			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>1</b>	<b>21</b>	<b>1</b>	<b>21</b>	<b>1</b>	<b>21</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>4</b>	<b>64</b>	<b>4</b>	<b>64</b>	<b>4</b>	<b>64</b>	<b>0</b>	<b>0</b>	