

TSSPDCL - LMRC / Corporate office

Date: 19.07.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Habsipur	Dubbaka	33KV	Siddipet	02.55	09.30	06.35		B/D due to Tree fallen on line & Conductor snapped	Habsipur	-
2		Siddipet	Narsapur	33KV	Siddipet	01.55	10.10	08.15		B/D due to Conductor snapped	Siddipet	-
3		Jogipet	Laxmisagar	33KV	Jogipet	00.00	10.40	10.40		B/D due to Insulator failed	Jogipet	-
4		Pashamailaram	EPIP	33KV	Sangareddy	13.00	15.20	02.20		B/D due to Jumper cut	Pashamailaram	-
1	RR S	R.C Puram	Shankarpally	33KV	RJNR	14.15	16.30	02.15		Neem tree fallen on 33KV line at Shankarpally		-

TSSPDCL - LMRC / Corporate office

Date: 19.07.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Nagaramgate	Koilsagar	11KV	Mahabubnagar	05.30	07.10	01.40		11KV Tree fallen on conductor Near Ajillapuram(V)	-
2		Dudyal	Hakeempet	11KV	Mahabubnagar	08.10	11.00	02.50		11KV Conductor cut at pulcherla Thanda (V)	-
3		Doultabad	Allapur	11KV	Mahabubnagar	02.30	05.00	02.30		11KV Insulator Damage Near Jeedimamidi (V)	-
4		Bijwar	Pulimamidi	11KV	Mahabubnagar	08.30	09.45	01.15		11KV Phase to Phase at Chinnaparla (V)	-
5		Karkonda	Kuchur	11KV	Mahabubnagar	10.00	13.25	03.25		11KV Phase to Phase at Doddy pally (V)	-
1	NLG	Chandur	Gundrepally	11KV	Nalgonda	03.00	10.00	07.00	E/L	11KV line cut at SS-28	-
2		Pole Centre	Buddaram	11KV	Nalgonda	01.20	06.30	05.10	E/L	11KV line melting at village end	-
3		Marriguda	Y.G.Pally	11KV	Devarakonda	03.00	07.15	04.15	E/L	Heavy Rain Problem	-
1	MDK	Mulugu	Mulugu	11KV	Tooparan	03.00	07.00	04.00		B/D due to Insulator failed	-
2		Shivampet	Sadaspally	11KV	Tooparan	10.10	13.40	03.30		B/D due to Jumper cut	-
3		Masaipet	Masaipet	11KV	Tooparan	15.30	17.00	01.30		B/D due to Jumper cut	-
4		Nizampur	Venkatapur	11KV	Sangareddy	11.10	16.50	05.40		B/D Due to 11KV conductor snapped at Rendlapally	-
1	RR S	Vanasthalipuram	Balajinagar	11KV	CPT	09.55	11.05	01.10	EL/BD	Pin insulator failed at FCI Colony	-
1	RR N	KPHB	KPHB	11KV	GCB	04.08	05.49	01.41	BD	11KV Pin Insulator Failed Near MIG-629 At KPHB.	-
2		L&T	PJR Nagar	11KV	GCB	05.10	06.34	01.24	BD	11KV Line AB Switch Jumper Cut and 11KV T/F Disc Failure at Telecom Nagar.	
3		ESCI	Nanakramguda	11KV	GCB	14.32	16.00	01.28	BD	11KV Line Melting and Rectified at Rai Durgam Police Station.	
4		IIIT	IVRCL	11KV	GCB	09.32	10.44	01.12	BD	11KV Line Patrolling. No Visible Fault.	
5		Mathrusrinagar	Srila	11KV	GCB	14.35	15.25	00.50	BD	Tree Branches Fallen On The 11KV Line at Calvary Temple.	
6		Mathrusrinagar	Durga Matha	11KV	GCB	14.40	15.35	00.55	BD	Due to Heavy Rain And Wind. No Visible Fault.	
7		Borabanda	Gayatri Nagar	11KV	GCB	14.35	16.08	01.33	BD	LT Lug Cut and Replacement at Vivekananda Nagar.	
8		Borabanda	Gayatri Nagar	11KV	GCB	16.28	17.34	01.06	BD	Tree Branches Fallen On The 11KV Line at Vivekananda Nagar.	
9		J D M Ss-III	U S P Organic	11KV	KKP	00.50	11.50	11.00	BD	11kv AB Cable Snapped At G V K Company	
10		J D M Ss-I	J E T EL	11KV	KKP	09.10	11.47	02.37	BD	11kv AB Cable failure At Svr Polymer Company	
11		Mayurinagar	Prashanth nagar	11KV	KKP	14.40	16.30	01.50	BD	11kv Pin Insulator At Padama Hospital	
12		J D M Ss-III	Pipe Line Road	11KV	KKP	00.50	08.45	07.55	BD	11kv Ab Cable Endy Kit Failure & Post Of Insulator Failure In Sub Station	
13		J D M Ss-III	U S P Organic	11KV	KKP	11.45	13.15	01.30	BD	11kv Conductor Snapped At U S P Organic Company	
14		Kolthur	Anantharam	11KV	MEDCL	05.45	07.15	01.30	BD	11KV Pin Insulator failed at Anantharam Village	
15		Gowdavelly	Ayodhya	11KV	MEDCL	06.30	07.55	01.25	BD	Tree Fallen on the 11KV Line at Medchal Road	
16		Subash Nagar	Ramaraj Nagar	11KV	MEDCL	15.10	16.20	01.10	BD	11KV Pin Insulator failed at Vigneshwara Apartment	
17		Dulapally	IDA-II	11KV	MEDCL	14.48	16.10	01.22	BD	Bird fallen on the 11KV Line IDA Dulapally	
18		Athiwelly	Athiwelly	11KV	MEDCL	15.40	17.10	01.30	BD	11KV Pin Insulator failed at Hitech School, Athiwelly	-
19		GP Pally	Neighbourhood	11KV	MEDCL	15.40	17.30	01.50	BD	11KV Pin Insulator failed at Lakshmi Nagar	-
20		GP Pally	GP Pally	11KV	MEDCL	14.50	16.30	01.40	BD	No Fault	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
21		GP Pally	Malla Reddy	11KV	MEDCL	15.35	18.45	03.10	BD	11KV Conductor Snapped at Mallareddy College	-
22		Gowdavelly	Ayodhya	11KV	MEDCL	15.30	17.00	01.30	BD	15KVA T/F failed at Hanmanthreddy Thota,Ayodhaya	-
1	RR E	VP Nagar	RK Puram	11KV	Sainikpuri	15.25	15.55	00.30		Tree branches fallen on 11Kv line at VP Nagar Water Tank (AE/OP/Neredmet)	-
2		Anandbagh	NMDC	11KV	Sainikpuri	14.50	15.20	00.30		Tree branches fallen on 11Kv line at Shirdi Nagar East Anandbagh (ALM Janardhan)	-
3		Street no 8	Laxmi nagar	11KV	Habsiguda	14.56	16.45	01.49		11kv Disk & Pin insulator fail& replaced at Sri Sai Pragathi APpt	-
4		Thattiannaram	Thattiannaram	11KV	Sarooranagar	01.20	03.30	02.10	EL	11KV PIN INSULATOR FAIL AT THATTIANNARAM	-
5		Aushapur	Chandupattla guda	11KV	Habsiguda	15.00	18.00	03.00		11kv line twested at Edulabad	-
6		Rampally	Veneguda	11KV	Habsiguda	15.30	16.35	01.05		11kv line cut at Manna Engineering collageopp Ssyard	-
7		Yardarpally	Cheryala	11KV	Habsiguda	15.25	17.35	02.10		Post of insulator fail at cheryala Laxmi narshima temple	-
8		Yardarpally	Thimaipally	11KV	Habsiguda	17.00	18.20	01.20		11kv line cut at Thimaipally village	
9		Narapally	Industrial	11KV	Habsiguda	14.57	16.45	01.48		Tree baranches fallen on 11kv line at Revathi rice mile narapally road	
10		Narapally	Narapally	11KV	Habsiguda	07.10	08.20	01.10		11kv jumper cut at Telephone exchange narapally	
11		Abdullapermet	Batasingaram	11KV	Sarooranagar	04.30	06.20	01.50	EL	11KV DISK FAIL AT BATASINGARAM	
12		Abdullapermet	Batasingaram	11KV	Sarooranagar	15.20	17.20	02.00	OL	TREE BRCHANS FALLOW ON 11KV LINE AT KOTHA GUDA	-
13		Pedda Amberpet	Industrial	11KV	Sarooranagar	16.00	19.00	03.00	EL/OL	TREE BRCHANS FALLOW ON 11KV LINE AT PEDDA AMBERPET	-
1	HYD N	Mothi Nagar	Rajiv Nagar	11KV	Erragadda	01.06	02.55	01.49	EL	I/C Cable fault at beside SS	-
2		K.I.M.S.	Nakshatra	11KV	Sec-bad	03.05	05.50	02.45	EL	Faulty 11KV Chikoti feeder loads	-
3		Janapriya	I.O.L	11KV	Erragadda	14.40	15.45	01.05	EL,OL-Rph	Tree branches fallen on lines at P.R.Nagar Chowrasta	-
4		Road No.12	Kanaka Durga	11KV	Banjarahills	15.02	16.08	01.06	EL	Tree branches fallen on lines at Singadi Kunta	-
5		Clock Tower	Natraj	11KV	Sec-bad	14.50	16.10	01.20	EL,OL-Rph	No Visible fault	-
6		Nehru Nagar	Contonement	11KV	Sec-bad	14.42	16.24	01.42	OL-Rph	Big Tree fallen on lines at Banjara Arcade	-
7		Gymkhana	Pared Ground	11KV	Sec-bad	14.42	17.00	02.18	EL	Big Tree fallen on lines at Polo	-
8		Kundan Bagh	B.S.Maktha	11KV	Erragadda	14.42	16.07	01.25	EL,OL-Rph	Tree branches fallen on lines at Rakesh Kiran Shop	-
9		R.P.Nilayam	Nagadevatha	11KV	Bowenpally	14.52	16.20	01.28	EL	HT Service fault at Military Area	
10		Road No.12	Kanaka Durga	11KV	Banjarahills	15.05	16.15	01.10	EL	Tree branches fallen on lines at Mithila Nagar	
11		Chilkaalguda	Gandhi Hospital	11KV	Sec-bad	16.05	17.30	01.25	All Indication	Cable fault	Arranged B/F on 11KV P.R.Nagar fdr
12		Bansilalpet	Botany School	11KV	Sec-bad	18.50	20.08	01.18	EL,OL-Rph	HT Line snapped at Hari Ganga Bowli	
13		Madhapur	Vaishanavi Residency	11KV	Banjarahills	20.25	21.35	01.10	EL,OL	Cable fault	Arranged B/F on 11KV Kummar Basti feeder
14		R.P.Nilayam	Saraswathi Nagar	11KV	Bowenpally	21.30	22.45	01.15	EL	Faulty DTR at Sri Sai Appartment	-
1	HYD S	Malakpet	Chaderghat	11KV	Asmangadh	00.05	01.30	01.25	OL-Bph	Cable End Kit failed at Chaderghat	-
2		Chanchalguda	Madannapet	11KV	Asmangadh	06.25	08.25	02.00	EL,OL	Pin Insulator flash over at Gandamguda	-
3		Chanchalguda	Madannapet	11KV	Asmangadh	09.02	10.26	01.24	EL,OL-Rph	Pin Insulator flash over at Madannpet	-
4		E.N.T.	Rang Mahal	11KV	Begumbazar	11.45	12.50	01.05	All Indication	Snapped Conductor at Rang Mahal	-
5		Kandikal Gate	G.M Chowni	11KV	Charminar	12.35	13.55	01.20	EL	Kite Stick fallen on lines at Qhadri Chaman	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
6		Womens College	Quthbiguda	11KV	Begumbazar	11.50	13.50	02.00	OL	HT Jumper Cut at Quthbiguda	-
7		Falaknuma	Fathima Nagar	11KV	Charminar	16.00	17.27	01.27	All Indication	Pin Insulator falsh over Mohammadiya Masjid	Arranged B/F on 11KV Farooq Nagar fdr
1	HYD C	Nampally	FAPCCI	11KV	Mehdipatnam	08.38	09.41	01.03	EL,OL	Brass Patti B/O & Faulty DTR at Pandabha PT	-
2		Vittalwadi	I.C.I.C.I.	11KV	Saifabad	10.35	12.15	01.40	EL	Cable fault	Arranged B/F on 11KV Urdu Hall fdr
3		Amberpet	C.P.L	11KV	Azamabad	14.50	17.00	02.10	EL	Disc Insulator failed at C.P.L	-
4		Chilkaiguda	Musheerabad	11KV	Saifabad	15.05	16.55	01.50	EL,OL-Rph	Tree branches fallen on lines	-
5		Vittalwadi	Gandhi Kuteer	11KV	Azamabad	15.10	16.20	01.10	EL,OL-Rph	Tree branches fallen on lines at H.V.Colony	-

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201	1	1	1	1	1	1			
5	RR(N)	82	407		22		22		22			
6	RR(E)	38	360		13		13		13			
7	Hyd	186	1014		26		26		26			
	Total	504	2929	1	62	1	62	1	62	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969		5		5		5			
2	NLG	150	948		3		3		3			
3	MDK	87	828	4	4	4	4	4	4			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	4	12	4	12	4	12	0	0	
	Grand Total	908	6149	5	74	5	74	5	74	0	0	