

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		1		1		1			
5	RR(N)	82	407		2		2		2			
6	RR(E)	38	360		3		3		3			
7	Hyd	186	1014	1	6	1	6	1	6			
	Total	504	2929	1	12	1	12	1	12	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	2	1	2	1	2	1			
2	NLG	150	948		10		10		10			
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	2	11	2	11	2	11	0	0	
	Grand Total	908	6149	3	23	3	23	3	23	0	0	

TSSPDCL - LMRC / Corporate office

Date: 20.07.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Nagarkurnool	Bijinapally	33KV	Nagarkurnool	11.55	14.33	02.38	E/L	33KV Jumper cut near Palem	Bijinapally	-
2		Achampet	Lingal	33KV	Nagarkurnool	06.15	08.10	01.55	O/L	Tree Branches Fallen on the Line near Mailaram (V)	Lingal	-
1	HYD S	220KV Ch' Gutta	Santosh Nagar	33KV	Malakpet	03.30	03.35	00.05	EL,OL-Rph	AB Switch Rph, End Kit failed at Champapet	Santosh Nagar	Loads transferred onto 220KV Ch' Gutta SS via 33KV Santosh Nagar OH fdr at 18.10 hrs Idle fdr charged stood OK after rectifying End Kit

TSSPDCL - LMRC / Corporate office

Date: 20.07.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kothamolgara	Kothamolgara	11KV	Jadcherla	08.40	10.30	01.50		Tree Fallen On The 11KV Line Near Peddakappeta(V)	-
1	NLG	B Chandupatla	Bheemlathanda	11KV	Suryapet	11.00	12.55	01.55	E/L	Jumper cut	-
2		Palakeedu	Bothalapalem	11KV	Huzurnagar	03.00	06.00	03.00	OL	11Kv Disk Failure Near Bothalapalem village	-
3		Bheelyanaik thanda	Pathathanda	11KV	Huzurnagar	09.55	13.20	03.25	EL	11Kv line cutted cutted near Pathathanda village	-
4		Ravipahad	Burkacherla	11KV	Huzurnagar	08.20	11.20	03.00	EL	11Kv Jumper cut near Burkacherla village	-
5		Repala	V R Puram	11KV	Huzurnagar	11.00	14.00	03.00	EL	11Kv Disk Failure Near V R Puram village	-
6		Alair	Ikkurthy	11KV	Bhongir	08.40	11.30	02.50	EL	ss-5 Manthapuri Jumper snapped	-
7		Marriguda	Konduru	11KV	Devarakonda	08.00	11.00	03.00	EL	Jumper cut	-
8		D.Nagaram	Peepalpahad	11KV	Nalgonda	09.30	11.40	02.10	EL	11 KV Jumper Cut	-
9		Ghattuppal	Lachammagudem	11KV	Nalgonda	08.30	12.00	03.30	EL	11 KV Jumper Cut	-
10		Thipparthi	GG Palem	11KV	Nalgonda	10.30	14.00	03.30	EL	11 KV Jumper Cut	-
1	RR S	Kathedhan I	Feder 4	11KV	RJNR	14.00	18.30	04.30		11 KV CT Fail at SS	-
1	RR N	ESCI	ESCI	11KV	Gachibowli	05.10	06.30	01.20	BD	11KV Line Cut At Care Hospital Beside	-
2		GP Pally	GP Pally	11KV	Medchal	03.20	04.10	00.50	BD	Tree Fallen on the 11KV Line at Sunita House,GP Pally	-
1	RR E	Vinayak Nagar	Old Safilguda	11KV	SKP	01.35	02.40	01.05		11Kv Pin Insuletor failure at Petrol Bunk Old Safilguda (L Insp Nageshwar Rao)	-
2		Narapally	Pratapsingaram	11KV	HBG	14.50	15.50	01.00		Copper Patti cut and touched AB Switch at Maktha	-
3		Keesara	Ankireddypally	11KV	HBG	11.50	12.40	00.50		Line patrolling but no fault	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD S	Santosh Nagar	Jyothi Bagh	11KV	VIII	01.40	04.02	02.22	EL	Breaker Fault at SS	Arranged B/F on 11KV Jahingir Ngr & Saleema Khatoon fdrs
2		Kandikal Gate	G.M.Chowni	11KV	III	02.15	03.40	01.25	EL	Cable fault	Arranged B/F on 11KV Ravindra Naik Nagar fdr
3		C.R.P.F	Omar Colony	11KV	III	12.40	14.55	02.15	EL,OL-Rph	Cable fault	Arranged B/F on 11KV Baba Nagar feeder
4		Falaknuma	Vatte Pally	11KV	III	17.42	18.45	01.03	EL,OL-Bph	HT Lines twisted at Hanuman Temple	-
1	HYD C	Industrial Area	R.O.M	11KV	II	15.40	19.05	03.25	EL,OL-Rph	Cable fault at VST Bus Stop	Arranged B/F on 11KV Azamabad Key SS fdr
2		A.C.Gaurds	Bazarghat	11KV	VII	13.40	15.06	01.26	EL,OL-Bph	Cable fault	Arranged B/F on 11KV Bada Masjid & Niloufer fdrs